



Firefighting Water Supplies

Central-North Otago Fire Area.
Five Mile, Building 1, Suite 1, Level 1,
34 Grant Road, Frankton,
Queenstown, 9349.

30 June 2025

Re: Hydrant system and Roothing

Dear Lauren,

Thank you for taking the time to work with Fire and Emergency New Zealand to ensure the Film Hub and Hotel site at Ayrburn meets the requirements regarding the hydrant system layout and roading for firefighting purposes.


You've provided plans showing the hydrants are no further than 135metres from each other and the roading is a minimum of 6 metres wide.

FENZ see no issues after reviewing these initial plans.

If you have any further questions, then please do not hesitate to contact me.

Kind regards,

Claire Jones
Risk Reduction Advisor



Appendix A

