

Engineering Geology Ltd

- **)** +64 9 486 2546
- info@egl.co.nz
- Unit 7C, 331 Rosedale Road, Albany, Auckland PO Box 301054, Albany, Auckland 0752
- www.egl.co.nz

EGL Ref: 9702

MATAKANUI GOLD LIMITED BENDIGO-OPHIR GOLD PROJECT SITE-SPECIFIC SEISMIC HAZARD STUDY REPORT

Prepared for: 08 August 2025

Matakanui Gold Limited







EXECUTIVE SUMMARY

This report provides a site-specific seismic hazard assessment (SSSHA) for the Bendigo-Ophir Gold Project (BOGP). The results are required for the safe design of the Tailings Storage Facility (TSF) in accordance with the New Zealand Dam Safety Guidelines (NZDSG) published in 2024 (Ref. 1). The results are suitable for other structures, with due consideration for the specific basis of design being applied and compliance with the Building Act (Ref. 9), Regulations and Codes (Ref. 10).

Peak ground acceleration (PGA) and spectral acceleration values are provided along with mean magnitudes for design.

For the site, the seismic hazard contribution from shallow crustal earthquakes is the most notable. This includes known and undefined faults in the wider local region, with notable contribution from the Alpine Fault at the 1 in 150 year level. The Alpine Fault (closest distance of \sim 115km, potential magnitude up to M_w 8.6) is considered as a shallow crustal fault. At 1 in 10,000 year levels of shaking, at shorter spectral periods, including those typical of the TSF embankment, it is the local faults, known and undefined, that contribute most to the seismic hazard at this intensity level, and less so the Alpine Fault. The Puysegur Margin Subduction Zone (closest distance \sim 90 km) has a contribution. It contributes at all spectral periods for the OBE (33 to 48 %) and long spectral periods for the SEE (26 to 40 %). The TSF will be designed to be robust and safe from all potential earthquake sources contributing to the seismic hazard.

There are two nearby active fault sources contributing to the seismic hazard, the Dunstan (closest distance of 9 km) and Pisa (closest distance of 13 km) fault systems, with maximum magnitude estimates between $M_{\rm w}$ 7.1 and 8.3. The Pisa fault system aligns with the branches of the Cluden (15 km), and Grandview Faults (15 km) which can act together. Table 1 in the report provides a further summary of the characteristics of these fault sources which are shown in Figure 1. There are no known active faults expressed at the surface through the BOGP site.

DOCUMENT CONTROL

Document information

Title	Matakanui Gold Limited, Bendigo-Ophir Gold Project, Site-Specific		
	Seismic Hazard Study Report		
Revision	2		
Date	08 August 2025		
EGL Reference	9702		
Client Reference	-		
File Name	EGL9702 - BOGP Site Specific Seismic Hazard Study Report_Rev		
	2.docx		

Document roles and approvals

Role	Name	Credentials	Signature	Doc. Rev.	Date
Author	Y. Wang	BE (Hons) Civil, MEng (Hons), PhD		2	08/08/2025
Reviewer	E. Torvelainen	BE (Hons) Civil, MEngNZ		2	08/08/2025
EGL Approval	E. Torvelainen	Director		2	08/08/2025

Final copy issue requires signatures.

Document revision and issue record

Revision.	Date	Revision Description	Issue by
0	05/06/2025	Final	E. Torvelainen
1	04/07/2025	Exec. Sum., Section 4.2, Table 5	E. Torvelainen
2	08/08/2025	Revision to disclaimers	E. Torvelainen

Draft revisions are given alphabetic characters. Final copy issue and subsequent revision are given numeric characters.

Document applicability and disclaimers

This report has been prepared by EGL (Engineering Geology Limited) solely for the benefit of Matakanui Gold Limited as our client with respect to the particular brief given to us for the Bendigo-Ophir Gold Project. If used by other parties and/or used in any other context or for any other purposes, no warranty or representation is given as to its accuracy and no liability is accepted for loss or damage arising directly or indirectly from reliance on the information in it.

This report shall only be read in its entirety.

Where this report is issued in draft the contents shall be for initial information and review only and are subject to change and shall not be relied upon.

The author of this report acknowledges that this report will be relied on by a Panel appointed under the Fast Track Approvals Act 2024 and these disclaimers do not prevent that reliance.

CONTENTS

	Page No.
1.0 INTRODUCTION	5
2.0 SITE DESCRIPTION	5
3.0 METHODOLOGY	6
4.0 RESULTS AND DISCUSSION	6
4.1. Probabilistic seismic hazard results	6
4.2. Disaggregation of the probabilistic seismic hazard results	7
4.3. Deterministic seismic hazard results	7
4.4. Aftershock	7
4.5. Orientation of ground motion parameters	8
5.0 RECOMMENDED DESIGN SPECTRA	8
6.0 CONCLUSION	9
REFERENCES	9
TABLES 1 TO 8	
FIGURES 1 TO 7	
APPENDIX A – PROBABILISTIC SEISMIC HAZARD ANALYSIS (PSHA) I	PLOTS
APPENDIX B – HAZARD DISAGGREGATION PLOTS	

APPENDIX C – DETERMINISTIC SEISMIC HAZARD ANALYSIS (DSHA) PLOTS



Engineering Geology Ltd

) +64 9 486 2546

info@egl.co.nz

- Unit 7C, 331 Rosedale Road, Albany, Auckland PO Box 301054, Albany, Auckland 0752
- www.egl.co.nz

EGL Ref: 9702

08 August 2025

MATAKANUI GOLD LIMITED BENDIGO-OPHIR GOLD PROJECT SITE-SPECIFIC SEISMIC HAZARD STUDY REPORT

1.0 INTRODUCTION

Engineering Geology Limited (EGL) has been engaged by Matakanui Gold Limited (MGL) to provide a site-specific seismic hazard assessment (SSSHA) for the Bendigo-Ophir Gold Project (BOGP). The BOGP is located on the Bendigo and Ardgour Stations in the Dunstan Mountains of Central Otago. MGL is a subsidiary company of Santana Minerals Limited (SML).

This report presents the brief methodology and results of the SSSHA for the site. The results are required for the design of the Tailings Storage Facility (TSF) in accordance with the New Zealand Dam Safety Guidelines (NZDSG) published in 2024 (Ref. 1). The TSF will be designed as a High Potential Impact Classification (PIC) dam as defined by NZDSG (Ref. 1). The results of the SSSHA may also be useful for other design purposes.

Results were developed using the 2022 National Seismic Hazard Model (NSHM22, Ref. 2) using OpenQuake Engine (Ref. 3). NSHM22 represents a fundamental revision of the seismic hazard science in New Zealand. It incorporates the latest developments in scientific understanding of seismic sources within New Zealand and state-of-art knowledge with respect to estimation of seismic hazard.

2.0 SITE DESCRIPTION

The BOGP site is located in the Dunstan Mountains of Central Otago Region, approximately 20 km northeast of Cromwell. The site lies within Otago Schist, along the boundary of textural zones 3 and 4 (TZ3 and TZ4), separated by the Thomson Gorge Fault (TGF), a nonactive reverse fault with an 8 km offset. The schist originated from Permian-Triassic sedimentary rocks, metamorphosed during the Cretaceous period under greenschist facies conditions. Orogenic gold mineralisation occurred in the Rise and Shine Shear Zone (located on the BOGP site) during this metamorphism. The region has undergone multiple faulting events related to the Alpine Fault since 25 Mya, with glaciation shaping the valleys, leaving moraines and tills from the last glaciation (~650 kya).

The coordinates of the site used in this SSSHA are Latitude -44.951°, Longitude 169.430° in the World Geodetic System 1984 (WGS84). According to the New Zealand Community Fault Model (CFM, Ref. 4), there are two nearby active fault systems, the Dunstan (closest distance 9 km) and Pisa (closest distance 13 km) faults systems. The Cluden, and Grandview faults are also nearby and can act a part of the Pisa fault system. Figure 1 shows the locations of the site and nearby active faults. The characteristics of the Dunstan, Pisa, Cluden, and







Grandview faults are summarised in Table 1. There are no known active faults expressed at the surface through the BOGP site.

Earthquake design loads are affected by the subsurface ground conditions present at a site. This SSSHA utilises V_{s30} , the time average shear wave velocity of the upper 30 m of soil and rock, as the parameter to characterise the local ground conditions. Initial measurements of shear wave velocity of the rock at the TSF indicate a design value of approximately V_{s30} 1000 to 1500 m/s. Representative V_{s30} values for different site conditions, including 850, 1000, and 1500 m/s were run. The V_{s30} value range represents rock conditions, with no or very shallow stiff soil cover.

3.0 METHODOLOGY

Aligning with the requirements in NZDSG 2024 for a High PIC dam, two design earthquake levels have been assessed. They are:

- The Operating Basis Earthquake (OBE) based on mean probabilistic values with a 1 in 150 year Annual Exceedance Probability (AEP).
- Safety Evaluation Earthquake (SEE), either based on mean probabilistic values with a 1 in 10,000 year AEP or 84th percentile values from deterministic results from the Controlling Maximum Earthquake (CME). For the SEE an aftershock one magnitude less than the main shock shall also be considered.

The probabilistic seismic hazard analysis (PSHA) was undertaken using the OpenQuake engine (Ref. 3). OpenQuake has been developed by the Global Earthquake Model (GEM) Foundation and is widely used in the international earthquake engineering profession. The application of the NSHM2022 in the OpenQuake engine was developed by the New Zealand scientific community.

Probabilistic estimates of peak ground acceleration and spectral accelerations have also been provided at 1 in 500 and 1 in 2,500 AEPs.

Deterministic seismic hazard analyses (DSHA) for the CME have used the ground motion characterisation models (GMCMs) and the associated logic tree weightings applied in NSHM22 for New Zealand (Ref. 2).

4.0 RESULTS AND DISCUSSION

4.1. Probabilistic seismic hazard results

PSHA peak ground acceleration (PGA) and spectral acceleration (SA) results, for V_{s30} values of 850, 1,000, and 1,500 m/s are summarised in Tables 2 to 4. The results for mean spectral acceleration (SA_{RotD50}) for the OBE (1 in 150 AEP) and SEE (1 in 10,000 AEP) design cases are plotted in Figure 2, 3 and 4, along with the SEE aftershock. Spectral acceleration for 1 in 150 AEP, 1 in 500 AEP, 1 in 2,500 AEP, and 1 in 10,000 AEP and plotted together in Appendix A as additional information.

4.2. Disaggregation of the probabilistic seismic hazard results

Disaggregation plots of the earthquake sources contributing to PSHA for PGA, SA(0.15s), SA(0.5s), SA(1.0s), and SA(3.0s) are presented in Appendix B. Tables 5 and 6 summarise the mean magnitudes, mean rupture distances, and Tectonic Region Type (TRT) contributions for the 1 in 150 AEP and 1 in 10,000 AEP events. The table results and disaggregation plots indicate that the seismic hazard contribution from shallow crustal earthquakes are the most notable. This includes known and undefined faults in the wider local region, with notable contribution from the Alpine Fault at the 1 in 150 year level. Note the Alpine Fault (closest distance of ~115 km) is grouped in the shallow crustal faults in Table 5 and 6. At 1 in 10,000 year levels of shaking, at shorter spectral periods (PGA, 0.15 s, and 0.5 s), the mean rupture distance of 20 km to 34 km indicates that it is the local faults, known and undefined, that contribute most to the seismic hazard at this intensity level, and less so the Alpine Fault. The Puysegur Margin Subduction Zone (closest distance ~90 km) has a contribution indicated by the Subduction Interface and Subduction Intraslab contribution in Table 5. It contributes at all spectral periods for the OBE (33 to 48 %) and long spectral periods for the SEE (26 to 40 %).

4.3. Deterministic seismic hazard results

To assess the CME the maximum potential rupture from any earthquake source which has a 100,000 year average recurrence interval or less were considered. They were:

- Dunstan Fault, magnitude M_w =8.0 rupture, at 9 km distance, 84%ile motion
- Pisa Fault, magnitude M_w =8.2 rupture, at 13.1 km distance, 84%ile motion
- Alpine Fault, magnitude M_w =8.6 rupture, at 115 km distance, 84%ile motion

The CME is determined to be a magnitude M_w 8.0 rupture on the Dunstan Fault at 9 km distance. The response spectra for the Dunstan Fault rupture 84th percentile values are shown in Figures 5 to 7 for the different V_{s30} values against the PSHA spectra mean, 10^{th} percentile and 90^{th} percentile values. In Appendix C in Figures C1 to C3, deterministic 84th percentile spectra calculated for the Dunstan, Pisa, and Alpine Fault are all shown against the mean PSHA spectra. Tables C1 to C3 in Appendix C provide the data.

A magnitude $M_w = 8.8$ rupture on the Puysegur Margin Subduction Zone, at 90 km distance was also checked. This was not the critical rupture for the CME.

For comparison, the PSHA 1 in 10,000 year AEP result with the deterministic Dunstan Fault Rupture is shown in Figures 5 to 7 for different $V_{\rm s30}$ values. The $84^{\rm th}$ percentile magnitude 8.0 rupture on Dunstan Fault is higher than the 1 in 10,000 year probabilistic spectra for nearly all spectral periods. NZDSG requires the TSF to be designed for the lesser of the 1 in 10,000 year or CME response spectra. The 1 in 10,000 year response spectra is recommended for the TSF SEE design case. Tables 2 to 4 and Figures 2 to 4 summarise the recommended response spectra for the TSF.

4.4. Aftershock

Aftershock PGA and response spectra values were derived deterministically. For peak ground acceleration and short spectral periods (0.15 s) the 1 in 10,000 year PSHA

mean magnitude and mean rupture distance is M_w 6.7 to 6.8 at 20 km. Taking M_w 6.8 as the mean magnitude for the main earthquake shock, a magnitude M_w 5.8 was used to develop the response spectra for the aftershock. This is one magnitude less than the main shock. This approach aligns with NZDSG 2024 guidelines (Ref. 1). The rupture distance was set at D=9 km for this calculation and standard deviation parameter (epsilon) adjusted to achieve a consistent basis for the main shock and aftershock spectra. This approach determines the shape of the spectra and the drop in magnitude reduces the intensity of shaking or loading. Note for spectral period 0.5 s the mean magnitude is M_w 7.5 for the main shock. The same aftershock spectra can be used for 0.5 s, as for the shorter periods. However, the magnitude for the aftershock shall be taken as M_w 6.5. The aftershock spectra for different V_{s30} values are provided in Tables 2 to 4 and Figures 2 to 4 with the OBE and and SEE spectra. The aftershock spectra for the different V_{s30} values are plotted together in Figure C4 for comparison, in Appendix C. Table C4 in Appendix C provides the aftershock data.

4.5. Orientation of ground motion parameters

All results presented in this report are for the median of the maximum spectral acceleration observed over all horizontal orientations, termed SA_{RotD50}.

SA_{RotD50} is considered appropriate for the design of structures that are azimuth-dependent, i.e., the dynamic properties of the structure (e.g., stiffness) are dependent on the orientation being considered (Ref. 5). The SA_{RotD50} is appropriate for the geotechnical design, if the design method itself is derived based on SA_{RotD50} (for example when using the Bray and Macedo method (Ref. 6) for embankment displacement estimation).

For azimuth-independent structures (e.g., a structure whose footprint is axisymmetric such as silos and circular tanks), the 100th percentile (i.e., maximum) of the SA value (SA_{RotD100}) obtained by rotating the horizontal components through all angles may be more appropriate (Ref. 7). Modification ratios to obtain SA_{RotD100} from SA_{RotD50} based on Boore and Kishida (Ref. 8) are provided in Table 7, if required.

For many years in New Zealand the parameter SA_{Larger} has been used for building design response spectra. This is the larger component of the two recorded horizontal records and is typically less than $SA_{RotD100}$ and more than SA_{RotD50} . Modification ratios to obtain SA_{Larger} from SA_{RotD50} based on Boore and Kishida (Ref. 8) are provided in Table 7, if required.

When selecting response spectra for design, the designer should consider the design basis for the specific structure and which parameter is appropriate to use.

5.0 RECOMMENDED DESIGN SPECTRA

The report presents the results of a SSSHA for the BOGP. The assessment has been undertaken for the TSF. However, the results may be useful for other design purposes with due consideration for the basis of design or assessment and compliance with the Building Act (Ref. 9), Regulations and Codes (Ref. 10).

For the TSF (as a High PIC dam) the design response spectra for SA_{RotD50} for the OBE, SEE, and aftershock levels of shaking are summarised in Tables 2 to 4 and shown in Figures 2 to 4.

For design, magnitude is often required to apply with the selected design shaking intensity parameter. Mean magnitudes are provided in Tables 5 and 8.

The response spectra and seismicity parameters are based on a free-field ground motion (i.e., relatively flat or gently sloping ground). Topographic amplifications effects for embankments are to be applied separately in the TSF assessment.

PGA and SA values have been provided for three V_{s30} values, 850, 1000, and 1500 m/s. The V_{s30} values represent sites with rock conditions, with no or very shallow stiff soil cover. If other V_{s30} values are required, EGL can run the NSHM for other specific values.

6.0 CONCLUSION

A SSSHA has been completed for the proposed TSF at the BOGP. PGA and SA values are provided along with mean magnitudes for design. The results are suitable for other structures, with due consideration for the specific basis of design being applied and compliance with the Building Act (Ref. 9), Regulations and Codes (Ref. 10). The SSSHA includes many earthquake sources. The TSF will be designed to be robust and safe from all potential earthquake sources contributing to the seismic hazard.

REFERENCES

- 1. New Zealand Society of Large Dams (NZSOLD). (2024). 'New Zealand Dam Safety Guidelines'.
- 2. Gerstenberger, M. C., Bora, S., Bradley, B. A., DiCaprio, C., Van Dissen, R. J., Atkinson, G. M., Chamberlain, C., Christophersen, A, Clark, K. J., Coffey, G. L., et al. (2022). 'New Zealand National Seismic Hazard Model 2022 Revision: Model, Hazards and Process Overview', Lower Hutt (NZ): GNS Science. 106 p. (GNS Science Report; 2022/57).
- 3. Pagani, M., Monelli, D., Weatherill, G., Danciu, L., Crowley, H., Silva, V., Henshaw, P., et al. (2014). 'OpenQuake engine: An Open Hazard (and Risk) Software for the Global Earthquake Model', Seismological Research Letters, Vol. 85, Issue 3, pp. 692-702.
- 4. Seebeck, H., Van Dissen, R., Litchfield, N., Barnes, P., Nicol, A., Langridge, R., Barrell, D. J. A., Villamor, P., Ellis, S., Rattenbury, M., et al. (2022), 'New Zealand Community Fault Model version 1.0'. Lower Hutt (NZ): GNS Science. (GNS Science report; 2021/57).
- 5. Stewart, J. P., Abrahamson, N. A., Atkinson, G. M., Baker, J. W., Boore, D. M., Bozorgnia, Y., et al. (2011). 'Representation of Bidirectional Ground Motions for Design Spectra in Building Codes', Earthquake Spectra, Vol. 27, Issue 3, pp. 927-937.
- 6. Bray, J. D. & Macedo, J. (2019). 'Procedure for Estimating Shear-Induced Seismic Slope Displacement for Shallow Crustal Earthquakes', Journal of Geotechnical and Geoenvironmental Engineering, Vol. 145, Issue 12, p. 04019106.

- 7. NZSEE (2009). 'Seismic Design of Storage Tanks: 2009', New Zealand Society for Earthquake Engineering.
- 8. Boore, D.M. & Kishida, T. (2017). 'Relations between Some Horizontal-Component Ground-Motion Intensity Measures Used in Practice', Bulletin of the Seismological Society of America, Vol. 107, Issue 1, pp. 334-343.
- 9. New Zealand Building Act 2004, https://www.legislation.govt.nz/
- 10. New Zealand Building Regulations 1992, https://www.legislation.govt.nz/

TABLES

1 TO 8

List of Tables

Table 1	Summary of Known Active Faults within about 20 km of the Dam Site (based on CFM)
Table 2	Response Spectra (5% Damped) for Design and Evaluation of BOGP (unit: g) with $V_{\rm s30} = 850~\text{m/s}$
Table 3	Response Spectra (5% Damped) for Design and Evaluation of BOGP (unit: g) with $V_{\rm s30}$ = 1,000 m/s
Table 4	Response Spectra (5% Damped) for Design and Evaluation of BOGP (unit: g) with $V_{\rm s30}$ = 1,500 m/s
Table 5	Mean Magnitude and Distance from Hazard Disaggregation
Table 6	Average Magnitude and Distance from Hazard Disaggregation
Table 7	Conversion Ratios for different SA Values for Consideration of Ground Motion Orientations
Table 8	Design Seismic Parameters for Geotechnical Analysis

TABLE 1: Summary of Known Active Faults within about 20 km of the Dam Site (based on CFM).

Name	Dunstan	Pisa	Cluden**	Grandview**
Fault ID	771	772	770	767
Source-to-site Distance, Rrup (km)	9.0	13.1	14.7	15.4
Domain Name	Otago	Otago	Otago	Otago
Magnitude (Mw)*	7.15 to 7.95	7.75 to 8.25	7.35 to 8.05	7.85 to 8.35
Mean Rate (per year)	3.61e-6 to 8.94e-5	7.36e-7 to 2.54e-5	2.55e-7 to 5.38e-6	2.94e-7 to 2.19e-5
Dip (°)	45	45	60	60
Dip Direction	NW	W	NW	Е
Dominant Sense of Movement	Reverse	Reverse	Reverse	Reverse
Subordinate Sense of Movement	Null	Dextral	Dextral	Sinistral
Rake (°)	90	110	110	70
Average Slip Rate (mm/year)	0.5	0.1	0.1	0.1
Depth (km)	28.0	28.9	27.1	26.9
Length (km)	60.9	48.5	25.9	29.4

^{*} Includes rupture of multiple segments of adjacent faults together.

** Cluden and Grandview Faults are adjacent to the Pisa Fault and align with this fault system.

TABLE 2. Response Spectra (5% Damped) for Design and Evaluation of BOGP (unit: g) with $V_{s30} = 850 \ m/s.$

	BOGP ($Vs30 = 850 \text{ m/s}$)				
Period (s)	OBE (1 in 150 AEP)	SEE (1 in 10,000 AEP)	Aftershock	1/500 AEP	1/2,500 AEP
PGA	0.130	0.920	0.433	0.245	0.512
0.01	0.130	0.920	0.454	0.245	0.512
0.02	0.137	0.979	0.515	0.260	0.543
0.03	0.154	1.106	0.596	0.293	0.613
0.04	0.177	1.280	0.918	0.336	0.705
0.075	0.256	1.934	1.046	0.490	1.047
0.1	0.285	2.181	1.131	0.546	1.175
0.15	0.305	2.355	1.039	0.585	1.266
0.2	0.290	2.234	0.923	0.556	1.202
0.25	0.267	2.013	0.815	0.510	1.096
0.3	0.243	1.829	0.641	0.465	0.997
0.4	0.205	1.533	0.517	0.392	0.839
0.5	0.174	1.304	0.328	0.336	0.718
0.75	0.125	0.937	0.226	0.245	0.524
1	0.097	0.718	0.120	0.190	0.406
1.5	0.063	0.456	0.077	0.124	0.264
2	0.047	0.338	0.038	0.094	0.198
3	0.027	0.198	0.024	0.056	0.116
4	0.019	0.142	0.017	0.040	0.086
5	0.014	0.110	0.012	0.030	0.066
6	0.011	0.085	0.008	0.023	0.051
7.5	0.008	0.064	0.005	0.017	0.038
10	0.005	0.044	0.433	0.012	0.026

TABLE 3. Response Spectra (5% Damped) for Design and Evaluation of BOGP (unit: g) with $V_{s30} = 1,\!000\ m/s.$

	BOGP ($Vs30 = 1,000 \text{ m/s}$)					
Period (s)	OBE (1 in 150 AEP)	SEE (1 in 10,000 AEP)	Aftershock	1/500 AEP	1/2,500 AEP	
PGA	0.120	0.850	0.400	0.226	0.472	
0.01	0.120	0.850	0.419	0.226	0.472	
0.02	0.127	0.907	0.480	0.240	0.503	
0.03	0.144	1.037	0.561	0.273	0.573	
0.04	0.166	1.217	0.871	0.317	0.668	
0.075	0.243	1.864	0.984	0.467	1.004	
0.1	0.268	2.084	1.042	0.515	1.116	
0.15	0.280	2.185	0.939	0.538	1.169	
0.2	0.262	2.027	0.822	0.502	1.088	
0.25	0.237	1.797	0.717	0.454	0.976	
0.3	0.214	1.613	0.556	0.409	0.879	
0.4	0.178	1.333	0.445	0.341	0.730	
0.5	0.150	1.124	0.282	0.290	0.620	
0.75	0.109	0.807	0.194	0.212	0.453	
1	0.084	0.618	0.103	0.163	0.351	
1.5	0.055	0.393	0.067	0.108	0.228	
2	0.041	0.292	0.035	0.082	0.171	
3	0.024	0.180	0.024	0.051	0.107	
4	0.018	0.138	0.016	0.038	0.082	
5	0.013	0.107	0.012	0.029	0.064	
6	0.010	0.084	0.008	0.022	0.049	
7.5	0.008	0.063	0.005	0.017	0.037	
10	0.005	0.043	0.400	0.011	0.025	

TABLE 4. Response Spectra (5% Damped) for Design and Evaluation of BOGP (unit: g) with $V_{s30} = 1{,}500 \ m/s.$

	BOGP ($Vs30 = 1,500 \text{ m/s}$)				
Period (s)	OBE (1 in 150 AEP)	SEE (1 in 10,000 AEP)	Aftershock	1/500 AEP	1/2,500 AEP
PGA	0.106	0.752	0.351	0.198	0.415
0.01	0.106	0.752	0.370	0.198	0.415
0.02	0.112	0.806	0.428	0.211	0.444
0.03	0.128	0.932	0.507	0.243	0.512
0.04	0.149	1.109	0.792	0.286	0.605
0.075	0.221	1.718	0.885	0.425	0.919
0.1	0.239	1.890	0.917	0.462	1.005
0.15	0.244	1.934	0.815	0.471	1.027
0.2	0.224	1.762	0.706	0.431	0.939
0.25	0.201	1.545	0.615	0.385	0.833
0.3	0.181	1.383	0.479	0.347	0.749
0.4	0.150	1.144	0.388	0.291	0.625
0.5	0.129	0.974	0.250	0.250	0.537
0.75	0.096	0.712	0.175	0.186	0.400
1	0.075	0.554	0.095	0.146	0.315
1.5	0.050	0.360	0.063	0.099	0.209
2	0.038	0.278	0.034	0.078	0.162
3	0.023	0.174	0.023	0.048	0.103
4	0.017	0.136	0.016	0.036	0.080
5	0.013	0.106	0.012	0.028	0.062
6	0.010	0.083	0.008	0.022	0.048
7.5	0.007	0.062	0.005	0.016	0.036
10	0.005	0.043	0.351	0.011	0.025

TABLE 5. Mean Magnitude and Distance from Hazard Disaggregation.

	Intonsity			TRT Contribution (%)		
AEP	Intensity Measures	$\mathbf{M}_{\mathbf{w}}$	D (km)	Shallow	Subduction	Subduction
	Measures			Crust	Interface	Intraslab
	PGA	6.4	83	67	26	7
	SA(0.15)	6.3	74	66	26	8
1 in 150	SA(0.5)	7.3	86	60	33	7
	SA(1.0)	7.3	168	54	40	6
	SA(3.0)	7.7	212	52	45	3
	PGA	6.8	20	83	9	8
	SA(0.15)	6.7	20	82	9	9
1 in 10,000	SA(0.5)	7.5	34	82	11	7
	SA(1.0)	7.4	65	74	21	5
	SA(3.0)	8.0	146	62	37	1

Notes:

- $\begin{array}{ll} 1. & V_{s30} \text{ is taken as } 1,000 \text{ m/s}. \\ 2. & \text{Mean Magnitude (Mw); Mean Source-to-site Distance (D); Tectonic Region Type (TRT).} \end{array}$

TABLE 6. Average Magnitude and Distance from Hazard Disaggregation.

TDT	Intensity	1 in 15	50 AEP	1 in 10,0	000 AEP
TRT	Measures	M _w	D (km)	M _w	D (km)
	PGA	6.6	43	7.2	10
	SA(0.15)	6.5	39	7.2	10
Shallow Crust	SA(0.5)	7.0	54	7.3	14
	SA(1.0)	7.3	67	7.5	22
	SA(3.0)	7.8	89	7.9	54
	PGA	8.0	127	8.3	121
Subduction	SA(0.15)	8.0	127	8.2	121
Interface	SA(0.5)	8.0	131	8.4	122
Interface	SA(1.0)	8.0	138	8.4	124
	SA(3.0)	8.1	150	8.5	131
	PGA	7.1	142	7.7	125
Subduction Intraslab	SA(0.15)	7.1	143	7.6	126
	SA(0.5)	7.2	147	7.7	126
	SA(1.0)	7.3	151	7.7	128
	SA(3.0)	7.6	158	7.9	130

Notes:

- 1. V_{s30} is taken as 1,000 m/s.
- 2. Weighted-average Magnitude (Mw); Weighted-average Source-to-site Distance (D).

TABLE 7. Conversion Ratios for different SA Values for Consideration of Ground Motion Orientations

Period (s)	SA _{larger} /SA _{RotD50}	SA _{RotD100} /SA _{RotD50}
PGA	1.107	1.188
0.01	1.107	1.188
0.02	1.107	1.188
0.03	1.107	1.188
0.04	1.107	1.188
0.075	1.107	1.188
0.1	1.107	1.188
0.15	1.114	1.195
0.2	1.119	1.203
0.25	1.123	1.210
0.3	1.126	1.216
0.4	1.131	1.224
0.5	1.134	1.227
0.75	1.137	1.230
1	1.139	1.232
1.5	1.141	1.235
2	1.144	1.237
3	1.146	1.241
4	1.148	1.251
5	1.155	1.259
6	1.162	1.267
7.5	1.171	1.276
10	1.178	1.287

Note: SA_{larger}: Larger value of the two as-recorded components at each period; SA_{RotDnn}: nn-th percentile of the Sa value obtained by rotating the horizontal components through all non-redundant angles.

TABLE 8. Design Seismic Parameters for Geotechnical Analysis.

V _{s30} (m/s)	Design Earthquake	1 in 150 AEP	1 in 2,500 AEP	Aftershock
850	PGA (g)	0.130	0.920	0.433
	$\mathbf{M}_{\mathbf{w}}$	6.4	6.8	5.8
1,000	PGA (g)	0.120	0.850	0.400
	$\mathbf{M}_{\mathbf{w}}$	6.4	6.8	5.8
1,500	PGA (g)	0.106	0.752	0.351
	$\mathbf{M}_{\mathbf{w}}$	6.4	6.8	5.8

FIGURES

1 TO 7

List of Figures

Figure 1	Site Location and Nearby Active Faults
Figure 2	Mean Response Spectra (OBE, SEE, and Aftershock) for BOGP (Vs $30 = 850 \text{ m/s}$)
Figure 3	Mean Response Spectra (OBE, SEE, and Aftershock) for BOGP (Vs $30 = 1,000$ m/s)
Figure 4	Mean Response Spectra (OBE, SEE, and Aftershock) for BOGP (Vs $30=1,500$ m/s)
Figure 5	Spectra Comparison between DSHA (84 th Percentile) and PSHA (10 th Percentile, 90^{th} Percentile, and Mean) for $V_{s30} = 850$ m/s.
Figure 6	Spectra Comparison between DSHA (84 th Percentile) and PSHA (10 th Percentile, 90^{th} Percentile, and Mean) for $V_{s30} = 1{,}000$ m/s.
Figure 7	Spectra Comparison between DSHA (84 th Percentile) and PSHA (10 th Percentile, 90^{th} Percentile, and Mean) for $V_{s30} = 1,500$ m/s.




FIGURE 1. Site Location and Nearby Active Faults.




FIGURE 2. Mean Response Spectra (OBE, SEE, and Aftershock) for BOGP (V_{s30} = 850 m/s).




FIGURE 3. Mean Response Spectra (OBE, SEE, and Aftershock) for BOGP ($V_{s30} = 1{,}000 \text{ m/s}$).




FIGURE 4. Mean Response Spectra (OBE, SEE, and Aftershock) for BOGP ($V_{s30} = 1,500 \ m/s$).





FIGURE 5. Spectra Comparison between DSHA (84th Percentile) and PSHA (10th Percentile, 90th Percentile, and Mean) for V_{s30} = 850 m/s.



 $FIGURE~6.~Spectra~Comparison~between~DSHA~(84^{th}~Percentile)~and~PSHA~(10^{th}~Percentile,~90^{th}~Percentile,~and~Mean)~for~V_{s30}=1,000~m/s.$




FIGURE 7. Spectra Comparison between DSHA (84th Percentile) and PSHA (10th Percentile, 90th Percentile, and Mean) for V_{s30} = 1,500 m/s.

APPENDIX A

PROBABILISTIC SEISMIC HAZARD ANALYSIS (PSHA) PLOTS

List of Figures in Appendix A

Figure A1	Mean Response Spectra from PSHA for BOGP ($V_{s30} = 850 \text{ m/s}$)
Figure A2	Mean Response Spectra from PSHA for BOGP ($V_{s30} = 1,000 \text{ m/s}$)
Figure A3	Mean Response Spectra from PSHA for BOGP ($V_{s30} = 1,500 \text{ m/s}$)




Figure A1: Mean Response Spectra from PSHA for BOGP ($V_{s30} = 850 \text{ m/s}$).




Figure A2: Mean Response Spectra from PSHA for BOGP ($V_{s30} = 1,000 \text{ m/s}$).




Figure A3: Mean Response Spectra from PSHA for BOGP ($V_{s30} = 1,500 \text{ m/s}$).

APPENDIX B HAZARD DISAGGREGATION PLOTS

List of Figures in Appendix B

Figure B1	PGA Hazard Disaggregation by Magnitude and Distance for BOGP (1 in 150 AEP)
Figure B2	SA(0.15) Hazard Disaggregation by Magnitude and Distance for BOGP (1 in 150 AEP)
Figure B3	SA(0.5) Hazard Disaggregation by Magnitude and Distance for BOGP (1 in 150 AEP)
Figure B4	SA(1.0) Hazard Disaggregation by Magnitude and Distance for BOGP (1 in 150 AEP)
Figure B5	SA(3.0) Hazard Disaggregation by Magnitude and Distance for BOGP (1 in 150 AEP)
Figure B6	PGA Hazard Disaggregation by Magnitude and Distance for BOGP (1 in 10,000 AEP)
Figure B7	$\mathrm{SA}(0.15)$ Hazard Disaggregation by Magnitude and Distance for BOGP (1 in 10,000 AEP)
Figure B8	SA(0.5) Hazard Disaggregation by Magnitude and Distance for BOGP (1 in 10,000 AEP)
Figure B9	SA(1.0) Hazard Disaggregation by Magnitude and Distance for BOGP (1 in 10,000 AEP)
Figure B10	SA(3.0) Hazard Disaggregation by Magnitude and Distance for BOGP (1 in 10,000 AEP)




Figure B1: PGA Hazard Disaggregation by Magnitude and Distance for BOGP (1 in 150 AEP)




Figure B2: SA(0.15) Hazard Disaggregation by Magnitude and Distance for BOGP (1 in 150 AEP)




Figure B3: SA(0.5) Hazard Disaggregation by Magnitude and Distance for BOGP (1 in 150 AEP)




Figure B4: SA(1.0) Hazard Disaggregation by Magnitude and Distance for BOGP (1 in 150 AEP)




Figure B5: SA(3.0) Hazard Disaggregation by Magnitude and Distance for BOGP (1 in 150 AEP)




Figure B6: PGA Hazard Disaggregation by Magnitude and Distance for BOGP (1 in 10,000 AEP)




Figure B7: SA(0.15) Hazard Disaggregation by Magnitude and Distance for BOGP (1 in 10,000 AEP)




Figure B8: SA(0.5) Hazard Disaggregation by Magnitude and Distance for BOGP (1 in 10,000 AEP)




Figure B9: SA(1.0) Hazard Disaggregation by Magnitude and Distance for BOGP (1 in 10,000 AEP)




Figure B10: SA(3.0) Hazard Disaggregation by Magnitude and Distance for BOGP (1 in 10,000 AEP)

APPENDIX C
DETERMINISTIC SEISMIC HAZARD ANALYSIS (DSHA) PLOTS

List of Tables in Appendix C

Table C1	84^{th} Percentile Response Spectra from DSHA for BOGP with V_{s30} of $850\ m/s$
Table C2	84^{th} Percentile Response Spectra from DSHA for BOGP with V_{s30} of 1,000 m/s
Table C3	84^{th} Percentile Response Spectra from DSHA for BOGP with V_{s30} of 1,500 m/s
Table C4	Aftershock Response Spectra Adjusted from DSHA for BOGP

Table C1. 84^{th} Percentile Response Spectra from DSHA for BOGP with V_{s30} of 850 m/s.

Period (s)	84 th Percentile Response Spectra (g)		
	DSHA 1	DSHA 2	DSHA 3
PGA	1.259	0.722	0.141
0.01	1.259	0.722	0.141
0.02	1.342	0.764	0.148
0.03	1.508	0.846	0.160
0.04	1.741	0.954	0.177
0.075	2.639	1.385	0.234
0.1	2.970	1.562	0.256
0.15	3.223	1.734	0.280
0.2	3.079	1.692	0.284
0.25	2.785	1.572	0.276
0.3	2.550	1.460	0.268
0.4	2.160	1.266	0.247
0.5	1.845	1.105	0.227
0.75	1.294	0.817	0.184
1	0.958	0.627	0.153
1.5	0.574	0.400	0.113
2	0.392	0.293	0.091
3	0.205	0.174	0.063
4	0.135	0.122	0.049
5	0.099	0.092	0.039
6	0.075	0.071	0.031
7.5	0.053	0.051	0.025
10	0.033	0.033	0.017

Notes:

- 1. DSHA 1 for Dunstan Fault with Magnitude $M_{\rm w}=8.0$ and Source-to-site Distance $D=9.0~{\rm km};$
- 2. DSHA 2 for Pisa Fault with Magnitude $M_{\rm w}=8.2$ and Source-to-site Distance $D=13.1~{\rm km};$ and
- 3. DSHA 3 for Alpine (George to Jacksons) Fault with Magnitude $M_w=8.6$ and Source-to-site Distance $D=115.0\ km$.

Table C2. 84^{th} Percentile Response Spectra from DSHA for BOGP with V_{s30} of 1,000 m/s.

Period (s)	84 th Percentile Response Spectra (g)		
	DSHA 1	DSHA 2	DSHA 3
PGA	1.166	0.665	0.130
0.01	1.166	0.665	0.130
0.02	1.247	0.706	0.137
0.03	1.418	0.789	0.149
0.04	1.666	0.900	0.166
0.075	2.567	1.327	0.221
0.1	2.861	1.480	0.239
0.15	3.009	1.599	0.257
0.2	2.806	1.529	0.255
0.25	2.490	1.397	0.244
0.3	2.250	1.282	0.235
0.4	1.876	1.096	0.213
0.5	1.586	0.948	0.194
0.75	1.102	0.696	0.157
1	0.812	0.532	0.129
1.5	0.486	0.339	0.095
2	0.335	0.250	0.078
3	0.182	0.155	0.056
4	0.125	0.113	0.046
5	0.093	0.086	0.037
6	0.070	0.066	0.030
7.5	0.050	0.048	0.024
10	0.032	0.031	0.017

Notes:

- 1. DSHA 1 for Dunstan Fault with Magnitude $M_{\rm w}=8.0$ and Source-to-site Distance $D=9.0~{\rm km};$
- 2. DSHA 2 for Pisa Fault with Magnitude $M_{\rm w}=8.2$ and Source-to-site Distance $D=13.1~{\rm km};$ and
- 3. DSHA 3 for Alpine (George to Jacksons) Fault with Magnitude $M_w = 8.6$ and Source-to-site Distance $D = 115.0 \ km$.

Table C3. 84^{th} Percentile Response Spectra from DSHA for BOGP with V_{s30} of 1,500 m/s.

Period (s)	84 th Percentile Response Spectra (g)		
	DSHA 1	DSHA 2	DSHA 3
PGA	1.035	0.580	0.113
0.01	1.035	0.580	0.113
0.02	1.108	0.617	0.119
0.03	1.276	0.698	0.131
0.04	1.519	0.807	0.148
0.075	2.379	1.205	0.199
0.1	2.609	1.325	0.212
0.15	2.681	1.398	0.223
0.2	2.458	1.314	0.218
0.25	2.155	1.186	0.206
0.3	1.934	1.084	0.197
0.4	1.603	0.925	0.178
0.5	1.355	0.803	0.163
0.75	0.952	0.602	0.135
1	0.709	0.468	0.114
1.5	0.432	0.306	0.086
2	0.306	0.232	0.073
3	0.169	0.145	0.053
4	0.117	0.106	0.044
5	0.087	0.081	0.035
6	0.066	0.063	0.029
7.5	0.048	0.046	0.023
10	0.031	0.030	0.016

Notes:

- 1. DSHA 1 for Dunstan Fault with Magnitude $M_{\rm w}=8.0$ and Source-to-site Distance $D=9.0~{\rm km};$
- 2. DSHA 2 for Pisa Fault with Magnitude $M_{\rm w}=8.2$ and Source-to-site Distance $D=13.1~{\rm km};$ and
- 3. DSHA 3 for Alpine (George to Jacksons) Fault with Magnitude $M_w = 8.6$ and Source-to-site Distance $D = 115.0 \ km$.

Table C4. Aftershock Response Spectra Adjusted from DSHA for BOGP.

Period (s)	Aftershock Response Spectra (g)		
	$V_{s30} = 850 \text{ m/s}$	$V_{s30} = 1,000 \text{ m/s}$	$V_{s30} = 1,500 \text{ m/s}$
PGA	0.443	0.409	0.358
0.01	0.443	0.409	0.358
0.02	0.474	0.439	0.387
0.03	0.543	0.507	0.453
0.04	0.634	0.599	0.542
0.075	0.973	0.926	0.845
0.1	1.102	1.041	0.935
0.15	1.177	1.085	0.952
0.2	1.089	0.984	0.849
0.25	0.959	0.852	0.727
0.3	0.847	0.745	0.634
0.4	0.669	0.581	0.497
0.5	0.538	0.463	0.401
0.75	0.350	0.301	0.266
1	0.244	0.210	0.189
1.5	0.134	0.115	0.105
2	0.088	0.076	0.072
3	0.043	0.039	0.037
4	0.026	0.025	0.024
5	0.017	0.017	0.016
6	0.012	0.012	0.011
7.5	0.008	0.008	0.007
10	0.005	0.004	0.004

Note: DSHA results were adjusted by assuming that the aftershock has the same number of standard deviations as PSHA results.

List of Figures in Appendix C

- Figure C1 84^{th} Percentile Main Shock Response Spectra from DSHA for BOGP with $V_{s30} = 850 \text{ m/s}$.
- Figure C2 84th Percentile Main Shock Response Spectra from DSHA for BOGP with V_{s30} = 1,000 m/s.
- Figure C3 84th Percentile Main Shock Response Spectra from DSHA for BOGP with V_{s30} = 1,500 m/s.
- Figure C4 Aftershock Response Spectra adjusted from DSHA for BOGP




Figure C1: 84^{th} Percentile Main Shock Response Spectra from DSHA for BOGP with $V_{s30} = 850 \text{ m/s}$.




Figure C2: 84^{th} Percentile Response Spectra for Main Shock from DSHA for BOGP with V_{s30} = 1,000 m/s.




Figure C3: 84^{th} Percentile Response Spectra for Main Shock from DSHA for BOGP with $V_{s30}=1,500 \text{ m/s}.$




Figure C4: Aftershock Response Spectra adjusted from DSHA for BOGP.