

Conditions of this consent are set out in accordance with the Otago Regional Transitional Plan.

1. The permit is valid for a period of two years from date of issue, and is not transferrable.

A fully completed Otago Regional bore log form must be supplied to the Council as soon as practicable.

Copies of the results of any pump tests shall be supplied to the Council.

Copies of the results of any chemical analyses performed on the underground water shall be supplied to the Council.

Work carried out during the making or latering of the bore shall be of a standard which conforms with good drilling practice.

2. The bore head casing and reticulation shall be suitably constructed and sealed to avoid ingress of flood waters and other foreign matter.

3. There shall be adequate facility and access for future vertical lowering of a 2 cm diameter electric plumb bob for the purpose of measuring water level.

4. The bore shall be located not less than 30 metres from any existing or proposed septic tank outfall.

5. Any abandoned well is to be cased/sealed to at least three metres below ground level or backfill.

6. Adequate precaution shall be taken to prevent mixing of artesian groundwater above adjacent confining layers.

Reasons for the decision.

1. Based on information supplied by the Applicant/driller, this consent application is consistent with the purpose and principles of the Resource Management Act 1991, and any special provisions of the act as discussed in parts 7 & 8 of this report.

2. No adverse environmental effects will result from bore construction/alteration or the use of the bore.

3. The consent application is consistent with the Otago Regional Council Transitional Regional Plan - Groundwater bylaw 1988 Section 5. Permit conditions are set to require bore owner and driller to be responsible for the standard of bore construction and development.