

## APPENDIX 3 - Auckland Transport comments on conditions

### DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

**Red text** = amendments proposed by Precinct Properties New Zealand Limited to address comments received from invited parties.

## DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

### Conditions

Under clause 18 Schedule 5 of the FTAA and sections 108 and 108AA of the RMA, these consents are subject to the following conditions:

### Definitions

“AT” means Auckland Transport;

“AUP (OP)” means the Auckland Unitary Plan (Operative in Part);

“BPO” has the same meaning as defined in the Resource Management Act 1991;

“CAR” means Corridor Access Request;

“CLG” means Community Liaison Group;

“CMP” means Construction Management Plan;

“CNVMP” means Construction Noise and Vibration Management Plan;

“Consent Holder” means Precinct Properties Limited or its successor in title;

“Council” means the Auckland Council and for the purpose of compliance with the conditions of consent means the Council’s monitoring officer unless otherwise specified.

“CSMP” means Contaminated Site Management Plan;

“CTMP” means Construction Traffic Management Plan;

“DMP” means Dust Management Plan;

“EPA” means Engineering Plan Approval;

“ESCMP” means Erosion and Sediment Control Management Plan;

“FBMP” means Flood Barrier Management Plan;

“FTAA” means the Fast-track Approvals Act 2024;

“GD05” means the Council’s Guideline Document 005 *‘Erosion and Sediment Control Guide for Land Disturbing Activities in the Auckland Region’*;

“GSMCP” means Groundwater and Settlement Monitoring and Contingency Plan;

“HPUDOMP” means Hotel Pick Up and Drop Off Management Plan;

“HNZPT” means Heritage New Zealand Pouhere Taonga;

“HSMP” means Hazardous Substances Management Plan;

“MASAP” means Managed Access Service Arrangement Plan;

“NES:CS” means National Environmental Standard for Managing Contaminants in Soil;

“OWMP” means Operational Waste Management Plan;

“RMA” means the Resource Management Act 1991;

“SLMP” means Servicing and Loading Management Plan;

“SQEP” means Suitably Qualified and Experienced Person;

“SSWP” means Site-Specific Waste Plan;

“Viaduct Streets” means the public roads within the Viaduct annotated in yellow within Attachment 3.

## DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

### General conditions

These conditions apply to all resource consents.

#### Activity in Accordance with Application

1. The consent holder must undertake the works in general accordance with the application formally received by the Environmental Protection Authority on 18 December 2025, and the following documents. In the event that any of the provisions of the following documents conflict with the requirements of these conditions of consent, these conditions of consent must prevail.
  - a. Application form, Statutory Analysis and Assessment of Environmental Effects prepared by Barker & Associates Ltd titled "Downtown Carpark Site Development" and dated 18 December 2025;
  - b. The reports listed at **Attachment 1**; and
  - c. The plans listed at **Attachment 2**.

#### Lapse of Consent

2. In accordance with section 87(2)(b)(ii) and clause 26, Schedule 5 of the Fast-track Approvals Act 2024, this consent lapses ten (10) years after the date it commences unless the consent is given effect to within that ten-year period.

#### Monitoring Deposit

3. The consent holder must pay the Council an initial consent compliance monitoring charge of \$1,170 (inclusive of GST), plus any further monitoring charge or charges to recover the actual and reasonable costs incurred to ensure compliance with the conditions attached to these consents.

#### Advice Note:

*The initial monitoring deposit is to cover the cost of inspecting the site, carrying out tests, reviewing conditions, updating files, etc., all being work to ensure compliance with the resource consents. In order to recover actual and reasonable costs, monitoring of conditions, in excess of those covered by the deposit, will be charged at the relevant hourly rate applicable at the time. The consent holder will be advised of the further monitoring charge. Only after all conditions of the resource consents have been met, will the Council issue a letter confirming compliance on request of the consent holder.*

#### Community Liaison Group

4. Within two months of the grant of consent the consent holder must invite the listed parties in condition 5 to establish a Community Liaison Group (CLG), and, if any of the

## DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

invited parties accept that invitation, must hold the first meeting in accordance with condition 6.

5. The consent holder must invite each of the following parties to have a representative on the CLG:
  - a. Auckland Council;
  - b. The appointed construction company for the Project;
  - c. M Social (196-200 Quay Street, Auckland Central);
  - d. Body Corporate 199380 Sebel (**Sebel**) (85-89 Customs Street West, Auckland Central) and Accor Australia & New Zealand Hospitality Pty Limited;
  - e. Docklands Management Limited (representing Princes Wharf entities);
  - f. Quattro RE Limited as Trustee for ATT NZ1 (**Kyndryl Tower**); ~~and~~
  - g. Viaduct Harbour Holdings Limited;-
  - h. Piccadilly Trustee Limited (22 Fanshawe Street, Auckland Central)
  - i. Mornington Trustee Limited (30-36 Fanshawe Street, Auckland Central).
6. Invitations for the first CLG meeting must be sent by post and email at least 15 working days prior to the first meeting, requesting advice as to whether the invited parties wish to attend the first meeting, their nominated attendee(s) and if they have an ongoing interest in attending future CLG meetings. If any invited party declines to be involved in the meetings (including those not responding after reasonable attempts to contact them), either from commencement or subsequently, then subsequent meetings may progress for the balance of the Project without further notice to those parties who by absence elected not to be involved in the CLG.
7. The objectives of the CLG are to:
  - a. Provide a means for all parties to give and receive regular updates on progress with the construction of the Project (including demolition);
  - b. Provide a regular forum through which information about the construction of the Project can be provided by the consent holder;
  - c. Provide a process for providing weekly updates on upcoming works that may generate high levels of noise and vibration and to ensure that there is a process established for the parties to liaise with each other and schedule their activities to minimise the effects. This may include:

## **DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT**

- (i) Receivers of noise conveying the days and times when they have a high or low sensitivity to construction noise and vibration to enable the consent holder to plan high noise or vibration works; or
    - (ii) The consent holder advising that they are planning high noise or vibration works and liaising with the receivers to schedule the works in a way that minimises the effects;
  - d. Enable opportunities for concerns and issues to be reported to the consent holder and responded to by the consent holder; and
  - e. Enable parties the opportunity to provide input into the development and content of the following Management Plans (and any subsequent changes to those documents once certified) in accordance with the procedure outlined in Conditions 11 to 20;
    - (i) Construction Management Plan (CMP);
    - (ii) Construction Traffic Management Plan (CTMP);
    - (iii) Construction Noise and Vibration Management Plan (CNVMP);
    - (iv) Dust Management Plan (DMP); and
    - (v) Groundwater and Settlement Monitoring and Contingency Plan (GSMCP).
8. The consent holder must:
- a. Arrange a regular meeting to be held every 2 months on the same day of the week, (unless a different frequency is otherwise agreed with the CLG). Records of each meeting must be provided to Council on request.
  - b. Provide information at least 5 working days in advance of the meeting at which that information is to be discussed.
  - c. Provide reasonable administrative support for the CLG including:
    - (i) Organising meetings at a local venue;
    - (ii) Inviting all members of the CLG to meetings at least 10 working days before that meeting is to be held.
  - d. Consult with the CLG on the development and content of the Management Plans listed in condition 7e for review and feedback by the CLG, and must consider any feedback received and provide reasons for any feedback not incorporated into the final version of the plan(s). The consent holder must provide the CLG at least 10 working days within which to provide feedback.

## DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

- e. Provide an update at least every 2 months (or as otherwise agreed by the CLG) during construction of the Project setting out associated compliance with the consent conditions and any other relevant requirements of the Management Plans in Condition 7e including responses to compliance concerns raised by CLG members at the previous meeting.
  - f. Respond to all reasonable issues/queries/requests raised by the CLG and advise how their issues/queries/requests have been resolved and if not resolved, the reasons why. The speed of the response must be proportionate to the urgency of the matter as determined by the CLG.
  - g. Have a representative attend and chair all CLG meetings.
  - h. Provide a copy of the minutes of the CLG meetings to all CLG members within 5 working days of each meeting.
  - i. Provide a Project contact for assistance for the purpose of lodging complaints as specified in these conditions.
9. The CLG must continue until construction works are completed on the site, and Council sign-off has been provided confirming that all construction-related consent conditions have been met. However, in the event that all the members of the CLG agree, or there are three (3) meetings in a row where three (3) or less CLG members attend with the exception of M Social, the consent holder may disestablish the CLG upon written notice to its members. In such event, the conditions relating to the CLG shall cease to apply.

### Princes Wharf access

#### 9A. The consent holder must not cause:

- a. The right-turn lane from Quay Street into Princes Wharf and the left-turn from Princes Wharf to be closed during the demolition and construction phases of the Project, in a physical capacity; and/or
- b. The access to and from Princes Wharf via the lower Hobson flyover to be closed during the demolition and construction phases of the Project, in a physical capacity.

- 9B. An exception to this requirement to ensure public safety is anticipated during the demolition / removal of the Lower Hobson Street Pedestrian Overbridge (scheduled to occur over a single weekend), which could result in some impacts on access into Princes Wharf. The ability to turn right into Princes Wharf must be maintained throughout those works. In determining an appropriate weekend to undertake the removal of the Lower Hobson Street Pedestrian Overbridge, the Consent Holder must engage with Docklands Management Limited to coordinate those works on a weekend

**Commented [NS1]:** Comments included in B&A11 accepted, no issues with suggested wording.

## DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

that avoids, as far as practicable, cruise ship arrivals / docking at Princes Wharf.

### Viaduct Harbour access

- 9C. The consent holder must not close the left-turn access from Sturdee Street into Customs Street West throughout the demolition and construction phases of the Project, in a physical capacity.

### Management Plans

10. Conditions 11 to 20 apply to all Management Plans required by these conditions.
11. Management Plans must be prepared by a Suitably Qualified and Experienced Person(s) (SQEP).
12. Management Plans must be submitted to the Council for certification in writing. Management Plans must be submitted at least 20 working days prior to the Commencement of Construction (as applicable) unless otherwise specified in the conditions. The certification process must be limited to confirming that the Management Plan has been prepared in accordance with the relevant condition(s) and will achieve the objectives and principles of the Management Plan.
13. Management Plans may be submitted in parts or in stages to address particular activities or to reflect a staged implementation of the Project, and when provided in part or for a stage shall be submitted at least 20 working days prior to Commencement of Construction (as applicable) of that part or stage unless otherwise specified in the conditions. Management Plans submitted must clearly show the linkage with plans for adjacent stages and interrelated activities.

### Advice Note:

*Under Condition 24, the consent holder is required to address in the CMP construction works programming, including confirmation of the proposed staging and sequence of construction of the Project.*

14. Where consultation on a Management Plan is required by a condition of these consents including any change to a Management Plan contemplated by Condition 17, the consent holder must provide the following to the Council when submitting the Management Plan for certification:
- A summary of consultation during preparation of the Management Plan;
  - Any feedback on the proposed text of the Management Plan from the party or parties that the condition requires consultation with; and

**Commented [NS2]:** Similarly fine from AT's perspective.

**Commented [NS3]:** Potentially affect one of the intended wastewater extension options, however there is no concern with this from AT's perspective assuming that there is no conflict with the intended infrastructure extension option. Notwithstanding this position, having discussed this further with AC we understand that the infrastructure required to reasonably service the development cannot be unbundled as part of the scope of this application. This is supported by AT and for the reasons outlined within our memo dated 29<sup>th</sup> April 2026 failure to properly consider any resulting impacts of the required wastewater / stormwater options may have material impacts upon the transport network, noting the extent of road closure(s) may be greater than what has already been assessed. Consequently, the amendments undertaken by the applicant's team have sought to delete all construction related matters arising from such works from the CTMP / CMP conditions below. In principle, the amendments provided as part of the earlier memorandum prepared by AT was to act somewhat as a stopgap at compliance stage to ensure that further information was provided to understand whether any cumulative impacts would arise from the construction activities already assessed with any additional works required to facilitate the development. There is a very possible scenario in which the reasonableness of the details, principles, and objectives of the CTMP condition may be impacted if the extent of any construction related activities is different by comparison to what has been reviewed to date.

**Commented [NS4]:** B&A15: As discussed with the applicant and covered via supporting email, conditions relating to heavy construction vehicle monitoring are considered no longer required. However, there is an area of disagreement relating to the need for erecting and maintaining visual screens along the flyover. For the reasons outlined within Section 7.18 & 7.19 of Mr Peake's memo dated 29<sup>th</sup> April 2026, the applicant has not resolved these outstanding concerns and the s55 response provided does not provide any additional information to this effect, which has not otherwise been considered previously. AT maintains the position that the risk of driver distraction is exacerbated in this location, which is inherently different compared with other locations within the City Centre due to the proximity between the construction staging area and flyover; and the fact that there is no visibility of the staging area at the lower level when motorists are moving along the flyover. The potential impact at this location in the event of a crash is disruption to the network, particularly for buses including the NX1 and key north shore services, noting that this is the only route out from this location for these key bus services.

**Commented [NS5]:** Comment B&A17: With respect to the comments regarding consultation, this was due to the reoccurring theme within the earlier conditions set that suggested that AT was a party to be consulted rather than part of Auckland Council Group ("ACG") responsible for certifying compliance with the conditions. The response provided seems to accept this position, as evidenced in B&A19, to an extent that AT is comfortable with such a deletion. Accept the comments relating to the applicability of Condition (19).

**Commented [NS6]:** As per B&A21, deletion accepted for the reasons outlined above.

## DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

- c. A response to that feedback indicating the matters that were not incorporated into the text of the Management Plan submitted for certification and the reasons why.

15. Should the Council refuse to certify a Management Plan, or a part or stage of a Management Plan, in accordance with Conditions 12 and 13 above, the consent holder must submit a revised Management Plan for certification as soon as practicable. The certification process must follow the same procedures as outlined in Condition 12 above.
16. Any certified Management Plan may be amended if necessary to reflect any minor changes in design, construction methods or management of effects. Any amendments are to be submitted to the Council in writing prior to implementation of the change and will not be subject to certification, unless the Council determines that those amendments once implemented would result in a materially different outcome to that described in the original plan in which case Condition 17 applies.
17. Any changes to a certified Management Plan involving a materially different outcome under Condition 16 must be submitted to the Council to certify that they comply with the applicable requirements of these conditions. Any material change must be consistent with the purpose of the relevant Management Plan and the requirements of the relevant conditions of these consents. Where a Management Plan was prepared in consultation with affected parties, any material changes to that Management Plan shall be prepared in consultation with those same parties.
18. Any subsequent revision of the Management Plan must also be submitted to Council for certification. Works must not commence on Site until the Council certification is provided in writing.
19. All works must be carried out in accordance with the certified Management Plans. No works or activities covered by an individual Management Plan may commence until written certification of that Management Plan is provided by the Council, unless otherwise approved in writing by the Council.
20. A copy of the certified Management Plan must be made available to the Council during monitoring inspections.

### Specific conditions – land use consent LUC[insert reference]

#### Construction Management Plan (CMP)

21. The consent holder must prepare and submit a Construction Management Plan (CMP) in general accordance with the draft CMP referenced in Condition 1.

Advice Note:

**Commented [NS7]:** Amendment in B&A22 accepted, as per comments above.

**Commented [NS8]:** In response to B&A23, accept the deletion of reference to SQEP within the body of the condition. However, Condition (11) is not clear in terms of who is a SQEP for the purposes of individual management plans. Given that a contractor has not yet been specifically engaged, it is appropriate to ensure that the advice note is retained as they will be the one ultimately responsible for delivering the intended works and supporting methodology.

**Formatted:** Indent: Left: 1.75 cm, No bullets or numbering

## DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

*For the purposes of achieving compliance with Condition (11), references to SQEP in the context of Condition (21) includes representation and input from the Main Contractor responsible for setting up the intended programme of works and delivering any works authorised by these consents.*

~~21.—~~

22. The objectives of the CMP are to:
  - a. Define the procedures to manage adverse effects resulting from construction activities;
  - b. Set out the duration, frequency and timing of works to manage disruption, taking into account other construction related activities occurring in the vicinity;
  - c. Require engagement with affected receivers; and
  - d. Require timely management of complaints, including by implementing remedial actions, where appropriate.
23. The CMP must be prepared in accordance with the following principles:
  - a. Protect the public from demolition and construction activities; and
  - b. Contain the demolition and construction works within the Site where possible.
24. The CMP must include specific details to manage adverse effects on the environment and neighbouring properties from construction, and management of all works associated with this development, including at a minimum:
  - a. Specify practicable methods and measures to manage adverse environmental effects arising from construction works;
  - b. Provide the framework for the contractor responsible for this CMP to achieve compliance with conditions of resource consents;
  - c. Include contact details of the appointed contractor or project manager (phone number, email address, postal address);
  - d. Include an outline of the construction programme including (but not limited to): the hours of operation; intended duration and sequencing for each stage of works (including demolition and construction); final methodologies for carrying out the intended works; identification of any differences between the draft CMP outlined in Condition 1 and the methodologies required to facilitate intended works;

**Commented [NS9]:** B&A26, some of the previous inclusions relating to Condition (24)(d) and (24)(d)(i) are not shown in the tracked changed document, however it is understood that these amendments were not accepted. If the inclusion of the advice note to Condition (21) is accepted, in theory the last sentence that was previously recommended by AT can be removed. As the advice note clarifies that a SQEP, including Main Contractor representation, should be provided in detailing the outline of the construction programme as they are the ones responsible for undertaking the works.

The deletion of the references to finalised options for extending the Wastewater and Stormwater Networks is not accepted. AT considers that the intent of these amendments is not specifically addressed in that the purpose of such amendments was to recognise that the detail regarding any adverse impacts associated with such extensions were not identified as part of the processing of this application. These amendments are to provide further certainty to Council regarding what time of measures would be required to install the extensions to either network, to help inform the final CTMP that has not been prepared to take into account such works. In principle, this information would be better suited to be reviewed at this stage to understand whether any fundamental changes to conditions would be required / establish if the measures provided within the conditions are fit for purpose.

## DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

- e. Identify measures to be adopted to maintain the Site in a tidy condition in terms of disposal / storage or rubbish, unloading of building materials, waiting and storage areas and similar construction activities;
- f. Identify the location and servicing of workers' conveniences (e.g. porta-loos) and workers transport arrangements and car parking;
- g. Include a Site plan(s) identifying material, plant and machinery storage areas as well as loading and unloading ~~zones~~ scenarios for each stage(s) of works, whilst taking into account the requirement of Condition 24d. Should the loading and unloading scenarios be changed by comparison to those included within the draft CMP, the consent holder must provide additional tracking to demonstrate that heavy vehicles can suitably manoeuvre in / out from any intended loading area(s) into surrounding roads and further supporting assessment detailing any resulting differences in management measures required for any new or amended construction scenario;
- h. Identify measures to ensure that, to the extent practicable, construction related activities are managed taking into account other demolition and construction-related activities occurring in the vicinity at the same time, to manage effects on the environment; and
- i. Complaints procedure.

### Construction Traffic Management Plan (CTMP)

- 25. The consent holder must prepare and submit a Construction Traffic Management Plan (CTMP) in general accordance with the draft CTMP referenced in Condition 1.
- 26. The objective of the CTMP is to manage the effects of demolition and construction traffic impacts on the surrounding road network, including effects on:
  - a. The efficient operation of the managed accesses and construction staging area contained within Lower Hobson Street for the purposes of unloading and loading construction vehicles;
  - b. The performance of the adjacent intersections including Lower Albert Street / Customs Street West, Lower Hobson Street / Customs Street West / Sturdee Street and Sturdee Street / Customs Street West;
  - c. The function of adjacent bus lanes and bus services that rely upon the immediately surrounding transport network including (but not limited to) the Northern and Western Express bus routes; and
  - d. The properties within the vicinity of the demolition and construction works.

**Commented [NS10]:** B&A27, whilst acknowledging the applicant's comments it does not appear that any specific amendments have been provided within the CTMP condition to reflect a situation where the unloading / loading scenarios may change compared to what has already been assessed. Suggest that this is the more appropriate place for such an inclusion, rather than it needing to be specifically detailed within the finalised CTMP. This is particularly significant, because the entirety of the applicant's assessment is based on a particular approach to managing any relating construction impacts. Should the contractor intend to revise this approach, the degree of adverse impacts may be materially different by comparison, which is part of the reason why the amendments were originally proposed to provide that degree of certainty regarding the finalised methodology for a contractor to undertake works. Ultimately, the applicant has confirmed a willingness to provide this, it just becomes a question of what is the more appropriate plan for it to be provided.

**Commented [NS11]:** B&A28, no specific concerns with this position.

**Commented [NS12R11]:** B&A29, discussed earlier within the body of AT's comments above.

**Commented [NS13]:** B&A30, deletion accepted for the reasons identified above.

**Commented [NS14R13]:** B&A31, minor amendments accepted.

## DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

27. The CTMP must be prepared to achieve the following principles:

- aa. A clear understanding of the constraints and requirements of those residents and businesses operating in the vicinity of the Project (obtained through consultation with the CLG and affected parties) informs the approach to the management of traffic activities associated with the demolition and construction phases of the Project;
- a. Protect the public from hazards associated with demolition and construction activities;
- b. Contain the demolition and construction works within the Site where possible;
- c. ~~Minimise-Avoid~~ pedestrian-closures along Customs Street West except for in the period during demolition required to remove the existing vehicle ramp from the Downtown Car Park to Fanshawe Street;
- d. ~~Minimise-Avoid~~ road and bus lane closures, except in the following instances:
  - (i) For the east side of Lower Hobson Street at the lower level between Quay Street and Customs Street West and a small section of Customs Street West between Sturdee Street and the existing western Downtown Car Park entry; and
  - (ii) During a time when the existing vehicle ramp from the Downtown Car Park to Fanshawe Street is being removed and the time during the removal of the existing pedestrian overbridge at the northern end of Lower Hobson Street
  - ~~(ii) —~~
- e. Have regard to Auckland Transport's Temporary Traffic Management Guidelines 2022 – 2025, dated 7<sup>th</sup> September 2022 ("TTM") in preparing the CTMP;
- f. Manage impact upon the transport network, taking into account other construction related activities occurring in the vicinity; and
- g. Avoid using Quay Street and the **Viaduct Streets** as Heavy Construction Vehicle routes.

**Commented [NS15]:** B&A32, this principle does raise some concerns because of the fact that there is a suggestion that an alternative management approach might be required to factor in the needs of party(ies) to the CLG, which might result in materially different adverse effects upon the network. We understand that consultation has occurred with some parties, particularly extensive engagement with M Social to understand how the scope of construction impacts might affect the use of their loading space, however a similar degree of visibility for any other party(ies) has not been provided to Council to understand if alternative management measures are required or not and whether the could be traded off against other fundamental principles of the CTMP, notably maintaining the function and effectiveness of the network more generally. At the meeting held on 9<sup>th</sup> June 2026, this difficulty was acknowledged by the applicant and has confirmed that they intend to meet with these parties shortly to confirm the extent to which their operational requirements need to be met.

**Commented [NS16]:** B&A33, the amendments proposed to delete the use of the "Avoid" and reintroduction of "Minimise" are not accepted. The reasoning for this is that there is some suggestion that a degree of flexibility is intended to be retained, which could inadvertently result in additional road(s) and/or bus lane(s) closures over and above those that have already been explicitly identified and assessed. Should any further road closure(s) or bus lane(s) closure be proposed, the degree of adverse impacts is likely to be greater than what has already been accepted and could compromise the function of the bus services reliant upon this part of the City Centre, most notably the WX1 / NX1 / Western Shore Buses and other key inner city services. At the meeting held on 9<sup>th</sup> June 2026, the applicant indicated that the intend of such an amendment was to provide some degree of flexibility. However, it is difficult to entertain an increased level of flexibility without having a specific assessment to ascertain what the degree of adverse impact upon the transport network might be.

**Formatted:** Strikethrough, Not Highlight

**Formatted:** Indent: Left: 4.25 cm, No bullets or numbering

28. The CTMP must include specific details relating to avoiding, remedying, or mitigating adverse effects on the transport environment from demolition, earthworks, construction and management of all works associated with this development, and taking into account other construction related activities occurring in the vicinity, and setting out

## DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

procedures to be followed which ensure compliance with the conditions of consent, and at a minimum must include:

- a. Contact details of the appointed contractor or project manager (phone number, email address, postal address);

b. An outline of the Site clearance, demolition and construction programme as required in Condition 24d;

c. Detailed consideration of the extent to which the undertaking of the public Wastewater and Stormwater extensions, as outlined in Condition (24)(d)(i) of these consents, will adversely affect the surrounding transport network and the necessary management measures required to ensure that the principles of the CTMP, as required in Condition (27) of these consents, are to be upheld;

~~e-d.~~ Plans showing areas where stockpiles, and storage of equipment will occur so that any obstruction of public spaces (e.g., roads) is minimised;

~~e-e.~~ Plans showing the location of any Site offices and worker facilities during the construction period;

~~e-f.~~ Details of measures to manage how contractors will travel to and from the Site for work, including measures to promote alternative travel modes to driving, such as carpooling, using public transport, or cycling/walking where feasible, avoiding the use of the dedicated vehicle access beneath the flyover at the intersection of Sturdee Street / Customs Street West; providing a shuttle bus from off-site parking, and identifying nearby public car park facilities where workers can park. All staff are to be advised that parking in time-restricted or residential areas is not permitted;

~~f-g.~~ An overview of measures that will be adopted to prevent unauthorised public access during the construction period;

h. Location of traffic signs and measures for advanced notice of any disruptions to the surrounding transport network during demolition and construction (including but not limited to) the removal of the Lower Hobson Street footbridge, and the removal of the Downtown Carpark Ramp across Customs Street West. This must include (at a minimum) the following:

- (i) Variable Message Signage ("VMS") on Quay Street to the east warning of the works to enable motorists to make an informed decision as to choose another route;

**Commented [NS17]:** B&A35, amendment accepted.

**Formatted:** Not Expanded by / Condensed by , Not Highlight

**Formatted:** Not Expanded by / Condensed by , Not Highlight

**Formatted:** Indent: Left: 2.63 cm, Tab stops: Not at 2.82 cm

**Commented [NS18]:** B&A36, comments and deletion not accepted. It is understood that the works cannot be unbundled as part of the scope of this application, noting that it is inherently part of the proposal required to service the intended development.

**Formatted:** Right, Indent: Left: 3.5 cm, No bullets or numbering

**Commented [NS19]:** B&A37, comments and deletion not accepted. This condition is in relation to construction workers travelling to and from the site for work, and not in relation to the delivery of materials. Construction workers arriving to work on a day to day basis should not require direct access to the site in a location that is intended for use by heavy vehicles. The ability to manage workers' vehicles commuting to the site will be difficult to coordinate these with heavy vehicles. This has the potential to effect the efficient operation of the access under the Lower Hobson Street flyover which could impact on the operation on bus lane. The restriction is considered appropriate given that the draft CTMP states that workers will be encouraged to use public transport and will be advise of off-site parking. Therefore, there should be little need for workers travelling to the site to work to drive into the site. Alternative arrangements would be needed for workers to drop off tools.

**Formatted:** Indent: Left: 2.5 cm, Tab stops: Not at 2.82 cm + 2.95 cm

## DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

- (ii) Signage warning of road closures for works involving the removal of the vehicle access ramp from the existing Downtown Car Park for at least 14 days prior to the works commencing; and
- (iii) Advanced advertising and notification, including (but not limited to) the use of radio, social media, use of VMS on the wider road network, and other options to the travelling public to inform consideration of alternative travel arrangements or use of different routes to avoid the area;
- g. Location of traffic signs and measures for advanced notice of any disruptions to the surrounding transport network during demolition and construction (including but not limited to) the removal of the Lower Hobson Street footbridge, and the removal of the Downtown Carpark Ramp across Customs Street West. This must include (at a minimum) the following:
  - (i) Signage warning of road closures including Variable Message Signage ("VMS"); and
  - (ii) Advanced advertising and notification, including (but not limited to) the use of radio, social media, signage, and other options to the travelling public to inform consideration of alternative travel arrangements or use of different routes to avoid the area;
- h.i. Hours of operation and any restrictions on Site access at certain times, including measures to manage access;
  - (i) During demolition;
  - (ii) During enabling works and basement construction; and
  - (iii) During tower construction.
- h.j. A list and description of all heavy vehicle types that will require access to the Site, including frequency over the various stages of the Project and the associated waiting and loading locations. This must include details outlined in the final CMP, as required in Condition 24;
- k. ii. A maximum number of 24 construction vehicles (48 vehicle movements) per hour across all hours of works accessing the construction zone via a right turn from Sturdee Street/Hobson Street into Customs Street West, except that a greater number may be expressly approved as part of the finalized CTMP where supported by a transport assessment prepared by a SQEP and otherwise certified by Council. For the purposes of this condition, "Construction vehicles" includes heavy construction vehicles; trucks and vans for the purposes of loading or unloading of substantive construction materials; but excluding cars;

**Commented [NS20]:** B&A38, amendments not accepted. Lacking specificity in location / timeframes / extent to ensure that sufficient notice is provided to motorists. Earlier inclusion is considered more appropriate to give motorists suitable advanced notice.

**Formatted:** Not Highlight

**Formatted:** List Paragraph, List Paragraph 1, Bulleted list in paragraph, Report Paragraph, Header 1 - Network Consent, Left, Numbered + Level: 1 + Numbering Style: a, b, c, ... + Start at: 1 + Alignment: Left + Aligned at: 2.25 cm + Indent at: 3.13 cm

**Formatted:** Font: Italic, Not Highlight

**Commented [NS21]:** B&A40, amendments have been suggested to address the applicant's further response and based on the discussions that were held on 9<sup>th</sup> June 2026. Specifically, AT have identified that the previous amendments lacked detail regarding the types of construction vehicles that could use this space and the potential of a quasi-self certification process within the condition. Should there be any concerns with the intensity of the numbers that would warrant the lowering of the maximums, depending on where the applicant is at with across their various stages of construction, a s128 review condition is an appropriate mechanism to lower the maximums should there be any noticeable impacts upon the transport network that would necessitate an alternative approach.

## DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

~~l. The arrival of heavy truck movements to Lower Hobson Street must be managed so that no more than one truck arrives at the site access at a time, and only when there is sufficient space within the site to accommodate additional trucks;~~

m. Measures to ensure satisfactory vehicle and pedestrian access is maintained to adjacent properties at all times, unless agreed by private agreement.

~~n. ii. The retention of an east-west pedestrian connection along Customs Street West, which must be secured by way of Class-B Hoardings (or similar), alongside provision of a managed zebra crossing from the northern Customs Street West footpath to the median island at the Customs Street West / Sturdee Street intersection;~~

~~o. iii. The location of any contractor parking area(s) of light vehicles and access for dropping off tools, which should include reference to the detail requested within the CMP. No access of light vehicles must be permitted through the managed access proposed beneath the flyover into Lower Hobson Street; The location of any contractor parking area(s) of light vehicles and access for dropping off tools, which should include reference to the detail requested within the CMP;~~

j.p. Temporary protection measures to minimise any damage to public roads, footpaths, berms, kerbs, reserves or other public assets as a result of the demolition, earthworks and construction activities;

k.q. Requirements for any road pavement assessment and road pavement monitoring details, and associated road pavement repair measures;

l.r. The process to record and investigate all traffic complaints that includes the following steps being taken as soon as practicable:

- (i) Acknowledge receipt of the concern or complaint within 24 hours and record:
  - Time and date the complaint was received and who received it;
  - Time and date of the activity subject to the complaint (estimated where not known);
  - The name, address and contact details of the complainant (unless they elect not to provide);
  - The complainants' description of the resulting effects; and
  - Any relief sought by the complainant;
- (ii) Identify the relevant activity and the nature of the works at the time of the complaint;

**Commented [NS22]:** Deletion proposed without any specific feedback on such an amendment. This is inherently part of the applicant's intended approach to managing HCVs. At the meeting held on 9<sup>th</sup> June 2026, the applicant clarified that they don't think that this is necessary as there are stages where trucks can be accommodated within the subject site in certain scenarios, particularly where space is available within the site itself and outside of the staging area contained within Lower Hobson Street. Whilst AT acknowledges this position, there still remains a risk without appropriate management of trucks queuing back into the adjacent bus lane. The management of these movements is appropriate to minimise and effectively mitigate the potential for this conflict to occur.

**Formatted:** List Paragraph, List Paragraph 1, Bulleted list in paragraph, Report Paragraph, Header 1 - Network Consent, Left, Numbered + Level: 1 + Numbering Style: a, b, c, ... + Start at: 1 + Alignment: Left + Aligned at: 2.25 cm + Indent at: 3.13 cm

**Commented [NS23]:** B&A41, changes accepted.

**Formatted:** List Paragraph, List Paragraph 1, Bulleted list in paragraph, Report Paragraph, Header 1 - Network Consent, Justified, Indent: Left: 2 cm, Hanging: 1 cm, Numbered + Level: 1 + Numbering Style: a, b, c, ... + Start at: 1 + Alignment: Left + Aligned at: 2.25 cm + Indent at: 3.13 cm, Tab stops: 2.82 cm, Left + 2.95 cm, Left

**Commented [NS24]:** B&A42, changes not accepted for the reasons provided above.

## DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

- (iii) Review the mitigation and management measures in place;
  - (iv) Record the findings and recommendations in a complaints register that is provided to the Project Manager after each and every complaint and made available to the CLG and Auckland Council upon request;
  - (v) Report the outcomes of the investigation to the complainant within 5 working days of the complaint being received, identifying where the relief sought by the complainant has been adopted or the reason(s) otherwise;
- ~~m.s.~~ Identification of haulage routes with Auckland Council and Auckland Transport prior to Commencement of Construction, that minimise the effects of construction-related traffic on sensitive land uses in the vicinity of the site. Haulage routes must consider the restrictions in Condition 27.
- ~~n.t.~~ Avoid use of the existing loading zones on Lower Hobson Street and Customs Street West (to the west of Lower Hobson Street);
- oo. Avoid left hand movements from Sturdee Street into the give way intersection of Sturdee Street / Customs Street West east of existing flyover into the loading area located within the lower level of Lower Hobson Street;
- ~~o.u.~~ Provide facilities to clean vehicles' wheels prior to exiting the works area to minimise the chances of mud or other excavated material from being dropped on the road;
- ~~p.v.~~ Ensure the Site access point(s) are clearly signposted;
- ~~q.w.~~ For each construction phase:
- (i) identify the location and duration of any road or lane closures associated with on-street loading zones for construction traffic (including the dimensions of loading zones) to ensure these are of sufficient size to accommodate the anticipated number of heavy vehicle movements, including during peak demand periods.
  - (ii) Where road closures are proposed, details of road closure segments and duration of works for each closure, indication of detour routes for each closure and assessment of the effects on the road and public transport network of any road closures and a plan to mitigate these effects;
- ~~r.x.~~ Measures to ensure that loading zones for construction traffic will be managed to minimise congestion on the surrounding road network;
- ~~s.y.~~ Measures to ensure truck travel to and from the Site is staged and sequenced as much as possible. These measures will include (but not limited

## DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

to) detailed planning and preconstruction coordination, radio communication devices and GPS tracking of trucks. This will ensure that the designated truck holding areas will be unlikely to overflow and potentially result in conflict with the general traffic and bus lanes; and

4.2. Identify the relevant Auckland Transport/Auckland Council approvals.

### Advice note:

*It is the responsibility of the consent holder to seek separate approval for the CTMP from Auckland Transport. Please see Auckland Transport's website [www.aucklandtransport.govt.nz](http://www.aucklandtransport.govt.nz) for more information.*

*The CTMP must be prepared in accordance with the Auckland Code of Practice for Land Development and Subdivision Chapter 3: Transport or CTMPs (as applicable) and the New Zealand Guide to Temporary Traffic Management (NZGTTM), which is replacing the New Zealand Transport Authority's Code of Practice for Temporary Traffic Management (CoPTTM)*

### S128 Review Condition – Construction Management

28A. Under section 128 of the RMA, the conditions of these consents may be reviewed by the Manager Resource Consents at the consent holder's cost.

Within one month following commencement of any construction activity authorized by these consents, but excluding the period of decommissioning any utilities contained within the Downtown Car Park, in order:

- To deal with any adverse effect on the environment which may arise or potentially arise from the exercise of these consents and which it is appropriate to deal with at a later stage, in particular adverse construction effects associated with the undertaking of any required construction activity, including enabling works; basement construction; and the construction of any tower super structure(s), upon the surrounding transport network; and
- To review the suitability of the objectives, principles, and specific details required in the final CTMP required in Conditions (26), (27), and (28) of these consents to appropriately avoid, remedy, or mitigate adverse effects upon the transport network directly associated with any construction activity(ies) exercised through these consents. This may include, but not be limited to, the following measures:
  - a) Reduction of the maximum number of hourly Construction Vehicles below the maximum of 24 Construction Vehicles required by Condition (28)(k) of these consents; and
  - b) Restrictions to Construction Vehicles during either the AM peak period between the hours of 7am – 10am and/or PM peak period between 4pm – 7pm;

### Flyover Visual Screening Barrier

**Formatted:** Font: Bold

**Formatted:** AC BodyText Numbers, Indent: Left: 1.27 cm, Hanging: 1 cm, Space Before: 0 pt, After: 0 pt, Line spacing: single

**Formatted:** AC BodyText Numbers, Indent: Left: 2.27 cm, Space After: 0 pt, Line spacing: single

**Formatted:** AC BodyText Numbers, Space After: 0 pt, Add space between paragraphs of the same style, Line spacing: single, Bulleted + Level: 1 + Aligned at: 2.9 cm + Indent at: 3.54 cm

**Formatted:** AC BodyText Numbers, Space After: 0 pt, Add space between paragraphs of the same style, Line spacing: single, Bulleted + Level: 2 + Aligned at: 4.17 cm + Indent at: 4.81 cm

**Commented [NS25]:** Whilst acknowledging that some of the previous concerns identified by AT have been resolved, particularly in terms of the average length of time that a HCV could feasibly enter, load / unload, and exit the site, it is considered that these are examples of specific measures within the applicant's control that could be implemented should the objectives, principles, and details of the CTMP included in Condition (28) not provide to adequately mitigate adverse construction impacts upon the surrounding transport network based on the length of construction; lack of final details regarding the contractor's intended methodology; and likelihood that the receiving environment will change, over time, given the seven year duration of works proposed.

**Formatted:** Font: Bold

**Formatted:** List Paragraph, List Paragraph 1, Bulleted list in paragraph, Report Paragraph, Header 1 - Network Consent, Space Before: 0 pt, After: 0 pt, Line spacing: single

## DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

28B. At least two weeks prior to the commencement of any construction activity authorized by these consents, the consent holder must erect a 1m visual screen from the top of the existing concrete edge barrier along the entire eastern extent of the Hobson Street Flyover to limit views towards any proposed crane operation. This barrier must be maintained for the life of the required construction activity or until such a time that the Flyover is no longer in place or operational.

Advice Note:

Engineering Approval will be required for this work.

**Formatted:** Indent: Left: 0.95 cm, Hanging: 1 cm, Space Before: 10.5 pt, After: 0 pt, Add space between paragraphs of the same style, Line spacing: 1.5 lines, No bullets or numbering, No widow/orphan control, Don't adjust space between Latin and Asian text, Don't adjust space between Asian text and numbers

**Formatted:** Underline

**Formatted:** Indent: Left: 2 cm, Space After: 0 pt, Line spacing: 1.5 lines

**Formatted:** Indent: Left: 2 cm, Space Before: 10.5 pt, After: 0 pt, Line spacing: 1.5 lines

### Construction Noise and Vibration Management Plan (CNVMP)

29. The consent holder must prepare and submit a Construction Noise and Vibration Management Plan (**CNVMP**) in general accordance with the draft CNVMP referenced in Condition 1.
30. The objective of the CNVMP is to identify and adopt the Best Practicable Option for minimising adverse construction noise and vibration effects, including defining the procedures to be followed to achieve compliance with the criteria in Conditions 65 and 67 where practicable; and where compliance cannot practicably be achieved, ensuring that the Schedule to the CNVMP is prepared in accordance with Condition 70.
- 30A. The consent holder must engage with the CLG and affected receivers as identified by the SQEP as part of the development of the final CNVMP to ensure a clear understanding of the constraints and requirements of those residents and businesses operating in the vicinity of Project inform the approach to mitigating noise and vibration effects associated with the demolition and construction phases of the Project.
31. The CNVMP must, at a minimum, include the information required by Section 8 and Annex E2 of NZS6803:1999. The CNVMP must include at a minimum:
  - a. Noise and vibration criteria identified in Conditions 65 and 67;
  - b. Hours of work;
  - c. Identification of the likely sources of noise emissions during the demolition and construction works;
  - d. Identification of the likely noise and vibration levels activities during the demolition and construction works;
  - e. Identification of the duration, frequency and timing of works to manage disruption;

## DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

- f. Identification of potentially affected receivers;
- g. Processes for engaging with potentially affected receivers;
- h. Measures for controlling noise and vibration;
- i. A complaints procedure;
- j. Methods and frequency for construction noise and vibration monitoring, and reporting of monitoring results and outcomes;
- k. Noise and vibration management training requirements;
- l. Procedures for preparing a Schedule to the CNVMP in accordance with Conditions 70 and 71;
- m. A description of situations where a Schedule is likely to be required by Condition 69; (including demolition and construction works) at certain times and locations and certain types of activities), and
- n. A requirement for the review of the CNVMP:
  - (i) annually after its first certification; and
  - (ii) where there are changes to the construction methodology during the demolition and construction works that are likely to result in material changes to noise and vibration levels from those addressed in the CNVMP.
- o. A requirement for the update of the CNVMP:
  - (i) where there are changes to the construction methodology during the demolition and construction works that are likely to result in material changes to noise and vibration levels from those addressed in the CNVMP.

- 31A. The consent holder must implement the certified CNVMP for the duration of the demolition and construction works and keep an updated copy at the Site office.

### **Erosion and Sediment Control Management Plan (ESCMP)**

32. The consent holder must prepare and submit an Erosion and Sediment Control Plan (**ESCMP**) in general accordance with the draft ESCP referenced in Condition 1 and guided by Council's guideline document *Erosion and Sediment Control Guide for Land Disturbing Activities in the Auckland Regional Guideline Document 2016/05 (GD05)*.
33. The objectives of the ESCMP are to:
- a. Detail the Best Management Practices that will be implemented to minimise potential for erosion; and

## DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

- b. Maximise the removal of sediment from any stormwater runoff during earthworks and land disturbance prior to discharge into the receiving environment.

34. The ESCMP must include at a minimum the following information:

- a. Specific erosion and sediment control works (location, dimensions, capacity, supporting calculations and design drawings), all controls must be in ~~the~~ accordance with Auckland Council's Guideline Document 2016/005 Erosion and Sediment Control Guide for Land Disturbing Activities in the Auckland Region (GD05);
- b. Catchment boundaries;
- c. Timing and duration of construction and operation of control works (in relation to the staging and sequencing of earthworks);
- d. Details relating to the management of exposed areas (e.g., grassing, mulching or placement of hardfill); and
- e. Monitoring and maintenance requirements for the proposed erosion and sediment controls.
- f. Location of stabilised construction entry/exits.
- g. Wheel wash facilities, if required, at each exit point to minimize sediment tracking onto the public roads.
- h. Confirmation of how dewatering and treatment of water will be undertaken.
- i. Monitoring and maintenance requirements, including specific maintenance required for the water treatment device(s) and frequency of cleaning out / desilting.
- j. Confirmation of the wastewater system that will be built, the construction methodology and the required erosion and sediment control measures.
- k. Prior to 1 May of any year that earthworks are proposed to be undertaken during the winter period (1 May to 30 September inclusive), the ESCMP should be reviewed and updated to include any additional ESC measures that may be required during the winter period.

34A. All discharges from the site to the receiving environment (including the stormwater system) must achieve a minimum water quality of:

- a. 100 mm of visual clarity; and
- b. pH between 5.5 and 8.5.

## DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

34B. Prior to the commencement of earthworks activity on the site, a Chemical Treatment Management Plan (ChTMP) must be prepared in accordance with GD05 and submitted to Council for written certification. No earthwork activities must commence until written certification is provided by Council that the ChTMP meets the requirements of GD05, and the measures referred to in that plan have been implemented. The ChTMP must include as a minimum:

- a. Specific design details of chemical treatment system based on a flow activated dosing methodology for the site's dewatering system(s);
- b. Monitoring, maintenance and contingency programme (including a record sheet);
- c. Details of optimum dosage (including assumptions);
- d. Results of initial chemical treatment trial;
- e. A spill contingency plan; and
- f. Details of the person or bodies that will hold responsibility for long term operation and maintenance of the chemical treatment system and the organisational structure which will support this system.

### **Advice note:**

In the event that minor amendments to the ChTMP are required, any such amendments should be limited to the scope of this consent. Any amendments which affect the performance of the ChTMP may require an application to be made in accordance with section 127 of the RMA. Any minor amendments should be provided to the Council prior to implementation to confirm that they are within the scope of this consent.

34C. The site's dewatering system(s) must be chemically treated in accordance with the certified ChTMP required by condition 34B.

34D. All water generated during the concrete cutting must be contained and appropriately disposed of to ensure it does not enter the stormwater system.

### **Dust Management Plan (DMP)**

35. The consent holder must prepare and submit a Dust Management Plan (**DMP**) in general accordance with the draft DMP referenced in Condition 1.

36. The objective of the DMP is to manage and monitor dust related effects from demolition, earthworks and construction onsite in accordance with the "Ministry for the Environment Good Practice Guide for Assessing and Managing the Environmental Effects of Dust Emissions" dated November 2016.

## **DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT**

- 36A The consent holder must engage with the CLG and affected receivers as identified by the SQEP as part of the development of the final DMP to ensure a clear understanding of the constraints and requirements of those residents and businesses operating in the vicinity of Project to inform the approach to mitigating dust effects associated with the demolition and construction phases of the Project.
37. The DMP must, as a minimum, include the following information:
- a. A general description of the activities and main potential sources of dust emission;
  - b. Contact details for the person who will manage dust and receive complaints on Site to be made available to staff;
  - c. A full description of the dust mitigation system, including identifying relevant operating procedures and parameters, inventory of mitigating equipment and materials, details and reporting on maintenance programmes for this equipment and contingency procedures;
  - d. A description of the staff training required, including areas staff are to be trained in, mitigation methods to be used, frequency of training and where training records are to be kept;
  - e. Visual inspection and monitoring procedures, including frequency and kind of monitoring to be undertaken, records to be kept and any system review or reporting required;
  - f. Methods for continuous monitoring of ambient PM10 or Total Suspended Particulate (TSP) concentrations and wind speed and direction in accordance with Condition 101A, including specification of trigger levels for ambient PM10 or TSP concentrations and procedures for investigating and implementing dust management responses to measured trigger level exceedances; and
  - g. A process to record and investigate any dust complaints.

### **Groundwater and Settlement Monitoring and Contingency Plan (GSMCP)**

38. The consent holder must prepare and submit a Groundwater and Settlement Monitoring and Contingency Plan (**GSMCP**) in general accordance with the draft GSMCP referenced in Condition 1.
39. The objective of the GSMCP is to set out project controls to measure groundwater drawdown and ground settlements, and to address potential geotechnical effects related to the demolition and construction works.

## **DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT**

- 39A. The consent holder must engage with the CLG and affected receivers as identified by the SQEP as part of the development of the final GSMCP to ensure a clear understanding of any particular constraints or mitigation requirements of those buildings (and the activities contained within them) in the vicinity of the Project to inform the approach to mitigating groundwater and settlement effects associated with the Project.
40. The GSMCP must, as a minimum, include the following information:
- a. A monitoring location plan, showing the location and type of all Monitoring Stations, including ground and building deformation pins, retaining wall deflection markers and inclinometers and groundwater monitoring boreholes. The monitoring plan must be based on the plan titled "Downtown Car Park Redevelopment - Construction Monitoring and Instrumentation Plan", prepared by T + T, Figure 1, rev. 42, dated 2 May 2025. In any case where the location of a Monitoring Station differs substantively from that shown on the plan titled "Downtown Car Park Redevelopment - Construction Monitoring and Instrumentation Plan", prepared by T + T, Figure 1, rev. 42, dated 2 May 2025, a written explanation for the difference must be provided at the same time that the GSMCP is provided;
  - b. Final completed schedules B to D for monitoring of ground surface, building deformation and retaining wall deflection (including any proposed changes to the monitoring frequency) as required by conditions below;
  - c. All monitoring data, the identification of Services susceptible to Damage and all building/Service condition surveys undertaken to date, and required by conditions below;
  - d. A bar chart or a schedule, showing the timing and frequency of condition surveys, visual inspections and all other monitoring required by this consent, and a sample report template for the required two monthly monitoring;
  - e. All Alert and Alarm Level Triggers (including reasons if changes to such are proposed, for example as a result of recommendations in the building condition surveys or data obtained from pre-dewatering monitoring); and
  - f. Details of the contingency actions to be implemented if Alert or Alarm Levels are exceeded.
41. A copy of all pre-excavations building, structure condition surveys, and Service condition surveys required by this consent must be submitted to the Council with the GSMCP. All other records required by this consent must be provided to the Council upon request.

## DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

### Contamination Site Management Plan (CSMP)

42. The consent holder must prepare and submit a Contamination Site Management Plan (**CSMP**) in general accordance with the draft CSMP referenced in Condition 1, following the completion of a Detailed Site Investigation (DSI) referenced in Condition [141].
43. The objectives of the CSMP are to:
- a. Provide procedures to manage potential ground contamination effects on human health and the environment during ground disturbance activities associated with the proposed site development works.
  - b. Outline pre-works Site investigations to support Site development.
  - c. Meet the requirements for these conditions for ground disturbance works under the NESCS and AUP.
44. The CSMP must, as a minimum, include the following information:
- a. Pre-works sampling procedures including sampling rationale, methodology, data evaluation and reporting;
  - b. Health and safety procedures;
  - c. Ground disturbance procedures;
  - d. Validation and completion reporting; and
  - e. CSMP administration and control.

### Site-Specific Waste Plan (SSWP)

- 44A. The consent holder must prepare and submit a Site-Specific Waste Plan (**SSWP**) following the appointment of a contractor.
- 44B. The objective of the SSWP is to minimise waste during deconstruction, demolition and construction activities.
- 44C. The SSWP must, as a minimum, include an analysis of all material on-site and salvage processes for all valuable and reusable items where appropriate.

### Prior to Commencement Conditions

#### Pre-construction meeting

45. Prior to the commencement of each stage of construction including demolition, enabling works and earthworks, the consent holder must hold a pre-start meeting that:
- a. Is located on the Site;
  - b. Is scheduled **not less than five days** before the anticipated commencement of earthworks and/or construction;

## DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

- c. Includes an Auckland Council Monitoring Officer;
- d. Includes representation from the contractors who will undertake the works;  
~~and~~
- e. Includes the project archaeologist; and
- f. Includes the project works arborist

The meeting will include a discussion on the methodology for the stage, including management plan requirements, and shall ensure all relevant parties are aware of and familiar with the necessary conditions of this consent.

The meeting prior to the commencement of demolition works must include agreement of the locations of tree protective fencing as required by conditions of this consent and record those locations.

The meeting prior to the commencement of earthworks must also include a site works briefing by the project archaeologist and the project archaeologist must provide information to the contractors engaged on the site regarding:

- a. What constitutes historic heritage materials;
- b. The legal requirements of unexpected historic heritage discoveries;
- c. The appropriate procedures to follow if historic heritage materials are uncovered whilst the project historic heritage expert is not onsite to safeguard materials; and
- d. The contact information of the relevant agencies (including the project historic heritage expert, the council monitoring team, the Auckland Council Heritage Unit and Heritage New Zealand Pouhere Taonga) and mana whenua.

The following information must be made available at the pre-start meeting:

- Timeframes for key stages of the works authorised under this consent;
- Resource consent conditions;
- Any applicable management plan(s)

### **Advice Note:**

*To arrange the pre-start meeting required by the above condition please contact the Council to arrange this meeting via [monitoring@aucklandcouncil.govt.nz](mailto:monitoring@aucklandcouncil.govt.nz), or 09 301 01 01. All additional information required by the council should be provided no less than two (2) days prior to the meeting.*

## **DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT**

- 45A. Prior to the commencement of demolition works, KinderCare must vacate their premises at the Aon Building. Confirmation that KinderCare vacated the site prior to the commencement of demolition works must be provided to Auckland Council.

### **Architectural Design Plans**

46. Prior to the lodgement of Architectural Building Consent, a finalised set of architectural detail drawings and materials specifications must be submitted to the Council for written certification. The information must include the following:
- a. Details of the building's façade treatment / architectural features;
  - b. Materials schedule and specification, sample palette of materials, surface finishes, and colour schemes (including colour swatches) referenced on the architectural elevations;
  - c. Site services demonstrating how mechanical, electrical and communications equipment will be generally concealed from public view as far as practicable where this cannot be avoided for operational reasons (including external / rooftop services / plant, and visual / aural screening elements);
  - d. Confirmation that the development complies with Standard H8.6.29 (Glare) of the AUP(OP); and
  - e. Final design of the service lane including pedestrian paths.
  - f. Finalised design of the ground floor elevation wall position and door locations relative to the stairs and planters along Lower Hobson Street to facilitate safe emergency egress during evacuation and reduce movement clash.

The finalised set of drawings must ensure that the building's proposed architectural treatment and finished appearance is consistent with the plans and information referenced at Condition 1, with the exception of any changes made to accommodate condition 46f above.

All works must then be carried out in accordance with the finalised architectural detail drawings and materials specifications, and thereafter retained and maintained for the duration of the consented development.

- 46A. If required under Condition 107A, the consent holder must provide architectural detail drawings and materials specifications of the wind screen must be submitted to the Council for written certification. The information must include the following:
- a. Details of aesthetic quality to demonstrate that is compatible with and complements its proposed architectural context;
  - b. Details of coordination with the proposed public realm concept and design

## DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

including relating to the proposal's plan geometry, planting and other urban landscape elements, public movement patterns and views to and from the Urban Room; and

- c. Details of the degree of visual permeability, particularly at its Hobson Street end.

### **Advice note:**

*As part of the condition monitoring process, Council's monitoring inspectors will liaise with members of the Council's Urban Design Unit to ensure that the submitted details under Conditions 46 and 46A are consistent with the approved plans and information.*

### **Landscape Treatment and Maintenance – Finalised Details**

47. Prior to lodgement of Architectural Building Consent a finalised set of Landscape Plans must be submitted to the Council for written certification. The finalised plans must be consistent with the landscape design identified in the plans and information referenced at condition 1 (except where addressing Universal design / movement concerns below) and must include:
  - a. Detailed landscape plans for streetscape and the Urban Room, terraces and roofs and specifications;
  - aa. Location of planter boxes adjoining circulation paths, with clear widths marked between walls, stairs, external doors and planter beds to show adequate clearances. This is to ensure appropriate egress widths and movement, particularly during an emergency evacuation on Lower Hobson Street;
  - b. Planting schedule, detailing the specific planting species, the number of plants provided, locations, distances in between trees at street level, type (ever green or deciduous), heights/ grade (litre) at the time of planting;
  - c. Irrigation and drainage details;
  - d. Hard landscape plan and specifications, detailing site levels, materiality and colour for paving, furniture and balustrade for external spaces;
  - e. Annotated sections and/or design details with key dimensions to illustrate that adequate widths and depths are provided for amenity planting beds, garden beds / tree pits / raised planters / podiums and roof terraces. The depth and width of planting on raised gardens, terraces and roofs must be of sufficient space to accommodate the proposed type and scale of planting including specimen trees. The design and engineering must include suitable drainage, irrigation and medium provisions;

## DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

- f. A management/maintenance programme, in particular details of:
  - i. maintenance methodology, responsibility including frequency;
  - ii. allowance for replacement of plants in case plants are severely damaged / die over the first five years of the planting being established.

47A The finalised landscape plans must include detailed design of the hotel pick-up and drop-off interface, including landscape buffer, paving differentiation, surface treatment, and any kerb, planter or level-change details.

### **Advice Note:**

*This information is necessary to clearly distinguish the public pedestrian route along Customs Street West from the hotel drop-off and waiting areas, while maintaining safe and legible movement for all users.*

47B. Within the first planting season following the development being occupied and operational, the consent holder must implement the landscape design of the urban room and podium roof, which has been certified by the Council under condition 47.

### **Signage and Wayfinding Design**

48. Prior to erection or installation of any signs, the consent holder must provide to Council a comprehensive Signage Management Plan for written certification containing details of all signs to be erected on the Site including:
- a. All exterior building signs, including identification and building naming signs.
  - b. All exterior directional, way finding, including the location of public lifts, amenities, locker rooms, accessible toilets and rest rooms, and traffic and parking signs associated with the management of vehicle access to and from the Site that is not on land controlled by Auckland Transport.
  - c. Advisory signage to be included within the service lane to encourage motorists exiting the site to travel to the east to use the Customs Street West service lane access rather than the Quay Street access.

To ensure that proposed signage is cohesive and does not detract from the architectural quality of the building and immediate surrounding area and avoids visual clutter and/or obstruction, this information is to include the location, dimensions, placement, materiality, colour, and method of attachment or placement of each sign.

### **Lighting Plan**

49. Prior to the lodgement of Architectural Building Consent, the consent holder must provide a Lighting Plan and Certification/ Specifications prepared by a qualified Lighting Engineer, to the Council for written certification. The purpose of this condition is to

## DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

provide adequate lighting for the safety of people, working or visiting the premises and its immediate environs outside of daylight hours. The Lighting Plan must:

- a. Include details of the light-box feature (lux levels, type of lighting);
- b. Include all accessible areas of the premises where movement of people are expected. Such locations include, but are not limited to building entrances, building frontages, footpath or common access areas;
- c. Include proposed locations, lux levels and types of lighting (i.e. manufacturer's specifications once a lighting style has been determined) and any light support structures required to control timing, level of lighting, or to minimise light spill, glare, and loss of nighttime viewing including for example emergency lighting, sensor lights, areas of glare free luminaires and, strip lighting along stairs and in front of lifts;
- d. Demonstrate compliance with the relevant standards in E24.6.1 Lighting of the Auckland Unitary Plan (Operative in Part);
- e. Demonstrate compliance with the AS/NZS 1158 P requirements and clearly specify what P Category the lighting design will achieve. The selection criteria for the chosen lighting category should also be presented (i.e. pedestrian/cycle activity, risk of crime etc);
- f. Demonstrate the vertical illuminance by means of lux contours or a similar method to assess light spill on neighbouring properties where relevant. The limits of the vertical illuminance must comply with Auckland Unitary Plan (Operative in Part) Standard E24.6.1.3;
- g. Include night-time illumination, where proposed, for the stairway along Customs Street West; and
- h. Include an executive summary of the above information in plain English that outlines how the relevant requirements have been applied and the design response to them.

50. The finalised design details certified by the qualified Lighting Engineer under Condition 49 must be established prior to the development being first occupied, and thereafter retained and maintained for the duration of the consented development.

### **Advice note:**

*The purpose of this condition is to ensure that adequate lighting is provided for frequently used areas within the proposed development for the safety of users. Adequate lighting is the amount of lighting at eye level for a person with average eyesight so they can identify any potential threat approaching them from at least a 15-metre distance.*

## DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

### Certification of sediment and erosion controls

51. Within ~~40~~ 20 working days following implementation and completion of the specific erosion and sediment control works referred to in Condition 32, and prior to the commencement of earthworks activity on the subject site, a SQEP must provide written certification that the erosion and sediment control measures have been constructed and completed in accordance with Code of Practice GD05 to the Council. Written certification must be in the form of a report or any other form acceptable to the Council.

### Advanced notification that earthworks will be beginning on site

52. The Council must be notified at least 5 working days prior to earthwork activities commencing on the Site.

#### Advice note:

- *The Auckland Council Team Leader, Compliance and Monitoring – Central is the appropriate person to send notification to, where required in this condition.*
- *Prior to the commencement of earthworks activity, all required erosion and sediment control measures on the Site shall be constructed and carried out.*
- *It is recommended that you discuss any potential measures with Council's monitoring officer who will guide you on the most appropriate approach to take. Please contact the Team Leader, Compliance & Monitoring Central on +64 9 301 0101 for more details.*

### Managed Access Service Arrangement Plan (M Social)

- 53A. The objectives of the MASAP are:
- a. To ensure necessary measures are in place to manage scheduling and coordination of access / servicing requirements and delivery arrangement of M Social to and from its service driveway on Lower Hobson Street; and
  - b. To ensure members of the public and general traffic do not enter the Lower Hobson Street slip lane during demolition and construction.
53. Prior to commencement of demolition that will affect access to the M Social service driveway (accessed via the Lower Hobson Street slip lane), the consent holder must prepare, a Managed Access Service Arrangement Plan (**MASAP**). The MASAP must include, but not be limited to, the following matters:
- a. Details of the proposed intercom systems to allow a loading vehicle arriving at the gate to request the contractors to open the gate;

## DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

- b. Identification of the maximum size of vehicle expected to use the M Social service driveway and an outline of the intended waiting area to **minimise** **avoid** queuing back into the Lower Hobson Street flyover lanes;
- c. Mechanisms to be undertaken, in consultation with M Social, to **avoid** **minimise** two trucks arriving to use the M Social service driveway at the same time;
- d. Details on the design of supports for the overhead hoardings adjacent to, and/or, over the M Social service driveway to maintain suitable vehicle access;
- e. Details on mechanisms that must be put in place to enable vehicles arriving at the service driveway to access the site outside of times when the construction site is operation (e.g. before or after normal construction times or at weekends);
- f. Details on the modification to Lower Hobson Street footpath kerb or modification of the median island between the lower-level Lower Hobson Street and the Lower Hobson Street flyover lanes to assist 8m trucks exiting the loading bay turning into the flyover lanes; and
- g. Provisions to update the MASAP to reflect the later stages of construction and any updated contractor management, where overlap of truck manoeuvring may occur between M Social loading vehicles and any construction vehicles required by this consented development.

**Commented [NS26]:** Change not accepted, notably involving the use of "Minimise" versus "without queuing". Significantly different implications and results in potential safety risks should a service vehicle be overhanging the lane with any oncoming traffic potentially resulting in a collision. This aspect was discussed at the meeting held on 9<sup>th</sup> June 2026, the applicant identified that the use of the term "Avoid" represents an inability to create some degree of flexibility around the approach to managing such matters. This might be an area of disagreement in principle. Another matter discussed in this vein was the potential for contractors to be aware of when service vehicles require access to M Social's loading bay. The suggestion raised was whether the use of a booking system, or something similar, could be appropriate to allow contractors controlling the boom dock to secure efficient and safe access.

**Commented [NS27]:** Change to "minimise" not accepted, as there is no space to accommodate two vehicles in this waiting area prior to enabling a service vehicle to enter the managed access. A second vehicle would block access to the flyover which would impact on the operation of the network, including buses.

**Commented [NS28]:** Deletion of (54)(g) accepted, as the nature of this inclusion is dealt with via earlier subclauses.

- 54 The MASAP must be developed in collaboration with M Social and submitted to Council for certification at least 10 working days prior to demolition activities affecting the M Social service driveway commencing.

### Advice Note:

*Engineering Plan Approval would be required for any kerb modifications or modifications to the median island prior to commencement.*

- 54-55.** The following information must be provided with the MASAP as part of the Council certification process:

- a. Records of consultation undertaken with M Social; and
- b. A summary of changes sought by M Social and a commentary from the consent holder in regard to the changes sought by M Social, whether the consent holder has or has not adopted these changes and the reason(s) for adoption/non-adoption of the changes.

**Formatted:** Indent: Left: 1.12 cm, Numbered + Level: 1 + Numbering Style: 1, 2, 3, ... + Start at: 55 + Alignment: Left + Aligned at: 1.27 cm + Indent at: 1.9 cm

**Formatted:** Indent: Left: 2.87 cm, Numbered + Level: 2 + Numbering Style: a, b, c, ... + Start at: 1 + Alignment: Left + Aligned at: 2.54 cm + Indent at: 3.17 cm

## DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

### Fire Hydrant Test

~~55-56.~~ At the Architectural building consent lodgement, the consent holder must submit to the council a fire hydrant test(s) and accompanying report prepared by a suitably experienced and qualified engineering professional that certifies that there is adequate available water pressure for the development that meets the criteria of the New Zealand Fire Service Firefighting Water Supplies Code of Practice SNZPAS 4509:2008. The results of the fire hydrant test(s) and accompanying certification report must be prepared in accordance with the SNZ PAS 4509:2008, Table 1 (noting that the development is sprinklered).

Formatted: Indent: Left: 1.12 cm, Numbered + Level: 1 + Numbering Style: 1, 2, 3, ... + Start at: 55 + Alignment: Left + Aligned at: 1.27 cm + Indent at: 1.9 cm

- 56A. The Consent Holder must pursue the installation of break tanks as outlined in Appendix 19 - Infrastructure Concept Design Report, with the design developed in conjunction with fire protection requirements

#### **Advice Note:**

*While the area can meet the required fire protection demands, given the age ((approximately)110 years) of the watermain at the proposed sprinkler connection point, it would be prudent to incorporate fire flows into the break tank design to help attenuate peak fire flow demand during fire events.*

### Stormwater Management Plan (SMP)

- 56B Prior to the lodgement of any Engineering Plan Approval (EPA) relating to the public stormwater network, the Consent Holder must ensure that a Stormwater Management Plan (SMP) has been prepared and formally adopted under Auckland Council's Regionwide Network Discharge Consent (RWNDK).

The adopted SMP must demonstrate compliance with the relevant requirements of Schedule 4 of the RWNDK and must apply to all stormwater discharges to the public stormwater network associated with the development.

#### **Advice Note:**

*The consent holder is advised that as they have not sought a private diversion and discharge consent as part of their FTAA application, and as their FTAA application stipulates that they will rely on the RWNDK, it is at the Applicant's risk to proceed at this point without adopting an SMP or a private consent.*

During works conditions

### Archaeological recording

## DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

57. All post 1900 historic heritage features associated with the Auckland Graving Dock (R11/3458/CHI 483), reclamation fill and the Gunson Building exposed by the excavation works must be recorded by the project archaeologist. The recording of works must include:

- a. Onsite monitoring of works in the locations identified;
- b. Spot check monitoring of the rest of the Project area, and
- c. Call-in by the contractor if suspected historic heritage remains are exposed when the project archaeologist is not present.

If post 1900 structures associated with the 1915 reclamation or the Gunson Building are identified they are to be recorded to the standards prescribed in Heritage New Zealand Pouhere Taonga Archaeological Guidelines Series: Number 1 – Investigation and Recording of Buildings and Standing Structures (2018)

### **Advice Notes:**

*Heritage New Zealand Pouhere Taonga Archaeological Guidelines Series: Number 1 – Investigation and Recording of Buildings and Standing Structures (2018) are available at [www.heritage.org.nz/protecting-heritage/archaeology/archaeological-guidelines-and-templates](http://www.heritage.org.nz/protecting-heritage/archaeology/archaeological-guidelines-and-templates).*

### **Tree Protection**

58. The consent holder must ensure that all tree work be undertaken in accordance with the recommendations within the Arboricultural Assessment, prepared by Peers Brown Miller Ltd, dated 04/11/2025. A copy of this Arboricultural Assessment must be available onsite at all times.
59. The consent holder must ensure that no excavations are to be undertaken within the protected root zones of any street trees (including those within Sturdee Street Reserve) as part of the works, as all hard surfaces or foundations are beyond the canopy of the identified trees. If any alterations are required, further advice must be sought from the works arborist.
60. The protected root zone of the street trees must be considered sacrosanct. No building or fill materials must be stored or placed within the protected areas, either on a temporary or permanent basis.
61. Protective fencing of at least 1.8m high must be installed at an appropriate alignment on the edge of the root zone, under the guidance of the appointed project works arborist. This fencing must be installed at the edge of the root zone where practicable.
62. The fencing as required in condition 61 must remain in place for the duration of the

## DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

Project in order to best protect the subject trees. The fencing is to be rent-o style steel mesh sections. The location of this fencing as described in conditions 61 and 62 is to be confirmed and approved at the pre-construction meetings required by condition 45.

63. All pruning works are to be undertaken by a Council Approved Arborist under the supervision of the project works arborist. The pruning is to be recorded and added to the completion log.
64. Compliance with all conditions of consent relating to tree protection must be monitored by the appointed project works arborist, with the detail of each visit and communication being logged. The completed log must be provided to the consent holder at the completion of the project to serve as a compliance report and made available to the Council on request.

### Advice Notes:

- Prior to all works commencing on the Site, the consent holder should engage the services of a qualified and competent arborist experienced in site development activities in close proximity to mature trees to direct, supervise and monitor all pruning and activity that occurs in the root zone of protected trees for the duration of the Project in accordance with standards E17.6.*
- The consent holder should ensure that all contractors, sub-contractors, and workers engaged in all activities covered by this consent are advised of the tree protection measures in the conditions of consent and operate in accordance with them.*
- Any proposed works in the road reserve or on existing street trees will require Tree Owner Approval from the Community Facilities Urban Forest Specialist Team as the asset owner. Approval requests can be sent to [treemanager@auckland.council.govt.nz](mailto:treemanager@auckland.council.govt.nz)*

### Construction noise limits

65. Demolition and construction noise must be measured and assessed in accordance with NZS6803:1999 "Acoustics – Construction Noise" and must, subject to condition 66, comply with the following criteria at occupied buildings:

| Time                              | Construction Noise |        |
|-----------------------------------|--------------------|--------|
|                                   | dB LAeq            | LAFmax |
| Monday to Friday 6:30am – 10:30pm | 75                 | 90     |
| Saturday 7:00am – 11:00pm         | 80                 | 90     |

## DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

| Time                   | Construction Noise |        |
|------------------------|--------------------|--------|
|                        | dB LAeq            | LAFmax |
| Sunday 9:00am – 7:00pm | 65                 | 85     |
| All other times        | 60                 | 75     |

66. Where compliance with the criteria set out above is not practicable, the process in Condition 69 shall be adopted.

**Advice note:**

*Where external measurement of construction noise is impractical or inappropriate, the upper limits for the noise measured inside the building will be 20 dB less than the relevant levels in Table E25.6.28.2.*

**Construction vibration – amenity limits**

67. Demolition and construction vibration must be measured in accordance with ISO 4866:2010 "Mechanical vibration and shock – Vibration of fixed structures – Guidelines for the measurement of vibrations and evaluation of their effects on structures" and comply with the vibration amenity standards set out in the following table subject to condition 67A.

| Receiver                             | Period           | Peak Particle Velocity |
|--------------------------------------|------------------|------------------------|
| Occupied activity sensitive to noise | 10:00pm - 7:00am | 0.3 mm/s               |
|                                      | 7:00am -10:00pm  | 2.0 mm/s               |
| Other occupied buildings             | At all times     | 2.0 mm/s               |

- 67A. Vibration from sheet piling can exceed the limits in Condition 67 at 29 Customs Street West (Aon Building) between the hours of 5pm and 10:30pm Monday to Friday and 7am to 11pm Saturdays.

**Construction vibration – cosmetic building damage**

68. Demolition and construction vibration in relation to cosmetic building damage must be measured in accordance with, and comply with the relevant limits in, German Standard DIN 4150-3:2016 "Vibrations in buildings – Part 3: Effects of vibration on structures".
69. If a construction activity during demolition and construction works is predicted or measured to result in an exceedance of the noise and/or vibration criteria in Conditions 65 and 67 or occur outside the hours in condition 73, a SQEP must prepare a Schedule

## DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

to the CNVMP (Schedule), in consultation with the owners and occupiers of sites subject to the Schedule. The objective of a Schedule is to set out the Best Practicable Option for minimising the noise and/or vibration effects of an activity that cannot practicably comply with the criteria in Conditions 65 or 67.

**Advice note:**

*A schedule must not apply to low noise creating activities such as site set up, painting, electrical works and internal fit out which may occur outside of hours set out in condition 73.*

- 70A Consultation undertaken as part of the Schedule must include:
- a. A review of the construction methodology, mitigation measures, predicted noise levels and management strategies with the affected party; and
  - b. Consideration of the affected party's sensitivities to construction noise including timing and location.
70. A Schedule must include, as a minimum, the following details:
- a. the activity start and finish dates, equipment and methodology;
  - b. a plan showing the location of the activity and the receivers to be affected by a measured or predicted exceedance;
  - c. for each identified receiver, the predicted noise and/or vibration levels and durations of the exceedance;
  - d. the proposed site-specific noise and/or vibration mitigation measures that are proposed to be adopted and any mitigation options that have been discounted as being impracticable, and the reasons why;
  - e. a summary of the consultation undertaken with each identified receiver, and how consultation has been considered; and
  - f. the locations, times and types of monitoring including requirements to monitor at the first occurrence of the activity to which the schedule relates.
71. Each Schedule must be submitted to Council for certification at least 5 days before the activity commences, except where not undertaking the activity has health and safety or adjacent property damage risks, prior to the start of the activity to which the Schedule applies, and must be implemented for the duration of that activity.

**Construction hours**

72. The construction works must be restricted to hours between 6.30am and 10.30pm, Monday to Friday and 7am – 11 pm on Saturdays. No construction works are permitted

## DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

on Sundays or public holidays unless authorised under condition 70.

### **Advice note:**

*This restriction shall not apply to low noise creating activities such as site set up, painting, electrical works and internal fit out which may occur outside of these hours Monday to Saturday only.*

### **Operational Noise**

73. Noise arising from operational activities on the site must be measured and assessed in accordance with New Zealand Standard NZS 6801:2008 Measurement of environmental sound and New Zealand Standard NZS 6802:2008 Acoustics - Environmental noise.
74. The following noise limits must not be exceeded by activities occurring on the site when measured or assessed as the incident level on the façade of any building on another site in the business – City Centre Zone

| Time             | Noise Level                                                               |
|------------------|---------------------------------------------------------------------------|
| 7:00am – 11:00pm | 65 dB LAeq                                                                |
| 11:00pm – 7:00am | 60 dB LAeq<br>65 dB LAeq at 63 Hz<br>60 dB LAeq at 125 Hz<br>75 dB LAFmax |

The 63 Hz and 125 Hz octave band limits do not apply to fixed mechanical services plant.

75. Noise sensitive spaces must be designed and/or insulated so that the internal noise levels do not exceed the following limits based on the levels in Condition [74] incident on the façade.

| Space                        | Time             | Noise Level                                               |
|------------------------------|------------------|-----------------------------------------------------------|
| Bedrooms and sleeping areas  | 11:00pm – 7:00am | 35 dB LAeq<br>45 dB LAeq at 63 Hz<br>40 dB LAeq at 125 Hz |
| Other noise sensitive spaces | At all times     | 40 dB LAeq                                                |

Where the internal noise limits can only be complied with when doors or windows to rooms are closed, those rooms must have a mechanical ventilation and cooling system that shall not generate a noise level greater than:

- a. 35 dB LAeq in bedrooms and sleeping areas, and

## DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

- b. 40 dB LAeq in other noise sensitive spaces

This noise level must be measured at the minimum air flows and in accordance with *AS/NZS 2107:2016 Acoustics- Recommended design sound levels and reverberation times for building interiors*.

76. Prior to approval of the Architectural building consent application, the consent holder must provide an Acoustic Report to the Council confirming that noise sensitive spaces in the building have been designed to comply with Condition 75.

### **Wastewater**

77. The consent holder must ensure that connections to the public wastewater reticulation network to serve the development in accordance the requirements of the wastewater utility service provider are in place prior to occupation of the building. Certification from a suitably qualified civil engineer that works have been satisfactorily undertaken must be provided at the completion of the works to the Council.

### **Advice note:**

- *The consent holder must obtain written approval from Watercare on the wastewater servicing infrastructure to be submitted as part of the application for engineering plan approval with Auckland Council.*
- *Acceptable forms of Evidence from the Utility Providers include a Certificate of Acceptance.*
- *Alterations to the public wastewater reticulation network require Engineering Plan Approval. Additional approval is required from Watercare/Veolia as part of the Engineering Plan Approval Process.*
- *Public connections are to be constructed in accordance with the Water and Wastewater Code of Practice.*
- *Plans approved under Resource Consent do not constitute an Engineering Plan Approval and should not be used for the purposes of constructing public reticulation works in the absence of that approval.*
- *A build-over application and approval may be required prior to the Building Consent for the development.*
- *Work Over Approval may be required*

### **Flooding**

78. Prior to occupation of the building, the consent holder must construct a flood barrier at the northern end of the service lane and, if required in response to flood hazards in Customs Street West, at the southern end of the service lane in accordance with the

## **DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT**

Flood Hazard and Risk Assessment prepared by Tonkin + Taylor (reference: 1016043 v7, dated November 2025). The consent holder must provide to Council written confirmation from a SQEP that the flood barrier(s) has been installed in accordance with the Flood Hazard and Risk Assessment prior to occupation of the building.

- 79A. The consent holder must prepare and submit a Flood Barrier Management Plan (**FBMP**) in general accordance with the draft FBMP referenced in Condition 1.
- 79B. The objective of the FBMP is to ensure that flood and coastal inundation risks, including residual risks, are appropriately managed to protect building occupants, infrastructure, and the receiving environment from natural hazard risks over a 100-year timeframe.
- 79C. The FBMP must include, at a minimum:
  - a. A description of the flood barrier system;
  - b. Roles and responsibilities;
  - c. Flood barrier activation procedure;
  - d. Barrier lowering and post-flood procedure;
  - e. Service inspection and maintenance program;
  - f. Training requirements;
  - g. Emergency response, including in the event of a failure, and key contacts;  
and
  - h. Document control and review.
- 79D. Prior to the lodgement of relevant building consents, the consent holder must provide to Council details, prepared by a SQEP, of the flood management measures for the development, including but not limited to:
  - a. Protection of electrical equipment;
  - b. Waterproofing of doors;
  - c. Drainage sumps within the basement; and
  - d. Specific measures relating to any wastewater storage.

### **Access and Parking**

- 79. Prior to occupation of the building, all access, parking and maneuvering areas must be formed, sealed with an all-weather surface, marked out, sign posted and drained in accordance with the approved plans in Attachment 2.
- 80. All new vehicle crossings must be designed and formed in accordance with the Auckland Transport Design Manual. The new crossing must maintain an at-grade

## DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

(level) pedestrian footpath across the length of the crossing, using the same materials, kerbing, pavings, patterns and finish as the footpath on each side of the crossing.

### Advice Notes:

*A vehicle Crossing Permit is required to be obtained for these works. Please contact Auckland Transport for vehicle crossings, Ph. (09) 353 3553 or refer to their website for standards and requirements. <https://at.govt.nz/about-us/working-on-the-road/vehicle-crossing-application/>*

81. Prior to the operation of the activity, all redundant vehicle crossings must be removed and reinstated as kerbing and verge/footpath in accordance with Auckland Transport Design Manual. This must be undertaken at the consent holder's expense.

### Advice Note:

*The final condition of the reinstatement is to be confirmed either at Engineering Approval Stage or based on further discussions to take place as part of the Integration Agreement between the applicant, Auckland Council, and Auckland Transport.*

81.—

### Bicycle Parking

82. The consent holder must provide at least 594 secure long stay bicycle parking spaces within the Site and at least an additional 94 visitor cycle parking spaces onsite. The bicycle parking spaces must be installed and available for use before occupation of the building and must be provided at the expense of the consent holder and maintained as such thereafter for the duration of the activity.

### Electric Vehicle Supply Equipment

- 83A. At the lodgement of building consent, the consent holder must provide the Council with certification plans showing the space identified for future Electric Vehicle Supply Equipment as required by Standard E27.6.7(1).

### Earthworks

83. The erosion and sediment controls at the site must be constructed and maintained in accordance with the certified Erosion and Sediment Control Plan and Auckland Council guideline Document 2016/005 'Erosion and Sediment Control Guide for Land Disturbing Activities in the Auckland Region' throughout the duration of the earthwork activity, or until the Site is permanently stabilised against erosion. A record of any maintenance work must be kept and be supplied to the Council on request.
84. Earthworks must be managed to avoid the deposition of earth, mud, dirt or other debris on any public road or footpath resulting from earthworks activity on the Site. In the event

Formatted: Font: Not Italic, Underline, Not Highlight

Formatted: Font: Italic, Not Highlight

Formatted: Normal, Indent: Left: 1.75 cm, First line: 0.02 cm, No bullets or numbering

**Commented [NS29]:** Amendments accepted in part. Accept that there is a timing question here, where AT have planned to undertake significant corridor works to remove the flyover that would potentially coincide with enhancing pedestrian facilities along the site's frontage. There is a potential that an interim footpath tie in may be needed, should the removal of the flyover be out of sequence with this development. The conversations remain open in this regard.

Formatted: Indent: Left: 1.75 cm, No bullets or numbering

## DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

that such deposition does occur, it must immediately be removed. In no instance shall roads or footpaths be washed down with water without appropriate erosion and sediment control measures in place to prevent contamination of the stormwater drainage system, watercourses or receiving waters.

85. Earthworks must be managed to minimise any discharge of debris, soil, silt, sediment or sediment-laden water beyond the Site to either land, stormwater drainage systems, watercourses or receiving waters. In the event that a discharge occurs, works must cease immediately and the discharge must be mitigated and/or rectified to the reasonable satisfaction of the Council.

### **Geotechnical**

86. All earthworks must be managed to ensure that they do not lead to any uncontrolled instability or collapse either affecting the Site or adversely affecting any neighbouring properties. In the event that such collapse or instability does occur, it must be rectified as soon as practicable.
- 87A. Prior to the lodgement of structure building consents, the consent holder must identify and locate all public and private services, basements and foundations in proximity (beyond the extent of any ground anchors and the zone of influence of any retaining) to the proposed earthworks and anchors. This must inform the detailed design, and anchor geometry must be designed to avoid effects on buried services and neighbouring foundations and retaining walls.

### *Advice Note:*

*It is necessary to assess the effects on basements, foundations and services, regardless of their ownership.*

- 87B. Further detailed design (including PLAXIS modelling) must be completed for the basement retaining walls to confirm, based on the final construction methodology and sequence, including the following matters:
- a. Retaining wall movements and ground settlement: confirmation of predicted wall deflections and associated ground surface settlement for the final excavation staging and support system remain within consented limits.
  - b. Temporary/permanent support demands; final sizing/spacing and load demands for temporary anchors and/or top-down props, including waler/capping beam actions.
  - c. Groundwater cut-off and seepage effects: confirmation of the final D-wall toe level to achieve the required groundwater cut-off and to manage seepage uplift/piping risks consistent with the Geotechnical Report by Tonkin + Taylor

## DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

(reference: 1016043.2000-RPT-GT-001, dated: November 2025) assumptions.

- d. Liquefaction effects: refinement of liquefaction assessment inputs and confirmation of liquefaction-related lateral earth pressures/deformation demands on the wall system.
- e. Contingency: sensitivity testing for parameters and construction elements for contingency planning.
- f. Considerations of neighbouring building surcharge, including basement and deep foundations.

The above must be supported by additional investigation and groundwater testing as necessary. These confirmations will be undertaken consistent with the Geotechnical Report by Tonkin + Taylor (reference: 1016043.2000-RPT-GT-001, dated: November 2025) design basis and the consent conditions, and must not materially change the effects conclusions.

87. Unless specifically provided for by this consent, or unless approval is obtained from Auckland Transport, there must be no damage to public roads, footpaths, berms, kerbs, drains, reserves or other public asset as a result of the earthworks, demolition and construction activity. In the event that such damage does occur, the consent holder must notify the Council within 24 hours of its discovery. The costs of rectifying such damage caused by the construction activity will be met by the consent holder.

### **Geotechnical supervision**

88. Earthworks and construction of retaining walls must be supervised by a SQEP who is familiar with Geotechnical Report by Tonkin + Taylor (reference: 1016043.2000-RPT-GT-001, dated: November 2025). In supervising the works, the suitably qualified geotechnical engineering professional must ensure that they are constructed and otherwise completed in accordance with the engineering plans and geotechnical recommendations, relevant engineering codes of practice and detailed plans forming part of the application. The supervising engineer's contact details must be provided in writing to the Council at least two weeks prior to earthworks commencing onsite.

### **Construction methodology**

90. The consent holder must, two weeks prior to the lodgement of structural building consents, provide a detailed construction methodology written or endorsed by a chartered geo-professional for the contractor to undertake the earthworks with and include the recommendations provided within Geotechnical and Groundwater Assessment Report by Tonkin + Taylor (reference: 1016043.2000-RPT-GT-001, dated:

## DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

November 2025) to the Council for written certification. The construction methodology must include:

- a. Details confirming the sequencing of installation of new underground services to follow after the decommissioning of ground anchors where ground anchors are identified by the SQEP to affect new service locations;
- b. The detailed basement design as required by this condition must include:
  - i. safety requirements for the areas above excavations and excavation time frames; and
  - ii. temporary propping/weatherproofing and sequencing of boundary works.

The consent holder must ensure that the contractor carries out the earthworks and construction in accordance with the certified construction management plan at all times.

No earthworks may commence until written certification of the construction methodology by the Council has been provided.

### **Advice Note:**

*This must be provided to ensure boundary stability is maintained throughout the civil works stage of the development.*

- 90A. The consent holder must provide detailed information to MCK on demolition of the existing carpark structure at proposed Gridlines J-N/26 where the existing M Social building is on the boundary and pile foundations are on the boundary, founded at a higher level than the diaphragm wall. This must be provided to MCK at least 20 working days prior to commencement of localised demolition in this area.
91. Certification from a suitably qualified engineering professional (SQEP) must be provided to the Council confirming that the earthworks have been completed in accordance with the approved construction methodology as required by Condition [90] within 10 working days following completion. Written certification must be in the form of a geotechnical completion report, or any other form acceptable to the council.

### **Activities to be Carried Out in Accordance with the Groundwater and Settlement Monitoring and Contingency Plan (GSMCP)**

92. All construction, monitoring and contingency actions must be carried out in accordance with the further detailed basement designs, certified GSMCP and certified construction methodology. There must be no bulk excavation activities commencing until the GSMCP is certified in writing by the Council.

### **Erosion and Sediment Control**

## DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

93. The operational effectiveness and efficiency of all erosion and sediment control measures specifically required by the finalised Erosion and Sediment Control Management Plan (**ESCMP**) required under condition [32] must be maintained throughout the duration of earthworks activity, or until the site is permanently stabilised against erosion. A record of any maintenance work must be kept and be supplied to the Council on request.
94. There must be no deposition of earth, mud, dirt or other debris on any public road or footpath resulting from earthworks activity on the subject site. In the event that such deposition does occur, it must immediately be removed. In no instance can roads or footpaths be washed down with water without appropriate erosion and sediment control measures in place to prevent contamination of the stormwater drainage system, watercourses or receiving waters.

**Advice note:**

*In order to prevent sediment laden water entering waterways from the road, the following methods may be adopted to prevent or address discharges should they occur:*

- *provision of a stabilised entry and exit(s) point for vehicles*
- *provision of wheel wash facilities*
- *ceasing of vehicle movement until materials are removed*
- *cleaning of road surfaces using street-sweepers*
- *silt and sediment traps*
- *catchpits or environpods*

*In no circumstances should the washing of deposited materials into drains be advised or otherwise condoned.*

*It is recommended that you discuss any potential measures with the council who may be able to provide further guidance on the most appropriate approach to take. Please contact the council at [monitoring@aucklandcouncil.govt.nz](mailto:monitoring@aucklandcouncil.govt.nz) for more details.*

95. All machinery associated with the earthworks activities must be operated in a way that ensures that spillages of hazardous substances such as fuel, oil, grout, concrete products and any other contaminants are prevented.

**Advice note:**

*Adhesives, solvents, paints and other contaminants from building operations must be prevented from entering stormwater drains and adjacent waterways.*

96. There must be no damage to public roads, footpaths, berms, kerbs, drains, reserves or

## **DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT**

other public asset as a result of the earthworks, removal and construction activity. In the event that such damage does occur, the consent holder must notify Council within 24 hours of its discovery. The costs of rectifying such damage caused by the construction activity must be met by the consent holder.

- 97. All materials and equipment must be stored within the Site's boundaries unless evidence is provided to the Council that written permission is granted from Auckland Transport for specific storage within the road reserve.
- 98. Within 10 working days following the completion or abandonment of earthworks on the Site all areas of bare earth must be permanently stabilised against erosion to the reasonable satisfaction of the Council.

### **Dust and odour**

- 99. No onsite crushing of demolition material must occur onsite.
- 100. Only wet cutting of concrete must occur at any time during demolition and construction works.
- 101. Beyond the boundary of the Site, there must be no odour, dust or particulate caused by discharges from the Site, which (when assessed in accordance with the Good Practice Guide for Assessing and Managing Dust (Ministry for the Environment, 2016), is the cause of a noxious, dangerous, offensive or objectionable effect.
- 101A During structural demolition of the car park building and attached overpass and footbridge, the consent holder must continuously monitor ambient particulate concentrations and wind conditions at or adjacent to site boundary locations for the purposes of providing continuous feedback on the efficacy of dust management measures. The monitoring must be undertaken in accordance with the following:
  - a. Monitoring of PM<sub>10</sub> or Total Suspended Particulate (TSP) concentrations must be conducted at no less than two separate locations, either downwind or upwind of the demolition works in the prevailing wind direction, or proximate to sensitive receptors beyond the site boundary;
  - b. Monitoring of wind speed and direction must be conducted at no less than one location;
  - c. The monitoring locations described in clauses (a) and (b) must be as certified in accordance with Condition 101B, except with the written approval of the Council;
  - d. 1-minute and 15-minute averages of monitored parameters must be recorded, retained for a period of no less than 12 months and provided to the Council in writing within 5 working days of a written request;

## **DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT**

- e. Electronic alert notifications of measured exceedances of the trigger levels specified in the certified Dust Management Plan (DMP) must be automatically distributed to the relevant persons responsible for managing dust specified in the DMP; and
- f. Installation, maintenance and manual calibration of all monitoring instruments must be undertaken by a suitably qualified and experienced person and in accordance with the instrument manufacturer's specifications.

101B The consent holder must submit a written identification of the proposed monitoring locations required under clauses (a) and (b) of Condition 101A to Council for certification no less than 10 working days prior to the commencement of demolition activities.

102. No discharges from any activity onsite must give rise to visible emissions, other than water vapour, to an extent which, in the reasonable opinion of the Council, is the cause of a noxious, dangerous, offensive or objectionable effect.

103. Beyond the boundary of the Site, there must be no hazardous air pollutant, caused by discharges from the Site, which is present at a concentration that causes, or is likely to cause adverse effects to human health, the environment or property.

104. The Council must be notified as soon as practicable in the event of any significant discharge to air, which results in or has the potential to result in a breach of air quality conditions listed in Condition 101-103 or cause significant adverse effects on the environment. The following information must be supplied:

- a. Details of the nature of the discharge;
- b. An explanation of the cause of the incident; and
- c. Details of any remediation action taken.

### **Notice of Completion**

105. The Council must be advised in writing within 10 working days of when excavation has been completed.

### **Access to third party property**

106. Where any monitoring, inspection or condition survey specified in this consent requires access to property/s owned by a third party, and access is declined or subject to what the consent holder considers to be unreasonable terms, the Council must be notified by the consent holder and provided with all relevant details relating to access problems as soon as is practicable. If access cannot be reasonably obtained, then a report prepared by a SQEP identifying whether reasonably available alternative monitoring

## **DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT**

options are possible, must be provided by the consent holder to the Council. The report must state whether the alternative monitoring options will provide sufficient early detection of deformation / damage to enable measures to be implemented to prevent damage to buildings, structures or services. Written approval from the Council must be obtained by the consent holder before any alternative monitoring option is implemented.

### **Wind**

107. At the time of lodgement of Structural Building Consent for the buildings on the Site, the consent holder must provide to the Council written certification from a SQEP that the development results in wind conditions the same or better than those that may have been consented. If it is found that the consented wind conditions are exceeded, the consent holder must make any changes as necessary to the development to ensure that compliance is achieved, prior to building occupation.
- 107A. In the event that the Wind Mitigation Planting shown on the Drawings – Landscape referenced in Condition 1 plan located within the M Social property or legal road is unable to be implemented, the consent holder must install the wind screen as shown on the architectural drawings listed in Condition 1 prior to building occupation.

### **Glare**

108. The buildings must be designed, and such changes made to the buildings as are necessary to comply with the standard H8.6.29. (Glare) in the Auckland Unitary Plan (Operative in Part). The consent holder must provide to Council written confirmation from a SQEP that the building complies with this standard prior to occupation of the building.

## **Post Construction Conditions**

### **Hazardous Substance Management Plan**

109. Within 20 working days from the completion of works, the consent holder must provide a final Hazardous Substance Management Plan (**HSMP**) in general accordance with the draft HSMP referenced in condition 1.
110. The objectives of the HSMP are to detail the controls in place at the Site to manage hazardous substances and minimise the risk of release of these substances into the surrounding environment.
111. The HSMP must, as a minimum, include the following information:
- a. Roles and responsibilities;
  - b. Important contact details;
  - c. A hazardous substance register including their storage locations, and

## **DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT**

associated safety data sheets;

- d. A risk register including identified risks and associated controls;
- e. Spill response plan (SRP);
- f. Emergency response management plan (ERMP);
- g. Site inspections, monitoring;
- h. Staff training; and
- i. Provisions of site audit and review of HSMP.

### **Flooding**

- 112. Within 20 working days from the completion of the works, the consent holder must provide to the Council a statement from a SQEP certifying that the overland flow path depicted within the Flood hazard and risk assessment by Tonkin + Taylor (reference: 1016043 v7, dated: November 2025) has its alignment maintained across the service lane.
- 113. Within 20 working days from the completion of the works, the consent holder must provide to the Council a statement from a SQEP certifying that the flood protection requirements recommended within the Flood hazard and risk assessment by Tonkin + Taylor (reference: 1016043 v7, dated: November 2025) have been installed and / or completed onsite.

### **Covenant for the lease of off-site parking spaces**

- 115. The consent holder must enter into a section 108 Resource Management Act 1991 covenant in favour of Auckland Council for 196-200 Quay Street [Lot 8 DP 60151] to use carparks within the Site. The consent holder must contact the Council to initiate the preparation of the covenant. A copy of the updated Computer Register (Record of Title) showing that the covenant has been registered must be provided to the Council prior to occupation of the building.

The covenant must:

- a. Stipulate that the site [196-200 Quay Street – Lot 8 DP 60151] has exclusive use and access to up to 121 car parking spaces located within the basement levels of the adjacent site 2 Lower Hobson Street [Lot 9 DP 60151].
- b. If access to up to 121 car parking spaces must be restricted for any period of time that is not agreed in writing with the site owner [196-200 Quay Street] then the owner of the adjacent site [2 Lower Hobson Street Lot 9 DP 60151] must provide alternative car parking spaces in close proximity to the site in agreement with the owner of 196-200 Quay Street.

## DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

- c. Should this site [196-200 Quay Street – Lot 8 DP 60151] be redeveloped or significantly altered to provide new and /or additional car parking spaces, up to 121 car parking spaces at 2 Lower Hobson Street [Lot 9 DP 60151] associated with this site must be accounted for / included as part of this site's parking provision when calculating the maximum parking rates for the Business - City Centre Zone as set out within the Auckland Unitary Development Plan (Operative in Part) or its successor for this site [196-200 Quay Street – Lot 8 DP 60151].
- d. Be drafted by the Council's nominated Solicitor at the consent holder's cost; and
  - I. be registered against the Computer Register(s) (record of title) to the affected land by the consent holder at their cost; and
  - II. require the consent holder to:
    - be responsible for all legal fees, disbursements and other expenses incurred by the Council in connection with the covenant, and procure its solicitor to give an undertaking to the Council for payment of the same; and
    - indemnify the Council for costs, fees, disbursements and other expenses incurred by the Council as a direct result of the Council being a party to this covenant.

### Footpath Reinstatement

116. Within three months following completion of the construction works, the consent holder must reinstate the pedestrian footpaths along Lower Hobson Street and along Custom Street West to Auckland Transport - Transport Design Manual requirements unless otherwise agreed in writing by Auckland Transport.

### Advice Notes:

- *A Corridor Access Request (CAR) application is required from Auckland Transport for any works within the road reserve that affects the normal operation of the road, footpath or berm.*
- *New vehicle crossings are subject to approval by Auckland Transport prior to construction.*
- *An approval letter and completion certificate from Auckland Transport is required to be submitted to the Council as a verification that Auckland Transport has completed approval and a final vehicle crossing inspection.*
- *The final condition of the reinstatement is to be confirmed either at Engineering Approval Stage or based on further discussions to take place as part of the*

## DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

*Integration Agreement between the applicant, Auckland Council, and Auckland Transport.*

### Prior to Occupation of Building Conditions

#### Operational Waste Management Plan (OWMP)

117. Prior to the commencement of any activities on the Site, the consent holder must provide a final Operational Waste Management Plan (**OWMP**) to the Council, in general accordance with the draft OWMP referenced in Condition 1.
118. The objectives of the OWMP are to ensure the effective operation of waste collection and management procedures for the development and set out clear management policies to cater for different waste management requirements of the commercial tenancies and residential activities.
119. The OWMP must, as a minimum, include the following information:
  - a. Define user access arrangements in detail;
  - b. Confirm that the vehicles to be used for rubbish collection can satisfactorily enter and exit the site (noting the 3.6m vertical height restriction);
  - c. Details of waste materials to be collected by facilities management on each floor level (e.g. food organics);
  - d. Details of education information packs and notices for residential occupants with respect of using the waste chutes and any food organics collection arrangements (and other);
  - e. Maintenance arrangements for the effective and ongoing operation of the waste chutes;
  - f. Contingency arrangements in the event that waste chute(s) are not functional for a period of time.
  - g. Requirements for maintaining the clean and sanitary condition of the waste rooms and chutes.
  - h. Details of the guidance and training to be given to building management and collection staff on using the:
    - i. waste chutes;
    - ii. compactors; and
    - iii. waste rooms.

#### Servicing and Loading Management Plan (SLMP)

## DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

120. Prior to the commencement of any activities on Site, the consent holder must provide a final Servicing and Loading Management Plan (SLMP) to the Council, in general accordance with the draft SLMP referenced in Condition 1.

121. The objectives of the SLMP are:

a. To provide a clear framework for ongoing management of the loading spaces that have access from the service lane;

b. To coordinate and schedule booking of the loading spaces to manage the available capacity of loading spaces;

c. To minimise conflicts during AM peak periods between servicing requirements and pedestrians along Quay Street;

b. \_\_\_\_\_

d. To ensure compliance with the vertical clearance restrictions on the service lane; and

e. To ensure the loading areas operate safely.

122. The SLMP must, as a minimum, include the following information:

a. Use of an automated booking system (such as Mobile Dock) to ~~require: allow~~ ~~provide for where proposed;~~

(i) Loading spaces to be booked in advance

(ii) Users to be aware in advance of the vertical clearance restrictions. Any vehicles that are unable to enter from Customs Street West due to the vertical clearance restriction of 2.9 m must enter and exit via Quay Street

(iii) Vehicle details (number plate and vehicle size) to be confirmed in advance of arrival; and

(iv) Details of an integration between the loading dock management system with access control and CCTV systems, allowing license plate recognition to navigate any security barriers with an approved booking(s).

(v) The management of arrivals to avoid truck movements during the AM peak period Monday - Friday, between 7am – 10am, to reduce conflicts with pedestrians, particularly on the Quay Street footpath;

(iv)

b. Provide procedures to manage unscheduled vehicle arrivals. This must

Formatted: Indent: Left: 2.87 cm

**Commented [NS30]:** B&A98, deletion and comments are not accepted. In the first instance, the applicant is referring to the PM peak which is not addressed via the condition itself. During the AM period, there are considerably higher numbers of pedestrians in this part of the City Centre that will be traversing along the likes of Quay Street, which creates additional conflict points associated with the ability to service the development. To ensure that pedestrian amenity is maintained, it is considered appropriate to impose an AM peak period restriction given the significance of the City Centre and levels of pedestrian amenity that are present along Quay Street. Furthermore, during the AM peak there will be higher numbers of vehicles entering the service lane from Quay Street which will increase the potential for these vehicles to be delayed from turning into the site by pedestrians crossing the vehicle access, thereby affecting the efficient operation of Quay Street, including buses using Bus Stop E and buses in the eastbound bus lane. The use of "Minimise" here is appropriate, noting that part of the restriction is to reduce vehicle conflicts with pedestrians to avoid any service vehicles arriving to or departing from during the AM peak.

Formatted: Indent: Left: 3.5 cm, No bullets or numbering

Formatted: Not Strikethrough, Not Highlight

**Commented [NS31]:** B&A99, deletion not accepted and comments do not appear clear in its intention. Specifically, the applicant has relied upon such a system to mitigate adverse impacts. The amendments are suggestive of the fact that it might be a nice to have, rather than a mechanism to control the booking of any loading spaces and appropriate management of the service lane and surrounding access points onto the network.

**Commented [NS32]:** B&A100, amendments accepted.

Formatted: Indent: Left: 3.75 cm

**Commented [NS33]:** Deletion not accepted for the reasons stated in the response to B&A98.

Formatted: Indent: Left: 4.5 cm, No bullets or numbering

## DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

include the availability of a concierge service to be made available outside of core hours if the loading dock manager is not available;

c. Provide access cards or other mechanisms to provide regular users the ability to access the loading dock to avoid vehicles from unnecessarily waiting within the service lane;

d. Provide details of the approach to managing the booking of the nine casual car parking spaces, which are to be utilized by the residential and office components;

b. \_\_\_\_\_

e-e. Core hours of 6:30 am to 4:30 pm-, taking into account the requirements of Condition (122)(a)(v) above, where the loading dock will be managed by a Dock Manager;

d-f. Details about signage to show the vertical clearance restrictions;

e-g. Details of a convex mirror to provide visibility for trucks exiting the loading area of the Site, as required by condition 132; and

f-h. Monitoring programme and Management Plan review.

Formatted: Indent: Left: 2.87 cm

Formatted: Indent: Left: 3.5 cm, No bullets or numbering

**Commented [NS34]:** A number of amendments have been made, however no specific commentary that has been provided in relation to the suggested amendments. All of which have already been specifically proposed by the applicant's consultants, as a means of further managing and mitigating effects of the development. Rather than these being as part of the body of the management plan itself, it makes sense in terms of making things abundantly clear to compliance around the fact that these measures are proposed and required to be implemented as part of the SLMP.

123. The development must be operated in accordance with the certified SLMP at all times for the duration of the activities on the Site.

### Hotel Pick Up and Drop Off Management Plan (HPUDOMP)

124. Prior to the commencement of hotel activities on Site, the consent holder must provide a final Hotel Pick Up and Drop Off Management Plan (**HPUDOMP**) to the Council, in general accordance with the draft HPUDOMP referenced in Condition 1.

125. The objectives of the HPUDOMP are:

- a. To provide a clear framework for ongoing management of the hotel pick up and drop off area;
- b. To ensure the hotel pick up and drop off area is used for hotel guests only, or for valet parking;
- c. To prevent vehicle queuing onto Customs Street West, including the potential for queuing across the Customs Street West footpath; ~~and~~
- d. To ensure the drop-off area operates safely; and
- e. To avoid adverse safety and operational effects on the adjacent road network.

126. The HPUDOMP must, as a minimum, include the following information:

## DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

- a. Details about the specific signage or markings required to show that the pick-up and drop-off area is for exclusive use by the hotel guest arrival and departure activity, and that will assist in the general operation of the drop-off area. These details should include:

- (i) Signage stating use for hotel drop-off only
- (ii) Time limit restrictions signage proposed for the use of the drop-off spaces of up to 5 minutes for hotel guests and 3 minutes for taxis or ride-share vehicles
- (iii) Signage stating not to leave vehicles unattended, and for valet parking to give keys to hotel staff members
- (iv) Clearly defining signage or markings for entry and exit points for vehicles
- (v) Vehicle size limitation signage (the maximum vehicle size utilising the drop-off area is a 7.4 m long van with a trailer)
- (vi) Markings/surface treatment defining drop-off spaces and pass-through lane

b. The level of staffing required, including (but not limited to) an identification of the numbers of staff required to maintain the valet parking service; staff to be manage the Hotel PUDO turnover; and staff required to handle any loading / unloading of PUDO vehicles;

b-c. An outline of any programme to train staff employed to maintain the Hotel PUDO and valet service;

e-d. Measures to encourage high turnover of the pick up and drop-off area;

d. Management measures to treat the bypass lane as a managed short term stacking / circulation area only, not as a loading, luggage handling or taxi / rideshare waiting area. This will provide short term capacity if needed, but ensure the bypass lane is not used as a formal loading area;

e. Providing a clearly defined route for vehicles to "circulate around the block";

f. Systems for implementation of booking, where practicable;

g. A larger vehicle protocol, whereby these vehicles should be called forward only when sufficient internal space is available, otherwise they will be directed to the defined recirculation route;

h-g. A clear "no informal drop-off" rule within the road reserve; and

**Commented [NS35]:** A comprehensive memo has been prepared by Mr Peake, dated 8<sup>th</sup> June 2026, which responds to the s55 response provided by Flow and takes into consideration the independent peer review by Hughs Transportation. Principally, there are significant practical implications of allowing the bypass lane to be utilised for extra capacity in terms of the ability for the two formal PUDO spaces to be accessed and to enable adequate exits from the PUDO facility. Implications of using the bypass lane as a short term stacking area is that vehicles would lead to manoeuvre within the space to allow vehicles to enter / exit PUDO spaces, which will have safety implications given the high pedestrian activity in the area both within subject site and along the Customs Street West frontage. Fundamentally, the bypass lane should be retained to maintain the ability to turnover vehicles in a more efficient capacity. Notwithstanding, AT's principle concern is that the physical dimensions of the Hotel PUDO continue to be insufficient based on the demand for such a facility.

**Commented [NS36R35]:** At the meeting held on 9<sup>th</sup> June 2026, the applicant discussed the potential for mitigating legibility concerns of the entry for vehicles approaching from Sturdee Street. Specifically, this included the provision of signage. It was not clear as to whether this was advanced notice or simply at the crossing point. In both instances, there are issues with the implementation of such measures in terms of whether these are effective in allowing motorists sufficient time / visibility to identify the location of the entry point, particularly if they are not regular users or otherwise facility with the Hotel PUDO arrangement. More likely than not the types of users will be casual users. In the existing traffic environment, there is a reasonable degree of visual clutter and is located in a complex lane arrangement which limits the potential effectiveness of signage in this particular location. The only way of addressing this aspect is via revising the location of the access.

**Commented [NS37]:** Supported amendment.

**Commented [NS38]:** Not sure what "Larger vehicle" means, should be more precise as there is a suggestion it could lead to a vehicle larger than a sprinter (i.e. a coach). Where is the vehicle(s) located in the "called forward" situation, i.e. is this located in the basement or any other facility before being redirected towards the site. The applicant has since clarified at the meeting held on 9<sup>th</sup> June 2026 that the "Larger vehicle protocol" was intended to move a larger vehicle from the short-term bypass lane into one of the formal PUDO spaces. However, there is no information provided to understand how this could practically work taking into consideration the concerns raised above in relation to normal vehicles, let alone larger vehicles where the functional requirements for manoeuvre are greater in terms of the amount of space needed to suitably position a larger vehicle into the space given the confined space that is available for manoeuvring. Suggest deletion, noting that the intent was to rely upon the bypass lane to accommodate these larger vehicles.

**Commented [NS39]:** Comfortable with the inclusion, but practically not sure how this is to be regulated particularly noting that the conditions generally relate to any activity located within the subject site.

DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

- i. ~~A specific “all 4 internal positions occupied” procedure; and~~
- h. A monitoring programme and management plan review.
- j. ~~—~~
- 127. The hotel activities must be operated in accordance with the certified HPUDOMP at all times for the duration of the activities on the Site.
- Hotel PUDO Monitoring:**
- 127A. To ensure the effectiveness of the management measures required in the Hotel PUDO Management Plan, as required in Conditions (126) of these consents, the consent holder must undertake monitoring in accordance with the following frequencies:

  - a) Within three months following the operation of the Hotel PUDO and implementation of the Hotel PUDO Management Plan;
  - b) Within six months following the operation of the Hotel PUDO and implementation of the Hotel PUDO Management Plan;
  - c) Within 12 months following the operation of the Hotel PUDO and implementation of the Hotel PUDO Management Plan;
  - d) Annually thereafter the monitoring required in Condition 126(c);
- Hotel PUDO Monitoring Parameters**
- 127B. The monitoring must occur across a week period and include surveys of at least two week days and one weekend day between the hours of 6am – 10pm. This must include an identification of the following:

  - a) Any incidents of queuing across the footpath along Customs Street West or into the road carriageway;
  - b) Instances where, and frequency of, hotel staff having had to send pick up and drop off vehicles away from the PUDO in the scenario where the PUDO was fully occupied;
  - c) Length of time that a vehicle(s) is parked within the PUDO;
  - d) The number and type of vehicles utilising the PUDO across the identified survey period;
  - e) Any instances relating to pickups and drop offs within the road reserve along the Customs Street West and Lower Hobson Street frontages of the subject site;
  - f) Observation of any near misses between pedestrians and vehicles utilising the PUDO;
  - g) Instances of any non-hotel related use of the PUDO, including identification of where staff had to move on any related vehicles;
- Hotel PUDO Monitoring Reporting Requirements**

**Commented [NS40]:** Suggest deleting this, based on the comments above regarding the need to maintain the capacity of the bypass lane.

**Formatted:** AC BodyText Numbers, Left, Indent: Left: 3.25 cm, Right: 0 cm, Space Before: 0 pt, After: 0 pt, Line spacing: single, No bullets or numbering, Tab stops: Not at 1.94 cm + 1.95 cm

**Formatted:** Indent: Left: 1.25 cm

**Commented [NS41]:** AT supports the increased monitoring frequencies identified by Hugh's peer review and what has been proposed by Flow.

**Formatted:** Indent: Left: 2.62 cm, Numbered + Level: 1 + Numbering Style: a, b, c, ... + Start at: 1 + Alignment: Left + Aligned at: 3.63 cm + Indent at: 4.27 cm

**Formatted:** Font: Bold

**Formatted:** Font: Bold

**Formatted:** Indent: Left: 1.27 cm, Hanging: 1.27 cm, No bullets or numbering

**Commented [NS42]:** Not specifically identified as part of the s55 response, however AT considers this necessary to help inform an assessment around the extent to which the demand for the facility is needed. Peer reviewer otherwise didn't disagree with AT's earlier suggestions.

**Formatted:** Font: Bold

**Formatted:** AC BodyText Numbers, Indent: Left: 1.27 cm, Hanging: 1 cm, Space After: 0 pt, Line spacing: single

## DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

127C. The results of any monitoring required in Condition (127B) must be provided to the Council in consultation with Auckland Transport, in writing, and prepared by a suitably qualified and experienced traffic engineer, within one month following the completion of each monitoring period. This must include, but not be limited to, the following matters:

- a) A summary of the survey data undertaken throughout the monitoring period(s);
- b) An assessment of any crashes in the vicinity of the PUDO, against NZTA's Crash Analysis System, including the intersection of Customs Street West / Lower Hobson Street / Sturdee Street to identify any safety issues that relate to the operation of the PUDO;
- c) The extent to which the management measures included within the Hotel PUDO Management Plan have been implemented and effective. This includes the extent to which queuing within Customs Street West, including across the footpath, has been avoided; and
- d) Any recommendations to address any issue(s) identified within the monitoring reporting to address the safety and performance of the adjacent transport network, which may include (but not be limited to) the closure of the Hotel PUDO. These measures must be identified and agreed with Auckland Council, in consultation with Auckland Transport, prior to implementation which must be at the consent holder's expense.

### Hotel PUDO Purpose / Reinstatement

127D. Should the consented use of the hotel activity cease to operate or be converted into any other activity(ies), the consent holder must remove the PUDO and reinstate the vehicle crossings associated with the use of the Hotel PUDO along Customs Street West, as shown in Condition (1) of these consents, in accordance with Auckland Council and/or Auckland Transport's requirements. This must be undertaken within three month period following the cease of operation and/or the change in consented use of the hotel activity.

~~127.~~

### **No complaints Covenant**

128. Prior to the occupation of the proposed hotel rooms and apartments, the consent holder shall provide evidence to Council that a restrictive no-complaints covenant has been registered on the title(s) to the property, in favour of Ports of Auckland Limited, by the landowner (and binding any successors in title).

#### **Advice Note:**

*The applicant has proffered this condition in order to demonstrate intent to comply with standard D25.6.1(6) of the Auckland Unitary Plan.*

### **Landscape Treatment – Implementation**

129. All hard and soft landscaping must be implemented, as detailed on the approved

**Formatted:** Font: Bold

**Formatted:** AC BodyText Numbers, Indent: Left: 1.27 cm, Hanging: 1 cm

**Formatted:** AC BodyText Numbers, Indent: Left: 1.27 cm, Hanging: 1.27 cm, Space After: 0 pt, Add space between paragraphs of the same style, Line spacing: single, No bullets or numbering

**Formatted:** Indent: Left: 1.75 cm, No bullets or numbering

## **DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT**

Landscape Plans required by Condition 47, in the first planting season immediately following the completion of construction works. The landscaping must be maintained for the life of this consent in accordance with the maintenance programme approved under Condition 47 above.

### **Vehicle intervisibility – convex mirror**

130. Prior to the operation of the activity, the consent holder must install a 600mm diameter convex mirror as directed by the consent holder's traffic engineer. This must include (at a minimum) within the service lane opposite the exit of the basement and as required internal to the basement to ensure adequate intervisibility. Any convex mirror(s) installed at the bends must have wide reflective angles to allow opposing vehicles to see each other in advance of the bend.
131. The convex mirror must be maintained in the consented location in a condition that provides for its effective and ongoing use for the duration of the operation of the activity.

### **Small Parking Spaces**

- 131A. The four parking spaces identified in the Operation Integrated Transportation Assessment with non-compliant dimensions must be clearly identified, by way of signage and/or pavement markings, and restricted to use by small vehicles only.

### **Quay Street vehicle crossing treatment**

132. The Quay Street service lane vehicle crossing must be constructed generally in accordance with the updated concept design titled "Quay Street Service Lane Access Design" (refer Appendix H of the Operational Integrated Transport Assessment), which reflects the outcomes of stakeholder engagement with M Social and Auckland Transport.

The design and construction of the vehicle crossing must achieve the following key outcomes:

- a. Clear delineation between vehicle and pedestrian areas.
- b. Improved demarcation between the service lane and the M Social frontage.
- c. Speed management through retention of existing speed humps and provision of appropriate measures near the property boundary.
- d. Physical separation of opposing traffic movements by a 0.5 m median strip (implemented as a textured surface, low raised lip, or planter feature).
- e. Provision of a low (less than 900 mm) separation element at the corner boundary with M Social to maintain visibility between pedestrians and vehicles.

## DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

- f. Provision for bollards within the road reserve, to be installed at Auckland Transport's discretion.
- g. Retention of the existing lighting pole between the M Social and service lane vehicle crossings, with the intervening space functioning as a pedestrian refuge area.

Any detailed design or construction drawings that depart materially from the concept plan in Appendix H must be submitted to and approved in writing by Auckland Transport prior to implementation, to confirm that the above outcomes are maintained.

### **Provision of off-site parking spaces**

133. Prior to the operation of the any activity on the Site a total of up to 121 car parking spaces within the Site must be signposted and marked out as available for the exclusive use of owner / occupier at 196-200 Quay Street [Lot 8 DP 60151]. The location of these leased parking spaces and their availability for the exclusive use of the visitor accommodation activity at 196-200 Quay Street must be identified through suitable signage and on an updated parking plan. Confirmation of the lease, signage and parking plan must be provided to the Council for certification.

#### **Advice note:**

*In the event that the lease of parking spaces is no longer possible, the consent holder should, in consultation with the owner/occupier of 196-200 Quay Street arrange for an alternative lease location in order to comply with this condition.*

### **Noise Assessment Report**

134. Prior to occupation of the building, a noise assessment report with measurement results prepared by a SQEP must be submitted to the Council to demonstrate that the building has been insulated and constructed to comply with Condition 75.

### **Hazardous Substance**

135. Prior to operation of the activity, the consent holder must produce a statement letter confirming the following design (as specified in the approved Hazardous Substances Assessment prepared by Tonkin + Taylor, reference 1016043.2000 v1, and dated November 2025 and as listed in condition 1) has been incorporated:

*"The minimum 4-hour fire rating wall for each of the proposed hazardous substance storage tanks and thick concrete construction material surrounding the tanks"*

#### **Advice Note:**

*This is required to ensure that the fire risk to people and property remains consistent with the assessment within the Hazardous Substances Assessment Report (as referenced in*

## DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

*condition 1).*

- 136. The site operation must adhere to the operational procedures, control measures and response procedures specified in the certified HSMP as per Condition 109 and the documents must be made available onsite at all times.
- 137. Suitable and sufficient spill kits must be maintained onsite at all times.
- 138. Any incidents resulting in a discharge of hazardous substances to the environment must be reported to the Council within 24 hours of an incident occurring and incident records must be made available to the Council upon request.

### **Operational Waste Management Plan**

- 139. The development must be operated in accordance with the certified Operational Waste Management Plan at all times for the duration of the activities on the Site.

### **Heritage Interpretation Panel**

- 139A Prior to occupation of the building, the consent holder must install one heritage interpretation panel in a location visible from street or ground level within the site. The consent holder must work with the project archaeologist to determine the content and location of a public interpretation panel on the historic heritage features of the site.

### **Active Surveillance Plan**

- 139B Prior to occupation of the building, the consent holder shall provide details of the building operation, confirming:
  - a. Hours of operation for all publicly accessible spaces;
  - b. Security measures/monitoring of the above spaces, as well as spaces able to be accessed by the public; and
  - c. Details of retractable security screens or other security measures.

## **Specific conditions – Discharge Permit DISxxxx and Land Use Consent (NESCS) LUCxxxx**

- 140. Soil disturbance on the Site must be undertaken in accordance with the certified CSMP as required by Condition 42.

### **Advice note: Contamination Site Management Plan**

*The Council acknowledges that the CSMP is intended to provide flexibility of the management of the works and contaminant discharges. Accordingly, the plan may need to be updated following the results of the additional soil sampling. Any updates should be limited to the scope of this consent and be consistent with the conditions of this consent. If you would like to confirm that any proposed updates are within scope, please*

## DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

*contact the Council. The Council's certification of the CSMP relates only to those aspects of the plans that are relevant under the RMA. The certification does not amount to an approval or acceptance of the suitability by the Council of any elements of the management plan that relate to other legislation, for example, the Building Act 2004 or the Health and Safety at Work Act 2015.*

141. At least 20 working days prior to soil disturbance occurring on the Site, a Detailed Site Investigation (DSI) must be undertaken on the Site. The DSI must be undertaken in accordance with the certified CSMP, referenced in Condition 42.
142. The DSI report documenting the site investigation, required by Condition 141, must be submitted to the Council for review at least 10 working days prior to soil disturbance occurring. The DSI report must confirm whether the stormwater quality monitoring and management/mitigation measures, proposed in the CSMP, referenced in Condition 42, are appropriate for the level of contamination onsite.
143. If the DSI report required by Condition 141 confirms additional stormwater quality monitoring, including analysis for cyanide and/or mitigation/measures are required during soil disturbance on the Site, then the consent holder must submit to the Council an updated CSMP for certification at least 10 working days prior to soil disturbance occurring onsite.
144. The Council must be informed, in writing, at least 10 working days prior to the start date of the works authorised by this consent.
145. The consent holder must engage a SQEP to oversee any works involving the disturbance of potentially contaminated material and ensure the control measures in the certified CSMP are adhered to throughout these works. All sampling should be undertaken in accordance with the Contaminated Land Management Guidelines No. 5, Ministry for the Environment (revised 2021).

### **Advice note: Soil Contamination Sampling**

*In order to comply with the Contaminated Land Management Guidelines No. 5 (Ministry for the Environment, revised 2021), all sample analysis should be undertaken in a laboratory with suitable experience and ability to carry out the analysis.*

146. During earthworks all necessary action must be taken to prevent dust generation and sufficient water must be available to dampen exposed soil, and/or other dust suppressing measures must be available to avoid dust formation. Excavation works must be undertaken in general accordance with the Good Practice Guide for Assessing and Managing Dust (Ministry for the Environment, 2016).
147. In the event of an incidental discovery of contamination during land disturbance activity

## DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

which has not been previously identified, including asbestos material, the consent holder must immediately cease the works in the vicinity of the contamination, notify the Council, engage a SQEP to assess the situation (including possible sampling and revision of the CSMP), and decide on the best option for managing the material.

148. Excavated material that is not re-used onsite must be disposed of at an appropriate facility licensed to accept the levels of any identified contamination. Excavated soil must not be disposed of as 'Cleanfill material' unless it has been appropriately tested and characterised by a SQEP as meeting the 'Cleanfill material' definition set out in the AUP(OP) and any subsequent updates.
149. The contamination levels of any soil or fill material imported to the site must be certified by a SQEP and, unless otherwise agreed with Council, must meet the definition of 'Cleanfill material', as defined by the AUP(OP) and any subsequent updates. The SQEP's certification must include testing of imported soil at a minimum rate of 1 sample per 500m<sup>3</sup> (analysed for heavy metals, polycyclic aromatic hydrocarbons, total petroleum hydrocarbons, and asbestos content) and verification that the fill material imported to site originates from:
  - a. A site that has been determined by a SQEP to have had no known history of potentially contaminating activities, as detailed on the Hazardous Activities and Industries List (Ministry for the Environment, 2011); or
  - b. A site that has been adequately investigated by a SQEP, in accordance with Contaminated Land Management Guidelines, No.5: Site Investigation and Analysis of Soils (Ministry for the Environment, revised 2021) or any updates to this document, to meet the 'Cleanfill material' definition, as prescribed in the AUP(OP); or
  - c. A commercial quarry (sampling is not required for hardfill material sourced from a commercial quarry) or topsoil from a landscape supplier.
150. Within three months of the completion of soil disturbance on the site, a Works Completion Report must be submitted to the Council for review and certification. The Works Completion Report must contain sufficient detail to address the following matters:
  - a. A summary of the soil disturbance undertaken, including the location and dimensions of the excavations carried out and the volume of soil excavated;
  - b. Details and results of any additional soil and groundwater sampling (if undertaken) and interpretation of the results in the context of the NES:CS, the AUP(OP), and the Cleanfill criteria;
  - c. Details and results of the stormwater quality monitoring and interpretation of the results against the Australian and New Zealand Environment

## DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

Conservation Council (ANZECC) Guidelines for Fresh and Marine Water Quality (2000);

- d. Details and results of any vapour monitoring (if undertaken) and interpretation of the results against the appropriate guidelines;
- e. Records/evidence of the appropriate disposal for any material removed from the Site;
- f. Details of any validation sampling undertaken on materials imported to site;
- g. Details of any stormwater/groundwater encountered during the works, details on any treatment and volume of disposal offsite;
- h. Records of any unexpected contamination encountered during the works and response actions, if applicable;
- i. Conditions of the final site ground surface;
- j. Reports of any complaints, health and safety incidents related to contamination, and/or contingency events during the earthworks; and
- k. A statement certifying that all works have been carried out in accordance with the requirements of approved plans and consent conditions, otherwise providing details of relevant breaches, if applicable;

### **Advice note: Asbestos Containing Materials**

*If you are demolishing any building that may have asbestos containing materials (ACM) in it:*

- *You have obligations under the relevant regulations for the management and removal of asbestos, including the need to engage a Competent Asbestos Surveyor to confirm the presence or absence of any ACM.*
- *Work may have to be carried out under the control of person holding a WorkSafe NZ Certificate of Competence (CoC) for restricted works.*
- *If any ACM is found, removal or demolition will have to meet the Health and Safety at Work (Asbestos) Regulations 2016.*
- *Information on asbestos containing materials and your obligations can be found at [www.worksafe.govt.nz](http://www.worksafe.govt.nz).*

*If ACM is found onsite following the demolition or removal of the existing buildings, you may be required to further remediate the site and carry out validation sampling. Dependent on the amount of soil disturbance, a further consent application may be required.*

### **Specific conditions – Discharge Permit DISXXXX**

#### **Duration of consent**

## DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

151. Consent DISXXXX expires five years from the date of commencement unless it has been surrendered or been cancelled at an earlier date pursuant to the RMA.

### During Works Conditions

#### Management of contaminant discharges

152. The disturbance of soils containing elevated levels of contaminants must be managed in accordance with the certified CSMP to minimise the discharge of contaminants (including debris, soil, silt, sediment, or sediment-laden water) from the Site to either land, stormwater drainage systems, watercourses or receiving waters:
- a. Erosion and sediment controls must be installed along the boundaries of the disturbance areas in accordance with the CSMP and Auckland Council guidance document 2016/005: Erosion and Sediment Control Guide for Land Disturbing Activities in the Auckland Region;
  - b. The excavation areas must be maintained in a damp state while works are occurring to suppress the generation of dust during the works;
  - c. Filter cloths or cover mats must be installed over the stormwater cesspits in the vicinity of the excavation areas;
  - d. Vehicles must be inspected prior to leaving the works area and wheels brushed/cleaned as required to avoid the potential for sediment to leave the Site on vehicle tyres and enter the stormwater system; and
  - e. Any truck-loads of excess excavated material leaving the Site must be covered during transportation.

#### **Advice note: Contaminant Discharges**

*Discharge from the Site includes the disposal of water (including groundwater or collected surface water) from the land-disturbance area.*

153. Temporary stockpiles of excavated soils containing elevated levels of contaminants must be located within an area protected by erosion and sediment controls and be covered outside working hours and during periods of heavy rain. Stockpiling of material containing separate phase hydrocarbons or odorous petroleum hydrocarbons must not take place.

#### **Advice note: Stockpiles**

*Stockpiling of excavated soils containing elevated levels of contaminants is to be minimised. To minimise contaminant discharges, soils containing elevated levels of contaminants should primarily be loaded directly into trucks for any off-site disposal.*

## DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

154. Any perched groundwater or surface run-off water encountered within excavation areas where soils containing elevated levels of soil contaminants are present that require removal must be considered potentially contaminated, and must either be:
- a. Allowed to soak into the ground; or
  - b. Pumped to sewer, providing the relevant permits are obtained; or
  - c. Discharged to the stormwater system or to the marine water environment provided testing demonstrates compliance with the Australian and New Zealand Guidelines for Fresh and Marine Water Quality (Water Quality Policy Sub-Committee and National Water Reform Committee, 2018) (or any updates to this document) for the protection of 80 percent of marine water species, with the exception of benzene where the 95 percent protection level must apply, and that it is free from petroleum hydrocarbon sheen and separate phase hydrocarbons.

**Advice note:**

*If any contamination exceeding the Permitted Activity soil acceptance criteria, set out in Chapter E30 of the AUP(OP), is retained within the Site upon the completion of the proposed land-disturbance activity, a long-term contaminant discharge consent under Chapter E30 of the AUP(OP) may be required for the Site.*

## DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

### Specific conditions – Water Permit WATxxxx – Ground Dewatering and Groundwater Diversion Consent Conditions

#### Definitions

Words in the ground dewatering (take) and groundwater diversion consent conditions have specific meanings as outlined in the table below.

|                                               |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                  |
|-----------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Alarm Level                                   | Specific levels at which actions are required as described in the relevant conditions.                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                           |
| Alert Level                                   | Specific levels at which actions are required as described in the relevant conditions.                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                           |
| Bulk Excavation                               | Includes all excavation that affects groundwater excluding minor enabling works and piling less than 1.5 m in diameter.                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                          |
| Commencement of Construction Phase Dewatering | Means commencement of Bulk Excavation and/or the commencement of the taking or diversion of groundwater, other than for initial state monitoring purposes.                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                       |
| Completion of Construction Phase Dewatering   | <p>Means, in the case of a tanked building or structure construction, the stage when all the external base slab and walls within an excavation are essentially watertight, the structures internal support mechanisms, including basement floors have been completed any temporary retention removed and no further groundwater is being taken for the construction of the basement.</p> <p>Or</p> <p>Means, in the case of a drained building or structure, the stage the structures external and internal support mechanisms, including basement floors have been completed, the permanent drainage system(s) are in place and no further groundwater is being taken for the construction of the basement.</p> |
| Commencement of Excavation                    | Means commencement of Bulk Excavation or excavation to create perimeter walls.                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                   |
| Completion of Construction                    | Means when the Code Compliance Certificate (CCC) is issued by Auckland Council                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                   |
| Completion of Excavation                      | Means the stage when all Bulk Excavation has been completed and all foundation/footing excavations within 10 metres of the perimeter retaining wall have been completed.                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                         |
| Condition Survey                              | Means an external visual inspection or a detailed condition survey (as defined in the relevant conditions).                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                      |
| Damage                                        | Includes Aesthetic, Serviceability, Stability, but does not include Negligible Damage. Damage as described in the table below.                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                   |

## DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

|                                |                                                                                                                                                                                                                                                                                                                                                                                                 |
|--------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| External visual inspection     | A condition survey undertaken for the purpose of detecting any ground instability, new external Damage or deterioration of existing external Damage. Includes as a minimum a visual inspection of the ground surrounding a building or excavation or the exterior of a building; and may include a dated photographic record of all observable changes to ground conditions or exterior Damage. |
| GSMCP                          | Means Groundwater and Settlement Monitoring and Contingency Plan                                                                                                                                                                                                                                                                                                                                |
| Monitoring Station             | Means any monitoring instrument including a ground or building deformation station, inclinometer, groundwater monitoring bore, retaining wall deflection station, or other monitoring device required by this consent.                                                                                                                                                                          |
| RL                             | Means Reduced Level.                                                                                                                                                                                                                                                                                                                                                                            |
| Seasonal Low Groundwater Level | Means the annual lowest groundwater level – which typically occurs in summer.                                                                                                                                                                                                                                                                                                                   |
| Services                       | Include fibre optic cables, sanitary drainage, stormwater drainage, gas and water mains, power and telephone installations and infrastructure, road infrastructure assets such as footpaths, kerbs, catch-pits, pavements and street furniture.                                                                                                                                                 |
| SQEP                           | Means Suitably Qualified Engineering Professional                                                                                                                                                                                                                                                                                                                                               |
| SQBS                           | Means Suitably Qualified Building Surveyor                                                                                                                                                                                                                                                                                                                                                      |

## DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

| Category of Damage | Normal Degree of Severity | Description of Typical Damage<br><i>(Building Damage Classification after Burland (1995), and Mair et al (1996))</i>                                                                                                                                                                                                                                                   | General Category<br><i>(after Burland – 1995)</i> |
|--------------------|---------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------|
| 0                  | Negligible                | Hairline cracks.                                                                                                                                                                                                                                                                                                                                                       | <b>Aesthetic Damage</b>                           |
| 1                  | Very Slight               | Fine cracks easily treated during normal redecoration. Perhaps isolated slight fracture in building. Cracks in exterior visible upon close inspection. Typical crack widths up to 1mm.                                                                                                                                                                                 |                                                   |
| 2                  | Slight                    | Cracks easily filled. Redecoration probably required. Several slight fractures inside building. Exterior cracks visible, some repainting may be required for weather-tightness. Doors and windows may stick slightly.<br><br>Typically crack widths up to 5mm.                                                                                                         |                                                   |
| 3                  | Moderate                  | Cracks may require cutting out and patching. Recurrent cracks can be masked by suitable linings. Brick pointing and possible replacement of a small amount of exterior brickwork may be required. Doors and windows sticking. Utility services may be interrupted. Weather tightness often impaired. Typical crack widths are 5mm to 15mm or several greater than 3mm. | <b>Serviceability Damage</b>                      |
| 4                  | Severe                    | Extensive repair involving removal and replacement of walls especially over door and windows required. Window and door frames distorted. Floor slopes noticeably. Walls lean or bulge noticeably. Some loss of bearing in beams. Utility services disrupted. Typical crack widths are 15mm to 25mm but also depend on the number of                                    |                                                   |

## DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

|   |             |                                                                                                                                                                                                                                                                   |                         |
|---|-------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------|
|   |             | cracks.                                                                                                                                                                                                                                                           |                         |
| 5 | Very Severe | Major repair required involving partial or complete reconstruction. Beams lose bearing, walls lean badly and require shoring. Windows broken by distortion. Danger of instability. Typical crack widths are greater than 25mm but depend on the number of cracks. | <b>Stability Damage</b> |

Table 1: Building Damage Classification

Note: In the table above the column headed "Description of Typical Damage" applies to masonry buildings only and the column headed "General Category" applies to all buildings.

### Duration of consent

155. The take (dewatering) and groundwater diversion consent WAT~~xxx~~60460867 expires thirty-five (35) years after it has been granted unless it has lapsed, been surrendered or been cancelled at an earlier date pursuant to the RMA.

### Provide for a review under section 128

156. Under section 128 of the RMA the conditions of this consent WAT6043057460460867 may be reviewed by the Manager Resource Consents (or equivalent delegation) at the consent holder's cost:

Within six months after Completion of Dewatering and subsequently at intervals of not less than five years thereafter in order:

- To deal with any adverse effects on the environment which may arise or potentially arise from the exercise of this consent and which it is appropriate to deal with at a later stage
- To vary the monitoring and reporting requirements, and performance standards, in order to take account of information, including the results of previous monitoring and changed environmental knowledge on:
  - a. ground conditions
  - b. aquifer parameters
  - c. groundwater levels; and
  - d. ground surface movement.

DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

Notice of Commencement of Dewatering

157. The Council must be advised in writing at least 10 working days prior to the date of the Commencement of Dewatering.

Design and Construction of Basement Retaining Walls

158. The design and construction of the basement retaining walls must be undertaken in accordance with the specifications contained in the following report:
- Downtown Carpark Development - Geotechnical and Groundwater Assessment Report”, prepared by Tonkin & Taylor (T + T), dated November 2025, ref. 1016043.2000 v3.

Excavation Limit

159. The bulk excavation for the basement must not extend below a bulk excavation level at RL -12.4m. This allows for construction of the lower basement level (B04) founded at RL -10.32m as defined by the architectural drawings listed in Condition 1, plus allowance for nominal over dig and construction of the slab, basecourse and any subsoil drainage below the basement. This excludes any local excavations away from the basement perimeter for minor structures, such as lift pit shafts, sumps or water tanks etc., which should not extend below RL 17.2m.

Performance Standards

Damage Avoidance

160. All excavation, dewatering systems, retaining structures, basements and works associated with the diversion or taking of groundwater, must be designed, constructed and maintained so as to avoid Damage to buildings, structures and Services on the Site or adjacent properties, outside that considered as part of the application process unless otherwise agreed in writing with the asset owner.

Alert and Alarm Levels

161. The activity must not cause any settlement or movement greater than the Alarm Level thresholds specified in Schedule A below. Alert and Alarm Levels are triggered when the following Alert and Alarm Trigger thresholds are exceeded:

| Schedule A: Alarm and Alert Levels |                                                                                                                       |                          |       |
|------------------------------------|-----------------------------------------------------------------------------------------------------------------------|--------------------------|-------|
| Movement                           |                                                                                                                       | Trigger Thresholds (+/-) |       |
|                                    |                                                                                                                       | Alarm                    | Alert |
| a)                                 | Differential vertical settlement between any two Ground Surface Deformation Stations (the Differential Ground Surface | 1:250                    | 1:500 |

## DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

|    | Settlement Alarm or Alert Level)                                                                                                                                                                                                                                                                                                                                                                                                                                                      |                                     |                                    |
|----|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------|------------------------------------|
| b) | <p>Total vertical settlement from the pre-excavation baseline level at any Ground Surface Deformation Station (the <b>Total Ground Surface Settlement Alarm or Alert Level</b>):</p> <ul style="list-style-type: none"> <li>Along Custom Street West and Service Lane between the excavation and AON/ HSBC podiums and towers</li> <li>Along Lower Hobson Street and private accessway between the Site and M Social</li> </ul>                                                       | <p>12mm</p> <p>18mm</p>             | <p>9mm</p> <p>15mm</p>             |
| c) | Differential vertical settlement between any two adjacent Building Deformation Stations (the <b>Differential Building Settlement Alarm or Alert Level</b> )                                                                                                                                                                                                                                                                                                                           | 1:750                               | 1:1,000                            |
| d) | <p>Total vertical settlement from the pre-excavation baseline level at any Building Deformation Station (the <b>Total Building Settlement Alarm or Alert Level</b>):</p> <ul style="list-style-type: none"> <li>M Social, HSBC Tower, AON Tower <del>&amp; Hobson Street Flyover</del></li> <li>Hobson Street Flyover</li> <li>204 Quay Street, Tepid Baths, 85 Customs Street West (The Sebel)</li> </ul>                                                                            | <p>12mm</p> <p>14mm</p> <p>10mm</p> | <p>8mm</p> <p>11mm</p> <p>7mm</p>  |
| e) | <p>Total lateral deflection from the pre-excavation baseline level at any retaining wall deflection station (the <b>Retaining Wall Deflection Alarm or Alert Level</b>):</p> <ul style="list-style-type: none"> <li>Top of Wall Along Northern <del>&amp; Southern</del> Boundary (Design Section 1)</li> <li>Top of Wall Along Western Boundary (Design Section 2)</li> <li>Top of Wall Along <del>Western</del> Southern &amp; South-Eastern Boundary (Design Section 3)</li> </ul> | <p>10mm</p> <p>25mm</p> <p>16mm</p> | <p>8mm</p> <p>20mm</p> <p>13mm</p> |
| f) | <p>Total lateral wall deflection from the pre-excavation baseline level and any subsequent reading at any Inclinator (the <b>Inclinator Deformation Alarm or Alert Level</b>):</p> <ul style="list-style-type: none"> <li>I01 to I034</li> </ul>                                                                                                                                                                                                                                      | 20mm                                | 18mm                               |
| g) | <p>Distance below the lowest baseline level (the <b>Groundwater Alert Levels 1 &amp; 2</b>):</p> <ul style="list-style-type: none"> <li>MW01 to MW04</li> </ul>                                                                                                                                                                                                                                                                                                                       |                                     | <p>(1) 0.7m</p> <p>(2) 1.0m</p>    |

## DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

### **Advice note:**

*The proposed locations of the Monitoring Stations listed in Schedule A are shown on the plan titled "Downtown Car Park Redevelopment - Construction Monitoring and Instrumentation Plan", prepared by T + T, Figure 1, rev. 2, dated 2 May 2026.*

*These levels may be amended subject to approval by the council as part of the Groundwater Settlement Monitoring and Contingency Plan (GSMCP) certification process, and, after the receipt of pre-dewatering monitoring data, building condition surveys and recommendations from a SQEP, but only to the extent that avoidance of damage to building, structures and Services can still be achieved.*

### **Advice Note:**

*There are conditions below that must be complied with when the Alert and Alarm Level triggers are exceeded. These include actions that must be taken immediately including seeking the advice of a SQEP.*

### **Alert Level Actions**

162. In the event of any Alert Level in Schedule A being exceeded the consent holder must:
- a. Notify the Council within 24 hours.
  - b. Re-measure all Monitoring Stations within 20 metres of the affected monitoring location(s) to confirm the extent of apparent movement.
  - c. Ensure the data is reviewed, and advice provided, by a SQEP on the need for mitigation measures or other actions necessary to avoid further deformation. Where mitigation measures or other actions are recommended those measures must be implemented.
  - d. Submit a written report, prepared by the SQEP responsible for overseeing the monitoring, to the Council within 5 working days of Alert Level exceedance. The report must provide an analysis of all monitoring data (including wall deflection) relating to the exceedance, actions taken to date to address the issue, recommendations for additional monitoring (i.e., the need for increased frequency or repeat condition survey(s) of building or structures) and recommendations for future remedial actions necessary to prevent Alarm Levels being exceeded.
  - e. Measure and record all Monitoring Stations within 20 metres of the location of any Alert Level exceedance every two days until such time the written report referred to above has been submitted to the Council.

## **DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT**

### **Alarm Level Actions**

163. In the event of any Alarm Level being exceeded, the consent holder must:
- a. Immediately halt construction activity, including excavation, dewatering or any other works that may result in increased deformation, unless halting the activity is considered by a SQEP to be likely to be more harmful (in terms of effects on the environment) than continuing to carry out the activity.
  - b. Notify the council within 24 hours of the Alarm Level exceedance being detected and provide details of the measurements taken.
  - c. Re-measure all Monitoring Stations within 20 metres of the affected monitoring location(s) to confirm the extent of apparent movement.
  - d. Undertake a condition survey (this could comprise either a detailed condition survey or an external visual inspection at the discretion of the SQEP responsible for overseeing the monitoring) by a SQEP or suitably qualified building surveyor (SQBS) of any building or structure located adjacent to any Monitoring Station where the Alarm Level has been exceeded.
  - e. Take advice from the author of the Alert Level exceedance report (if there was one) on actions required to avoid, remedy or mitigate adverse effects on ground, buildings or structures that may occur as a result of the exceedance.
  - f. Not resume construction activities (or any associated activities), halted in accordance with paragraph (a) above, until any mitigation measures (recommended in accordance with paragraphs (d) above) have been implemented to the satisfaction of a SQEP.
  - g. Submit a written report, prepared by the SQEP responsible for overseeing the monitoring, to the Council, on the results of the condition survey(s), the mitigation measures implemented and any remedial works and/or agreements with affected parties within 5 working days of recommencement of works.

### **Groundwater and Settlement Monitoring and Contingency Plan (GSMCP)**

164. At least 20 days prior to the Commencement of Dewatering, a Groundwater and Settlement Monitoring and Contingency Plan (GSMCP) prepared by a SQEP, must be submitted to the Council for written certification. Any later proposed amendment of the GSMCP must also be submitted to the Council for written certification.

The overall objective of the GSMCP is to set out project controls to measure groundwater drawdown and ground settlements, and to address potential geotechnical effects related to the construction works and must include, at a minimum, the following information:

## **DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT**

- a. A monitoring location plan, showing the location and type of all Monitoring Stations, including ground and building deformation pins, retaining wall deflection markers and inclinometers and groundwater monitoring boreholes. The monitoring plan must be based on the plan titled "Downtown Car Park Redevelopment - Construction Monitoring and Instrumentation Plan", prepared by T + T, Figure 1, rev. **2, dated 2 May 2026**. In any case where the location of a Monitoring Station differs substantively from that shown on the plan titled "Downtown Car Park Redevelopment - Construction Monitoring and Instrumentation Plan", prepared by T + T, Figure 1, rev. **2, dated 2 May 2026**, a written explanation for the difference must be provided at the same time that the GSMCP is provided.
  - b. Final completed schedules B to D (as per the conditions below) for monitoring of ground surface, building deformation and retaining wall deflection (including any proposed changes to the monitoring frequency) as required by conditions below.
  - c. All monitoring data, the identification of Services susceptible to Damage and all building/Service condition surveys undertaken to date and required by conditions below.
  - d. A bar chart or a schedule, showing the timing and frequency of condition surveys, visual inspections and all other monitoring required by this consent, and a sample report template for the required two monthly monitoring.
  - e. All Alert and Alarm Level Triggers (including reasons if changes to such are proposed, for example as a result of recommendations in the building condition surveys or data obtained from pre-dewatering monitoring).
  - f. Details of the contingency actions to be implemented if Alert or Alarm Levels are exceeded.
165. All construction, dewatering, monitoring and contingency actions must be carried out in accordance with the approved GSMCP. No Bulk Excavation (that may affect groundwater levels) or other dewatering activities must commence until the GSMCP is certified in writing by the council.

### **Pre-Dewatering Building and Structure Survey**

166. Prior to the Commencement of Dewatering a detailed condition survey of buildings and structures as specified in Schedule B below must be undertaken by a SQEP or SQBS and a written report must be prepared and reviewed by the SQEP responsible for overseeing the monitoring. The report must be submitted for certification by the Council. The consent holder must allow a minimum of ten (10) working days for a response from

## DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

the owner of any property that a condition survey is required for as set out in the GSMCP.

This condition does not apply where written evidence is provided to the Council that the owner of a property has confirmed they do not require a detailed condition survey.

The detailed condition survey must include:

- a. Confirmation of the installation of building deformation stations as required in Schedule B in the locations shown on the drawing titled "Downtown Car Park Downtown Car Park Redevelopment - Construction Monitoring and Instrumentation Plan", prepared by T + T, Figure 1, rev. 42, dated ~~31 May 2023~~ 2 May 2026.
- b. A description of the type of foundations.
- c. A description of existing levels of Damage considered to be of an aesthetic or superficial nature.
- d. A description of existing levels of Damage considered to affect the serviceability of the building where visually apparent, without recourse to intrusive or destructive investigation.
- e. An assessment as to whether existing Damage may or may not be associated with actual structural Damage and an assessment of the susceptibility of buildings/structures to further movement and Damage.
- f. Photographic evidence of existing observable Damage.
- g. A review of proposed Alarm and Alert Levels to confirm they are appropriately set and confirmation that any ground settlement less than the Alarm Level will not cause Damage.
- h. An assessment of whether the monitoring frequency is appropriate.
- i. An assessment of whether the locations and density of existing building deformation stations are adequate and appropriate for the effective detection of change to building and structure condition.

## DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

| Schedule B: Buildings/Structures that Require Detailed Condition Survey and Installation of Deformation Stations |                                     |                             |                                                            |
|------------------------------------------------------------------------------------------------------------------|-------------------------------------|-----------------------------|------------------------------------------------------------|
| Address                                                                                                          | Legal Description                   | Detailed Condition Survey   | Number of building/structure deformation stations required |
| 196 Quay Street<br>(M Social hotel)                                                                              | Lot 8 DP60151                       | Yes (External and Internal) | 6No.                                                       |
| 188 Quay Street<br>(HSBC Tower)                                                                                  | Lot 5 DP 63972 and<br>Lot 1 DP 7834 | Yes (External and Internal) | 6No.                                                       |
| 21/29 Customs<br>St West<br>( AON Tower)                                                                         | Lot 7 DP 77037                      | Yes (External and Internal) | 7No.                                                       |
| 100 Customs St<br>West<br>(Tepid Baths)                                                                          | Lot 2 DP 184176                     | Yes (External and Internal) | 2No.                                                       |
| 85 Customs St<br>West<br><br>(The Sebel,<br>previously named<br>The Watermark<br>Building)                       | Lot 2 DP 197735                     | Yes (External only )        | 3No.                                                       |
| 204 Quay Street                                                                                                  | Lot 1 DP 183125                     | Yes (External only )        | None                                                       |
| Lower Hobson<br>Street – Flyover                                                                                 | N/A                                 | Yes                         | 7No.                                                       |

Note: For the internal building survey, the survey must cover the basement levels and the ground floor.

**Advice Note:**

- *This condition does not apply where written evidence is provided to the Council that the owner of a property has confirmed they do not require a detailed condition survey.*

## DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

### **Pre-Dewatering Services Condition Survey**

167. Prior to the Commencement of Dewatering, a condition survey of potentially affected stormwater and wastewater Services must be undertaken in consultation with the relevant service provider.

#### **Advice note:**

*This condition does not apply to any service where written evidence is provided to the council that the owner of that service has confirmed they do not require a condition survey.*

### **External Visual Inspections during Dewatering**

168. External visual inspections of the surrounding ground and neighbouring buildings and structures must be undertaken for the purpose of detecting any new external Damage or deterioration of existing external Damage. Inspections must be carried weekly from the Commencement to Completion of Dewatering. A photographic record must be kept, including time and date, of each inspection and all observations made during the inspection, and must be of a quality that is fit for purpose.

The results of the external visual inspections and an assessment of the results must be reviewed by the SQEP responsible for overseeing the monitoring and included in the bimonthly monitoring report for the relevant monitoring period.

This condition does not apply to any land, building or structure where written evidence is provided to the Council confirming that the owner of the land, building or structure does not require visual inspections to be carried out.

### **Completion of Dewatering - Building, Structure and Services Condition Surveys**

169. Between six and twelve months after Completion of Dewatering, a detailed condition survey of all previously surveyed buildings, structures, and Services, must be undertaken by a SQEP or SQBS and a written report must be prepared. The report must be reviewed by the SQEP responsible for overseeing the monitoring and then submitted to the Council, within one month of completion of the survey.

The condition survey report must make specific comment on those matters identified in the pre-dewatering condition survey. It must also identify any new Damage that has occurred since the pre-dewatering condition survey was undertaken and provide an assessment of the likely cause of any such Damage.

This condition does not apply to any building, structure or Service where written evidence is provided to the Council confirming that the owner of that building, structure, or Service does not require a condition survey to be undertaken.

## DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

### Additional Surveys

170. Additional condition surveys of any building, structure, or Service within the area defined by the extent of groundwater drawdown or ground movement (as defined in the T+T geotechnical reports referenced in Condition 1), must be undertaken, if requested by the Council, for the purpose of investigating any new Damage potentially caused by ground movement resulting from dewatering or retaining wall deflection. A written report of the results of the survey must be prepared and/or reviewed by the SQEP responsible for overseeing the monitoring. The report must be submitted to the Council.

The requirement for any such additional condition survey will cease six months after the Completion of Dewatering unless ground settlement or building deformation monitoring indicates movement is still occurring at a level that may result in Damage to buildings, structures, or Services. In such circumstances the period where additional condition surveys may be required will be extended until monitoring shows that movement has stabilised and the risk of Damage to buildings, structures and Services as a result of the dewatering is no longer present.

### Groundwater Monitoring

171. Groundwater monitoring must be undertaken at the groundwater monitoring bore location shown on the plan titled "Downtown Car Park Redevelopment - Construction Monitoring and Instrumentation Plan", prepared by T + T, Figure 1, rev. 42, dated 2 May 2026, or in the approved GSMCP. Groundwater level monitoring must be undertaken in accordance with Schedule C below:

**Schedule C: Groundwater Monitoring Frequency**

| Bore Name                         | Location | Groundwater level monitoring frequency                                   |                                                                                            |                                                                       |
|-----------------------------------|----------|--------------------------------------------------------------------------|--------------------------------------------------------------------------------------------|-----------------------------------------------------------------------|
|                                   |          | From bore construction until one month before Commencement of Excavation | One month before Commencement of Excavation to Completion of Construction Phase Dewatering | From Completion of Construction Phase Dewatering until 3 months later |
| MW01 to MW04<br>Groundwater level |          | Monthly (with a minimum of three monthly readings)                       | Weekly                                                                                     | Monthly                                                               |

## DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

|                         |  |  |  |  |
|-------------------------|--|--|--|--|
| accuracy of<br>+/-10 mm |  |  |  |  |
|-------------------------|--|--|--|--|

**Advice note:**

*The monitoring frequency may be changed, if approved by the Council.*

### Ground Surface and Building Deformation Monitoring

172. Ground Surface and Building Deformation Monitoring Stations must be established and maintained at the approximate locations shown on the plan titled Downtown Car Park Redevelopment - Construction Monitoring and Instrumentation Plan", prepared by T + T, Figure 1, rev. 2, dated 2 May 2026. The Monitoring Stations must be monitored at the frequency set out in Schedule D. The purpose of the Monitoring Stations is to record any vertical or horizontal movement. Benchmark positions must be established no less than 20 metres away from the excavated area.

| Schedule D: Ground Surface and Building / Structure Monitoring |                                                                                        |                                                             |                                                   |
|----------------------------------------------------------------|----------------------------------------------------------------------------------------|-------------------------------------------------------------|---------------------------------------------------|
| Monitoring Station and type*                                   | Frequency                                                                              |                                                             |                                                   |
|                                                                | Pre-Excavation                                                                         | Commencement to Completion of Construction Phase Dewatering | Post- Completion of Construction Phase Dewatering |
| Ground: 22 Points                                              | Twice to a horizontal and vertical accuracy of +/- 2mm (achieved by precise levelling) | Weekly                                                      | Monthly for 6 months                              |
| Buildings/ Structures : 31 Points                              | Twice to a horizontal and vertical accuracy of +/- 2mm (achieved by precise levelling) | Weekly                                                      | Monthly for 6 months                              |

**Advice note:**

*The monitoring frequency may be changed, if approved by the council.*

### Retaining Wall Monitoring

173. Twenty three retaining wall deflection stations, for the measurement of lateral wall movement, must be installed along the top of the retaining walls, and ~~three~~ four inclinometers (I01 to

## DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

1034) for the measurement of lateral displacement, must be installed either within a retaining pile or immediately behind one and extending to the base of the retaining pile, as shown on the plan titled "Downtown Car Park Redevelopment - Construction Monitoring and Instrumentation Plan", prepared by T + T, Figure 1, rev. 2, dated 2 May 2026. Monitoring of the retaining wall deflection stations and inclinometers must be undertaken and recorded in accordance with Schedule E below and must be carried out using precise levelling.

| Schedule E: Retaining Wall Monitoring                           |                                                                                                     |                                                                                                          |                                                                                         |               |
|-----------------------------------------------------------------|-----------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------|---------------|
| Frequency                                                       |                                                                                                     |                                                                                                          |                                                                                         |               |
| Pre-Commencement of Construction Phase Dewatering               | Commencement of Construction Phase Dewatering to one month after Completion of Excavation           |                                                                                                          | One month after Completion of Excavation to Completion of Construction Phase Dewatering |               |
| Retaining Wall Deflection Stations                              | Retaining Wall Deflection Stations                                                                  | Inclinometers                                                                                            | Retaining Wall Deflection Stations                                                      | Inclinometers |
| Twice to either a horizontal and/or vertical accuracy of +/-2mm | Once for every 2 m depth (on average) of excavation, and, in any case, at a minimum of once weekly. | Once for every 2 m depth (on average) of excavation, and, in any case, at a minimum of once fortnightly. | Fortnightly                                                                             | Monthly       |

### Advice note:

*The monitoring frequency may be changed, if approved by the council, through the GSMCP.*

### Access to Third Party Property

174. Where any monitoring, inspection or condition survey in this consent requires access to property/ies owned by a third party, and access is declined or subject to what the consent holder considers to be unreasonable terms, the consent holder must provide a report to the Council prepared by a SQEP identifying an alternative monitoring programme. The report must describe how the monitoring will provide sufficient early detection of deformation to enable measures to be implemented to prevent Damage to buildings, structures or Services. Written certification from the Council must be obtained before an alternative monitoring option is implemented.

## **DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT**

### **Contingency Actions**

175. If the consent holder becomes aware of any Damage to buildings, structures or Services potentially caused wholly, or in part, by the exercise of this consent, the consent holder must:
- a. Notify the Council and the asset owner immediately as far as is practicable but within 2 working days of the consent holder becoming aware of the Damage.
  - b. Provide a report prepared by a SQEP (engaged by the consent holder at their cost) that describes the Damage; identifies the cause of the Damage; identifies methods to remedy and/or mitigate the Damage that has been caused; identifies the potential for further Damage to occur and describes actions that will be taken to avoid further Damage.
  - c. Provide a copy of the report prepared under (b) above, to the Council and the asset owner within 10 working days of notification under (a) above.

#### **Advice note:**

*It is anticipated the consent holder will seek the permission of the damaged asset to access the property and asset to enable the inspection/investigation. It is understood that if access is denied the report will be of limited extent.*

### **Building, Structure, and Services Surveys and Inspections**

176. A copy of all pre-dewatering building, structure condition surveys, and Service condition surveys and photographic records of external visual inspections required by this consent must be submitted to the council with the GSMCP. All other condition surveys and photographic records required by this consent must be provided to the council upon request.

### **Reporting of Monitoring Data**

177. At two monthly intervals, a report containing all monitoring data required by conditions of this consent must be submitted to the Council. This report must include a construction progress timeline, the monitoring data (including the results of condition surveys) recorded in that period, and a comparison of that data with previously recorded data and with the Alert and Alarm Levels for each Monitoring Station.

### **Notice of Completion**

178. The Council must be advised in writing within 10 working days of when excavation and dewatering has been completed.

#### **Advice note:**

*The Consent Holder is advised that the discharge of pumped groundwater to a stormwater system or waterbody will need to comply with any other regulations, bylaws or discharge rules that may apply.*

## DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

### General advice notes

**Commented [NS43]:** To assist the Panel, we have incorporated our recommended advice notes previously identified within AT's memo dated 29<sup>th</sup> April 2026.

1. Any reference to number of days within this decision refers to working days as defined in s2 of the RMA.
2. For the purpose of compliance with the conditions of consent, "the council" refers to the council's monitoring officer unless otherwise specified. Please email [monitoring@aucklandcouncil.govt.nz](mailto:monitoring@aucklandcouncil.govt.nz) to identify your allocated officer.
3. For more information on the resource consent process with Auckland Council see the council's website: [www.aucklandcouncil.govt.nz](http://www.aucklandcouncil.govt.nz). General information on resource consents, including making an application to vary or cancel consent conditions can be found on the Ministry for the Environment's website: [www.mfe.govt.nz](http://www.mfe.govt.nz).
4. If you disagree with any of the above conditions, and/or disagree with the additional charges relating to the processing of the application(s), you have a right of objection pursuant to sections 357A and/or 357B of the Resource Management Act 1991. Any objection must be made in writing to the council within 15 working days of your receipt of this decision (for s357A) or receipt of the council invoice (for s357B).
5. The consent holder is responsible for obtaining all other necessary consents, permits, and licences, including those under the Building Act 2004, and the Heritage New Zealand Pouhere Taonga Act 2014. This consent does not remove the need to comply with all other applicable Acts (including the Property Law Act 2007 and the Health and Safety at Work Act 2015), regulations, relevant Bylaws, and rules of law. This consent does not constitute building consent approval. Please check whether a building consent is required under the Building Act 2004.
6. Any canopies to be constructed over the private road boundary into the road corridor will require an encroachment licence application. This has not been specifically assessed as part of this application for resource consents. For more information please refer to the following: <https://at.govt.nz/about-us/working-on-the-road/road-processes-for-property-owners/road-encroachment-licences-or-leases/>.
7. Permanent traffic and parking controls as per the advice note above are subject to a Resolution approval from Auckland Transport. Changes to traffic / parking controls on the road reserve will require Auckland Transport Traffic Control Committee (TCC) resolutions. The resolutions, prepared by a qualified traffic engineer, will need to be approved so that the changes to the road reserve can be legally implemented and enforced. The resolution process requires external consultation to be undertaken in accordance with Auckland Transport's standard procedures. It is the responsibility of the consent holder to prepare and

**Formatted:** Font: Italic

**Formatted:** Font: Italic

**Formatted:** Font color: Black

**Formatted:** Font: Italic

## DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

submit a permanent Traffic and Parking Changes report to Auckland Transport Traffic Control Committee (TCC) for review and approval. No changes to the traffic and parking controls will be allowed before the resolution is approved by the Auckland Transport Traffic Control Committee (TCC). All costs shall be borne by the consent holder. Application details and can be found from the following Auckland Transport website link: <https://at.govt.nz/about-us/working-with-at/traffic-and-parking-controls>.

**Formatted:** Font: Italic

**Formatted:** Font: Italic

**Formatted:** Font color: Auto, Do not check spelling or grammar

**Formatted:** Font: Italic

**Formatted:** Font: Italic

8. Engineering Approval – Transport: Prior to the commencement of any engineering works, the consent holder shall submit engineering plans (including engineering calculations and specifications) to the Council for approval in writing. The engineering plans shall include, but not be limited to, the information regarding the detailed design of all roads and road network activities provided for by this resource consent approval.

**Formatted:** Font color: Black

9. As part of the application for Engineering Approval, a registered engineer shall:

**Formatted:** Font: Italic

10. Certify that all public roads and associated road network activities or access ways have been designed in accordance with the Auckland Code for Practice for Land Development and Subdivision – Chapter 3: Transport.

**Formatted:** Font: Font color: Red, English (Australia)

**Formatted:** Font: Italic

**Formatted:** Indent: Left: 0.75 cm, Right: 1.01 cm, Space Before: 6 pt, Line spacing: 1.5 lines, Numbered + Level: 1 + Numbering Style: 1, 2, 3, ... + Start at: 1 + Alignment: Left + Aligned at: 0.95 cm + Indent at: 1.95 cm, No widow/orphan control, Don't adjust space between Latin and Asian text, Don't adjust space between Asian text and numbers, Tab stops: 1.95 cm,

a) Provide a statement that the proposed infrastructure has been designed for the long-term operation and maintenance of the asset.

b) Confirm that all practical measures are included in the design to facilitate safe working conditions in and around the asset.

c) The engineering plan application forms including fees can be found at the following Auckland Council website: <https://www.aucklandcouncil.govt.nz/building-and-consents/engineering-approvals/Pages/default.aspx>.

**Formatted:** Indent: Left: 1.75 cm, Line spacing: 1.5 lines, Numbered + Level: 1 + Numbering Style: a, b, c, ... + Start at: 1 + Alignment: Left + Aligned at: 0.95 cm + Indent at: 1.95 cm

**Formatted:** Font: Italic

**Formatted:** Font: Italic

11. Corridor Access Requests It will be the responsibility of the consent holder to determine the presence of any underground services that may be affected by the Applicants work in the road reserve. Should any services exist, the Applicant shall contact the owners of those and agree on the service owners' future access for maintenance and upgrades. Services information may be obtained from <https://www.beforeudig.co.nz/>.

**Formatted:** List Paragraph, List Paragraph 1, Bulleted list in paragraph, Report Paragraph, Header 1 - Network Consent, Line spacing: 1.5 lines, Numbered + Level: 1 + Numbering Style: 1, 2, 3, ... + Start at: 1 + Alignment: Left + Aligned at: 0.95 cm + Indent at: 1.95 cm

All work in the road reserve shall be carried out in accordance with the general requirements of The National Code of Practice for Utility Operators' Access to Transport Corridors <http://nzuaq.org.nz/national-code/ApprovedNationalCodeFeb13.pdf> and Auckland Transport Design Manual <https://at.govt.nz/about-us/manuals-guidelines/transport-design-manual/>.

**Formatted:** List Paragraph, List Paragraph 1, Bulleted list in paragraph, Report Paragraph, Header 1 - Network Consent, Indent: Left: 0 cm, Line spacing: 1.5 lines

Prior to carrying out any work in the road corridor, the consent holder shall submit to Auckland Transport a Corridor Access Request (CAR) and temporary traffic management plan (TMP), the latter prepared by an NZ Transport Agency qualified person and work shall not commence until

**Formatted:** List Paragraph, List Paragraph 1, Bulleted list in paragraph, Report Paragraph, Header 1 - Network Consent, Indent: Left: 0 cm, First line: 0 cm, Line spacing: 1.5 lines

## DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

such time as the Applicant has approval in the form of a Works Access Permit (WAP). An assessment undertaken under the framework of the Resource Management Act does not constitute an equivalent approval for the required CAR or TMP. The application may be made at <https://ot.govt.nz/about-us/working-on-the-road/corridor-access-requests/apply-for-a-car/> and 15 working days should be allowed for approval.

5. \_\_\_\_\_

Formatted: Normal, No bullets or numbering

~~6-12.~~ The consent holder is responsible for ensuring that all development and associated works (including mobile plant and scaffolding) complies with the minimum safe distances from overhead electric lines in compliance with the New Zealand Electrical Code of Practice for Electrical Safe Distances (NZECP 34:2001) (NZECP34). Resource consent does not confirm compliance with NZECP34. The consent holder should ensure that minimum safe distances are achieved before commencing construction where there are overhead electrical lines nearby.

You can search your site address at <https://www.ena.org.nz/lines-company-map/> to identify your local lines company.

Vector network: <https://www.vector.co.nz/personal/help-safety/near-our-network/building-near-overhead-lines>

Counties Energy network: <https://www.countiesenergy.co.nz/forms/close-approach-permit>

~~7-13.~~ A Work Over Approval with Watercare may be required.

~~8-14.~~ Any reference to Auckland Transport throughout these conditions may instead be a reference to Auckland Council if Auckland Council has the relevant road controlling authority functions relevant to the condition.

~~9-15.~~ The minimum requirement of providing 1.2m gravity fall within the proposed wastewater connections is required to comply with in accordance with the Water and Wastewater CoP – WW17.

~~10-16.~~ Any works done on land affected by an Auckland Transport Designation need written consent from AT before the works can begin.

~~11-17.~~ All new water supply connections for the proposed units to the Watercare supply main shall be designed in accordance with Watercare Services Ltd's Standards and be completed by a Watercare Services Ltd approved contractor. For details, please contact Watercare Services Ltd.

~~12-18.~~ Individual underground telecommunications and power cables shall be installed to service the proposed units and must be installed and suitably marked within the road reserve and lot service connection location to the specification and satisfaction of the relevant authority and Auckland Council. If required, relevant gas reticulation and fibre optic services may also be

## DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

*provided.*

*Certification from the relevant utility provider is required to verify satisfactory completion of works.*

*[13.19.](#) A vehicle crossing application(s) should be approved by Auckland Transport prior to construction of new vehicle access(es) to the site or altering/widening of the existing vehicle crossing(s).*

*[14.20.](#) It is recommended that a visual inspection of the founding soils be undertaken by a geo-professional during the excavation works to determine the suitability of the subgrade and potential effects on the proposed foundations.*

*[15.21.](#) Additional geotechnical investigations may be required for final design for Building Consent.*

*[16.22.](#) Geotechnical review of the detailed design drawings may be required to confirm their recommendations have been adopted for Building Consent.*

*[17.23.](#) It is anticipated the consent holder will seek the permission from the potentially damaged building, services or landowner to access the property and asset to enable the inspection/investigation. It is understood that if access is denied the report will be of limited extent.*

## DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

### ATTACHMENT 1: TABLE OF REPORTS

| Report title and reference                                                                                                | Author                                  | Rev | Dated                                        |
|---------------------------------------------------------------------------------------------------------------------------|-----------------------------------------|-----|----------------------------------------------|
| Downtown Carpark Site Development<br>Fast-track Approvals Act Substantive<br>Application<br>17782                         | Barker &<br>Associates                  |     | <del>7 November</del><br>18 December<br>2025 |
| Architecture & Landscape Report                                                                                           | Warren and<br>Mahoney                   | B   | 03/10/25                                     |
| 9234 Downtown Carpark Redevelop<br>Stion 67 Request for Information                                                       | Warren and<br>Mahoney                   | -   | 2 April 2026                                 |
| Downtown Carpark Site Development<br>Te Pūmanawa O Tāmaki                                                                 | Haumi (NZ)                              | -   | -                                            |
| Downtown Carpark Site Development<br>Urban Design Assessment                                                              | McIndoe Urban                           | -   | 06 November                                  |
| MUL Urban Design Memo #15: Urban<br>Design Response to Auckland Council<br>Urban Design Feedback                          | McIndoe Urban                           | -   | 30 March<br>2026                             |
| Downtown Carpark Site Development<br>Landscape Assessment<br>5024 / C2                                                    | Isthmus                                 | -   | November<br>2025                             |
| <del>Downtown Carpark Site Development<br/>Construction Noise and Vibration<br/>Management Plan<br/>Rp 007-20230126</del> | <del>Marshall Day<br/>Acoustics</del>   | -   | <del>6/11/2025</del>                         |
| Downtown West Acoustic Assessment<br>Addendum                                                                             | Marshall Day<br>Acoustics               | -   | 1 April 2026                                 |
| Operational Integrated Transport<br>Assessment<br>R5D251107                                                               | Flow<br>Transportation<br>Specialists   | -   | 07 November<br>2025                          |
| Downtown Carpark Site Development<br>Draft Construction Management Plan                                                   | RCP and Pier<br>Property<br>Corporation | 4   | 9/10/2025                                    |
| Draft Erosion Sediment Control Plan<br>1016043.2000 v1                                                                    | Tonkin + Taylor                         | 1   | November<br>2025                             |
| Downtown West Redevelopment<br>Erosion and Sediment Control<br>Management Plan Addendum<br>1016043.2000                   | Tonkin + Taylor                         | -   | 2 April 2026                                 |

## DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

|                                                                                                       |                                 |       |                                           |
|-------------------------------------------------------------------------------------------------------|---------------------------------|-------|-------------------------------------------|
| Preliminary Detailed Site Investigation Report<br>1016043.1000 v2                                     | Tonkin + Taylor                 | 2     | 6 November 2025                           |
| Downtown Weste Development Geotechnical Addendum Report<br>1016043.2000                               | Tonkin + Taylor                 | -     | 7 April 2026                              |
| Draft Contamination Site Management Plan<br>1016043.2000 v2                                           | Tonkin + Taylor                 | 2     | November 2025                             |
| Arboricultural Assessment                                                                             | Peers Brown Miller              | -     | 4/11/25                                   |
| Infrastructure Concept Design Report<br>1016043.1000 v1                                               | Tonkin + Taylor                 | 1     | November 2025                             |
| Draft Operational Waste Management Plan<br>3-C2490.01                                                 | WSP                             | 1     | 10 October 2025                           |
| Consultation Summary Report                                                                           | Barker & Associates             | -     | <del>7 November</del><br>18 December 2025 |
| Flood Hazard and Risk Assessment<br>1016043.2000 v7                                                   | Tonkin + Taylor                 | 7     | 07/11/2025                                |
| Downtown Carpark Redevelopment = Section 67 request coastal and flood hazard response<br>1016043.2000 | Tonkin + Taylor                 | -     | 7 April 2026                              |
| Air Quality Assessment<br>1016043.2000 v3.0                                                           | Tonkin + Taylor                 | 3     | November 2025                             |
| Dust Management Plan<br>1016043.1000 v2.0                                                             | Tonkin + Taylor                 | 2     | November 2025                             |
| Draft Construction Traffic Management Plan<br>R6C251106                                               | Flow Transportation Specialists |       | 06 November 2025                          |
| Draft Construction Noise and Vibration Management Plan<br>Rp 007 20230126                             | Marshall Day Acoustics.         | -     | 6 November 2025                           |
| Environmental Winds Report<br>145828.16                                                               | Holmes                          | ISSUE | 29 October 2025                           |
| Draft Servicing and Loading Management Plan                                                           | Flow Transportation Specialists |       | 06 November 2025                          |
| Draft Hotel Pick-Up and Drop-Off Management Plan                                                      | Flow Transportation Specialists |       | 06 November 2025                          |

## DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

|                                                                                                                                 |                                 |                    |                                   |
|---------------------------------------------------------------------------------------------------------------------------------|---------------------------------|--------------------|-----------------------------------|
| Draft Managed Access Service Arrangement Plan (M Social)                                                                        | Flow Transportation Specialists |                    | 03 November 2025                  |
| Draft Hazardous Substances Management Plan – Downtown West 1016043.2000 v1                                                      | Tonkin + Taylor                 | 1                  | November 2025                     |
| Groundwater Assessment Report 1016043.2000-RPT-GT-001                                                                           | Tonkin + Taylor                 | 3.1                | Nov 2025                          |
| Draft Groundwater and Settlement Monitoring and Contingency Plan 1016043.2000 v5.1 v6.0                                         | Tonkin + Taylor                 | <del>5.1</del> 6.0 | <del>November 2025</del> May 2026 |
| Downtown Carpark Development, Auckland: Fast Track Archaeological Assessment                                                    | Clough & Associates             |                    | October 2025                      |
| Draft Archaeological Management Plan: Downtown Carpark Development, Auckland Fast Track                                         | Clough & Associates             |                    | October 2025                      |
| Downtown West Development Fast Track Application Economic Impact Overview 52492.10                                              | Property Economics              |                    | <del>October</del> November 2025  |
| Re: Downtown Carpark Site Development Fast-track Economic Impact Assessment                                                     | Property Economics              | -                  | 7 April 2026                      |
| St Patrick's Square Public Space Audit Summary Report                                                                           | Barker & Associates             | -                  | 4 September 2025                  |
| Acoustic Assessment of Effects Rp 006 20230126                                                                                  | Marshall Day Acoustics.         | -                  | 6 November 2025                   |
| CPTED Assessment 14987                                                                                                          | Barker & Associates             |                    | 28/10/2025                        |
| Demolition and Construction Transport Assessment R4C251106                                                                      | Flow Transportation Specialists |                    | 06 November 2025                  |
| Downtown Carpark Site Development FTAA Addendum Transport Report                                                                | Flow Transportation Specialists | -                  | 7 April 2026                      |
| Report regarding the needs for a Porte cochere, including a pick-up and drop-off facility for a proposed hotel in Auckland, NZ. | THSA - Hotel Advisors           |                    | 4 November 2025                   |
| Asbestos Management Plan 60607392                                                                                               | AECOM New Zealand               | 2                  | 07 February 2020                  |
| Hazardous Substances Assessment – Diesel storage for back-up generation - Downtown West 1016043.2000 v1                         | Tonkin + Taylor                 | 1                  | November 2025                     |

## DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

|                                                                                   |                 |   |              |
|-----------------------------------------------------------------------------------|-----------------|---|--------------|
| Downtown West Development<br>Hazardous substances addendum report<br>1016043.2000 | Tonkin + Taylor | - | 2 April 2026 |
| Coastal hazard and risk assessment<br>1016043 v3                                  | Tonkin + Taylor | 3 | 07/11/2025   |

## DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

### ATTACHMENT 2: DRAWINGS

| Plan title and reference              | Author             | Rev | Dated    |
|---------------------------------------|--------------------|-----|----------|
| <b><i>Drawings – Architecture</i></b> |                    |     |          |
| Render 01 FTA-00-201                  | Warren and Mahoney | B   | 03/10/25 |
| Render 02 FTA-00-202                  | Warren and Mahoney | B   | 03/10/25 |
| Render 03 FTA-00-203                  | Warren and Mahoney | B   | 03/10/25 |
| Render 04 FTA-00-204                  | Warren and Mahoney | B   | 03/10/25 |
| Render 05 FTA-00-205                  | Warren and Mahoney | B   | 03/10/25 |
| Render 06 FTA-00-206                  | Warren and Mahoney | B   | 03/10/25 |
| Render 07 FTA-00-207                  | Warren and Mahoney | B   | 03/10/25 |
| Render 08 FTA-00-208                  | Warren and Mahoney | B   | 03/10/25 |
| Render 09 FTA-00-209                  | Warren and Mahoney | B   | 03/10/25 |
| Render 10 FTA-00-210                  | Warren and Mahoney | B   | 03/10/25 |
| Render 11 FTA-00-211                  | Warren and Mahoney | B   | 03/10/25 |
| Render 12 FTA-00-212                  | Warren and Mahoney | B   | 03/10/25 |
| Render 13 FTA-00-213                  | Warren and Mahoney | B   | 03/10/25 |
| Project Location Plan FTA-01-001      | Warren and Mahoney | C   | 03/10/25 |
| Existing Site Plan FTA-02-001         | Warren and Mahoney | C   | 03/10/25 |
| Proposed Site Plan FTA-05-001         | Warren and Mahoney | C   | 03/10/25 |

## DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

| Plan title and reference                                        | Author             | Rev | Dated    |
|-----------------------------------------------------------------|--------------------|-----|----------|
| Tower Floor Plate Dimensions above 28m FTA-05-003               | Warren and Mahoney | C   | 03/10/25 |
| Mean Street Level Plan FTA-05-005                               | Warren and Mahoney | C   | 03/10/25 |
| General Arrangement – Floor Plan – Sub Basement FTA-10-095      | Warren and Mahoney | C   | 03/10/25 |
| General Arrangement – Floor Plan – Basement 04 FTA-10-096       | Warren and Mahoney | C   | 03/10/25 |
| General Arrangement – Floor Plan – Basement 03 FTA-10-097       | Warren and Mahoney | C   | 03/10/25 |
| General Arrangement – Floor Plan – Basement 02 FTA-10-098       | Warren and Mahoney | C   | 03/10/25 |
| General Arrangement – Floor Plan – Basement 01 FTA-10-099       | Warren and Mahoney | C   | 03/10/25 |
| General Arrangement – Floor Plan – Level 00 FTA-10-100          | Warren and Mahoney | C   | 03/10/25 |
| General Arrangement – Floor Plan – Level 01 FTA-10-101          | Warren and Mahoney | C   | 03/10/25 |
| General Arrangement – Floor Plan – Level 02 FTA-10-102          | Warren and Mahoney | C   | 03/10/25 |
| General Arrangement – Floor Plan – Level 03 FTA-10-103          | Warren and Mahoney | C   | 03/10/25 |
| General Arrangement – Floor Plan – Level 04 FTA-10-104          | Warren and Mahoney | C   | 03/10/25 |
| General Arrangement – Floor Plan – Level 05 FTA-10-105          | Warren and Mahoney | C   | 03/10/25 |
| General Arrangement – Floor Plan – Level 06 FTA-10-106          | Warren and Mahoney | C   | 03/10/25 |
| General Arrangement – Floor Plan – Level 07 FTA-10-107          | Warren and Mahoney | C   | 03/10/25 |
| General Arrangement – Floor Plan – T1 Level 08 & 08M FTA-10-201 | Warren and Mahoney | C   | 03/10/25 |
| General Arrangement – Floor Plan – T1 Level 09 & 10 FTA-10-202  | Warren and Mahoney | C   | 03/10/25 |
| General Arrangement – Floor Plan – T1 Level 11 & 12 FTA-10-203  | Warren and Mahoney | C   | 03/10/25 |

## DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

| Plan title and reference                                       | Author             | Rev | Dated    |
|----------------------------------------------------------------|--------------------|-----|----------|
| General Arrangement – Floor Plan – T1 Level 13 & 14 FTA-10-204 | Warren and Mahoney | C   | 03/10/25 |
| General Arrangement – Floor Plan – T1 Level 15 & 16 FTA-10-205 | Warren and Mahoney | C   | 03/10/25 |
| General Arrangement – Floor Plan – T1 Level 17 & 18 FTA-10-206 | Warren and Mahoney | C   | 03/10/25 |
| General Arrangement – Floor Plan – T1 Level 19 & 20 FTA-10-207 | Warren and Mahoney | C   | 03/10/25 |
| General Arrangement – Floor Plan – T1 Level 21 & 22 FTA-10-208 | Warren and Mahoney | C   | 03/10/25 |
| General Arrangement – Floor Plan – T1 Level 23 & 24 FTA-10-209 | Warren and Mahoney | C   | 03/10/25 |
| General Arrangement – Floor Plan – T1 Level 25 & 26 FTA-10-210 | Warren and Mahoney | C   | 03/10/25 |
| General Arrangement – Floor Plan – T1 Level 27 & 28 FTA-10-211 | Warren and Mahoney | C   | 03/10/25 |
| General Arrangement – Floor Plan – T1 Level 29 & 30 FTA-10-212 | Warren and Mahoney | C   | 03/10/25 |
| General Arrangement – Floor Plan – T1 Level 31 & 32 FTA-10-213 | Warren and Mahoney | C   | 03/10/25 |
| General Arrangement – Floor Plan – T1 Level 33 & 34 FTA-10-214 | Warren and Mahoney | C   | 03/10/25 |
| General Arrangement – Floor Plan – T1 Level 35 & 36 FTA-10-215 | Warren and Mahoney | C   | 03/10/25 |
| General Arrangement – Floor Plan – T1 Level 37 & 38 FTA-10-216 | Warren and Mahoney | C   | 03/10/25 |
| General Arrangement – Floor Plan – T1 Level 39 & 40 FTA-10-217 | Warren and Mahoney | C   | 03/10/25 |
| General Arrangement – Floor Plan – T1 Level 41 & 42 FTA-10-218 | Warren and Mahoney | C   | 03/10/25 |
| General Arrangement – Floor Plan – T1 Level 43 & 44 FTA-10-219 | Warren and Mahoney | C   | 03/10/25 |
| General Arrangement – Floor Plan – T1 Level 45 & 46 FTA-10-220 | Warren and Mahoney | C   | 03/10/25 |
| General Arrangement – Floor Plan – T1 Level 47 & 48 FTA-10-221 | Warren and Mahoney | C   | 03/10/25 |

## DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

| Plan title and reference                                            | Author             | Rev | Dated    |
|---------------------------------------------------------------------|--------------------|-----|----------|
| General Arrangement – Floor Plan – T1 Level 49 & 50 FTA-10-222      | Warren and Mahoney | C   | 03/10/25 |
| General Arrangement – Floor Plan – T1 Level 51 & 52 FTA-10-223      | Warren and Mahoney | C   | 03/10/25 |
| General Arrangement – Floor Plan – T1 Level 53 & Parapet FTA-10-224 | Warren and Mahoney | C   | 03/10/25 |
| General Arrangement – Floor Plan – T2 Level 07M & 08 FTA-10-301     | Warren and Mahoney | C   | 03/10/25 |
| General Arrangement – Floor Plan – T2 Level 09 & 10 FTA-10-302      | Warren and Mahoney | C   | 03/10/25 |
| General Arrangement – Floor Plan – T2 Level 11 & 12 FTA-10-303      | Warren and Mahoney | C   | 03/10/25 |
| General Arrangement – Floor Plan – T2 Level 13 & 14 FTA-10-304      | Warren and Mahoney | C   | 03/10/25 |
| General Arrangement – Floor Plan – T2 Level 15 & 16 FTA-10-305      | Warren and Mahoney | C   | 03/10/25 |
| General Arrangement – Floor Plan – T2 Level 17 & 18 FTA-10-306      | Warren and Mahoney | C   | 03/10/25 |
| General Arrangement – Floor Plan – T2 Level 19 & 20 FTA-10-307      | Warren and Mahoney | C   | 03/10/25 |
| General Arrangement – Floor Plan – T2 Level 21 & 22 FTA-10-308      | Warren and Mahoney | C   | 03/10/25 |
| General Arrangement – Floor Plan – T2 Level 23 & 24 FTA-10-309      | Warren and Mahoney | C   | 03/10/25 |
| General Arrangement – Floor Plan – T2 Level 25 & 26 FTA-10-310      | Warren and Mahoney | C   | 03/10/25 |
| General Arrangement – Floor Plan – T2 Level 27 & 28 FTA-10-311      | Warren and Mahoney | C   | 03/10/25 |
| General Arrangement – Floor Plan – T2 Level 29 & 30 FTA-10-312      | Warren and Mahoney | C   | 03/10/25 |
| General Arrangement – Floor Plan – T2 Level 31 & 32 FTA-10-313      | Warren and Mahoney | C   | 03/10/25 |
| General Arrangement – Floor Plan – T2 Level 33 & 34 FTA-10-314      | Warren and Mahoney | C   | 03/10/25 |
| General Arrangement – Floor Plan – T2 Level 35 & 36 FTA-10-315      | Warren and Mahoney | C   | 03/10/25 |

## DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

| Plan title and reference                                       | Author             | Rev | Dated    |
|----------------------------------------------------------------|--------------------|-----|----------|
| General Arrangement – Floor Plan – T2 Level 37 & 38 FTA-10-316 | Warren and Mahoney | C   | 03/10/25 |
| General Arrangement – Floor Plan – T2 Level 39 & 40 FTA-10-317 | Warren and Mahoney | C   | 03/10/25 |
| General Arrangement – Floor Plan – T2 Level 41 & 42 FTA-10-318 | Warren and Mahoney | C   | 03/10/25 |
| General Arrangement – Floor Plan – T2 Level 43 & 44 FTA-10-319 | Warren and Mahoney | C   | 03/10/25 |
| General Arrangement – Elevation & Section Key Plan FTA-20-000  | Warren and Mahoney | C   | 03/10/25 |
| Site Elevations FTA-21-001                                     | Warren and Mahoney | C   | 03/10/25 |
| Site Elevations FTA-21-002                                     | Warren and Mahoney | C   | 03/10/25 |
| Site Elevations FTA-21-003                                     | Warren and Mahoney | C   | 03/10/25 |
| Tower 01 – Building Elevations FTA-22-001                      | Warren and Mahoney | C   | 03/10/25 |
| Tower 01 – Building Elevations FTA-22-002                      | Warren and Mahoney | C   | 03/10/25 |
| Tower 02 – Building Elevations FTA-22-003                      | Warren and Mahoney | C   | 03/10/25 |
| Tower 02 – Building Elevations FTA-22-004                      | Warren and Mahoney | C   | 03/10/25 |
| Podium 03 – Building Elevations FTA-22-005                     | Warren and Mahoney | C   | 03/10/25 |
| Street Elevations FTA-23-001                                   | Warren and Mahoney | C   | 03/10/25 |
| Street Elevations FTA-23-002                                   | Warren and Mahoney | C   | 03/10/25 |
| Street Elevations FTA-23-004                                   | Warren and Mahoney | C   | 03/10/25 |
| Site Sections FTA-31-001                                       | Warren and Mahoney | C   | 03/10/25 |
| Site Sections FTA-31-002                                       | Warren and Mahoney | C   | 03/10/25 |

## DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

| Plan title and reference                                          | Author             | Rev | Dated    |
|-------------------------------------------------------------------|--------------------|-----|----------|
| Street Sections FTA-32-001                                        | Warren and Mahoney | C   | 03/10/25 |
| Street Sections FTA-32-002                                        | Warren and Mahoney | C   | 03/10/25 |
| Tower 2 – Apartment Schedule FTA-82-001                           | Warren and Mahoney | C   | 03/10/25 |
| <b>Drawings – Landscape</b>                                       |                    |     |          |
| Landscape Concept Ground Level Plan Existing Context L01.003      | Warren and Mahoney | I   | 03/10/25 |
| Landscape Concept Combined Levels Plan Existing Context L01.004   | Warren and Mahoney | I   | 03/10/25 |
| Levels Strategy L01.005                                           | Warren and Mahoney | I   | 03/10/25 |
| Landscape Concept Te Urunga Hau L01.101                           | Warren and Mahoney | G   | 03/10/25 |
| Landscape Concept Aon Podium L01.102                              | Warren and Mahoney | G   | 03/10/25 |
| Landscape Sections Te Urunga Hau L20.101                          | Warren and Mahoney | F   | 03/10/25 |
| Landscape Sections Te Urunga Hau L20.102                          | Warren and Mahoney | F   | 03/10/25 |
| Landscape Sections Te Urunga Hau L20.103                          | Warren and Mahoney | F   | 03/10/25 |
| Landscape Sections Te Urunga Hau L20.104                          | Warren and Mahoney | F   | 03/10/25 |
| Landscape Concept Roof Terrace L01.103                            | Warren and Mahoney | G   | 03/10/25 |
| <b>Drawings – Demolition</b>                                      |                    |     |          |
| Demolition Axonometric – Carpark FTA-04-001                       | Warren and Mahoney | C   | 03/10/25 |
| Demolition Plan – Carpark Upper Basement Level (North) FTA-04-101 | Warren and Mahoney | C   | 03/10/25 |
| Demolition Plan – Carpark Upper Basement Level (South) FTA-04-102 | Warren and Mahoney | C   | 03/10/25 |
| Demolition Plan – Carpark Upper Ground Level (North) FTA-04-103   | Warren and Mahoney | C   | 03/10/25 |

## DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

| Plan title and reference                                        | Author             | Rev | Dated    |
|-----------------------------------------------------------------|--------------------|-----|----------|
| Demolition Plan – Carpark Upper Ground Level (South) FTA-04-104 | Warren and Mahoney | C   | 03/10/25 |
| Demolition Plan – Carpark Upper First Level (North) FTA-04-105  | Warren and Mahoney | C   | 03/10/25 |
| Demolition Plan – Carpark Upper First Level (South) FTA-04-106  | Warren and Mahoney | C   | 03/10/25 |
| Demolition Plan – Carpark Upper Third Level (North) FTA-04-107  | Warren and Mahoney | C   | 03/10/25 |
| Demolition Plan – Carpark Upper Level 3 (South) FTA-04-108      | Warren and Mahoney | C   | 03/10/25 |
| Demolition Plan – Carpark Level 8 (Roof) FTA-04-109             | Warren and Mahoney | C   | 03/10/25 |
| Demolition Plan – Aon Upper Basement and HSBC L3 FTA-04-110     | Warren and Mahoney | C   | 03/10/25 |
| Demolition Plan – Aon Plaza and HSBC L3 FTA-04-111              | Warren and Mahoney | C   | 03/10/25 |
| Demolition Plan – Aon L2 and HSBC L7 L3 FTA-04-112              | Warren and Mahoney | C   | 03/10/25 |
| Demolition Elevations – Carpark West and South FTA-04-201       | Warren and Mahoney | C   | 03/10/25 |
| Demolition Elevations – Carpark East and North FTA-04-202       | Warren and Mahoney | C   | 03/10/25 |
| Demolition Elevations – Aon and HSBC East and South FTA-04-203  | Warren and Mahoney | C   | 03/10/25 |
| Demolition Elevations – Pedestrian Foot Bridge FTA-04-204       | Warren and Mahoney | C   | 03/10/25 |
| Demolition Elevations – Overpass Ramp FTA-04-205                | Warren and Mahoney | C   | 03/10/25 |
| Demolition Cross Sections – Carpark FTA-04-301                  | Warren and Mahoney | C   | 03/10/25 |
| Demolition Longitudinal Sections – Carpark FTA-04-302           | Warren and Mahoney | C   | 03/10/25 |
| Demolition Sections – Aon and HSBC Laneways FTA-04-303          | Warren and Mahoney | C   | 03/10/25 |
| <b>Drawings – Shading Analysis</b>                              |                    |     |          |

## DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

| Plan title and reference                                                       | Author             | Rev | Dated    |
|--------------------------------------------------------------------------------|--------------------|-----|----------|
| City Scope Shading Analysis Spring Equinox Sep 23 - 0700-1200 FTA-81-001       | Warren and Mahoney | D   | 17/10/25 |
| City Scope Shading Analysis Spring Equinox Sep 23 - 1300-1800 FTA-81-002       | Warren and Mahoney | D   | 17/10/25 |
| City Scope Shading Analysis Summer Solstice Dec 21 - 0700-1200 FTA-81-003      | Warren and Mahoney | D   | 17/10/25 |
| City Scope Shading Analysis Summer Solstice Dec 21 - 1300-1800 FTA-81-004      | Warren and Mahoney | D   | 17/10/25 |
| City Scope Shading Analysis Summer Solstice Dec 21 - 1900-2000 FTA-81-005      | Warren and Mahoney | D   | 17/10/25 |
| City Scope Shading Analysis Winter Solstice Jun 21 - 0800-1300 FTA-81-006      | Warren and Mahoney | D   | 17/10/25 |
| City Scope Shading Analysis Winter Solstice Jun 21 - 1400-1700 FTA-81-007      | Warren and Mahoney | D   | 17/10/25 |
| St Patrick's Sq Shading Analysis Spring Equinox Sep 23 - 1000-1115 FTA-81-010  | Warren and Mahoney | D   | 17/10/25 |
| St Patrick's Sq Shading Analysis Spring Equinox Sep 23 - 1130-1245 FTA-81-011  | Warren and Mahoney | D   | 17/10/25 |
| St Patrick's Sq Shading Analysis Spring Equinox Sep 23 - 1300-1400 FTA-81-012  | Warren and Mahoney | D   | 17/10/25 |
| St Patrick's Sq Shading Analysis Summer Solstice Dec 21 - 1000-1115 FTA-81-013 | Warren and Mahoney | D   | 17/10/25 |
| St Patrick's Sq Shading Analysis Summer Solstice Dec 21 - 1130-1245 FTA-81-014 | Warren and Mahoney | D   | 17/10/25 |
| St Patrick's Sq Shading Analysis Summer Solstice Dec 21 - 1300-1400 FTA-81-015 | Warren and Mahoney | D   | 17/10/25 |
| St Patrick's Sq Shading Analysis Winter Solstice Jun 21 - 1000-1115 FTA-81-016 | Warren and Mahoney | D   | 17/10/25 |

## DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

| Plan title and reference                                                             | Author             | Rev | Dated    |
|--------------------------------------------------------------------------------------|--------------------|-----|----------|
| St Patrick's Sq Shading Analysis<br>Winter Solstice Jun 21 - 1130-1245<br>FTA-81-017 | Warren and Mahoney | D   | 17/10/25 |
| St Patrick's Sq Shading Analysis<br>Winter Solstice Jun 21 - 1300-1400<br>FTA-81-018 | Warren and Mahoney | D   | 17/10/25 |
| St Patrick's Sq Shading Analysis Jul<br>29 - 1000-1115 FTA-81-019                    | Warren and Mahoney | A   | 17/10/25 |
| St Patrick's Sq Shading Analysis Jul<br>29 1130-1245 FTA-81-020                      | Warren and Mahoney | A   | 17/10/25 |
| St Patrick's Sq Shading Analysis Jul<br>29 - 1300-1400 FTA-81-021                    | Warren and Mahoney | A   | 17/10/25 |
| Urban Room Shading Analysis<br>Spring Equinox Sep 23 - 1000-1500<br>FTA-81-022       | Warren and Mahoney | D   | 17/10/25 |
| Urban Room Shading Analysis<br>Summer Solstice Dec 21 - 1000-1500<br>FTA-81-023      | Warren and Mahoney | D   | 17/10/25 |
| Urban Room Shading Analysis<br>Winter Solstice Jun 21 - 1000-1500<br>FTA-81-024      | Warren and Mahoney | D   | 17/10/25 |
| Urban Room 3D Shading Analysis<br>Spring Equinox Sep 23 - 0800-1600<br>FTA-81-025    | Warren and Mahoney | D   | 17/10/25 |
| Urban Room 3D Shading Analysis<br>Spring Equinox Sep 23 - 1700-1700<br>FTA-81-026    | Warren and Mahoney | D   | 17/10/25 |
| Urban Room 3D Shading Analysis<br>Summer Solstice Dec 21 - 0630-1330<br>FTA-81-027   | Warren and Mahoney | D   | 17/10/25 |
| Urban Room 3D Shading Analysis<br>Summer Solstice Dec 21 - 1400-1600<br>FTA-81-028   | Warren and Mahoney | D   | 17/10/25 |
| Urban Room 3D Shading Analysis<br>Winter Solstice Jun 21 - 0900-1630<br>FTA-81-029   | Warren and Mahoney | D   | 17/10/25 |
| Urban Room 3D Shading Analysis<br>Winter Solstice Jun 21 - 1700-1700<br>FTA-81-030   | Warren and Mahoney | D   | 17/10/25 |
| <b>Drawings – Infrastructure Design</b>                                              |                    |     |          |
| General                                                                              |                    |     |          |

## DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

| Plan title and reference                                              | Author          | Rev | Dated    |
|-----------------------------------------------------------------------|-----------------|-----|----------|
| Drawing List and Locality Plan<br>1016043.2000-0001                   | Tonkin + Taylor | 2   | 06/11/25 |
| General Notes and Legends<br>1016043.2000-0010                        | Tonkin + Taylor | 2   | 06/11/25 |
| Overall Services Plan<br>1016043.2000-0020                            | Tonkin + Taylor | 2   | 06/11/25 |
| Overall Roading Plan 1016043.2000-0021                                | Tonkin + Taylor | 2   | 06/11/25 |
| Earthworks                                                            |                 |     |          |
| Cut And Fill Plan<br>1016043.2000-1100                                | Tonkin + Taylor | 1   | 06/11/25 |
| Water                                                                 |                 |     |          |
| Connections 1 and 2<br>1016043.2000-2100                              | Tonkin + Taylor | 2   | 06/11/25 |
| Standard Details<br>1016043.2000-2400                                 | Tonkin + Taylor | 2   | 06/11/25 |
| Wastewater                                                            |                 |     |          |
| On-Site Storage / Off-Peak Pumping<br>1016043.2000-3050               | Tonkin + Taylor | 1   | 06/11/25 |
| Pump Station And Rising Main To Nelson St<br>1016043.2000-3051        | Tonkin + Taylor | 1   | 06/11/25 |
| Pump Station And Rising Main To Wellesly St West<br>1016043.2000-3052 | Tonkin + Taylor | 1   | 06/11/25 |
| Private Rising Main Through Precinct Land<br>1016043.2000-3053        | Tonkin + Taylor | 1   | 06/11/25 |
| Standard Details<br>1016043.2000-3400                                 | Tonkin + Taylor | 2   | 06/11/25 |
| Stormwater                                                            |                 |     |          |
| Network 1 - Sheet 1<br>1016043.2000-4100 2                            | Tonkin + Taylor | 2   | 06/11/25 |
| Network 1 - Sheet 2<br>1016043.2000-4101 2                            | Tonkin + Taylor | 2   | 06/11/25 |

## DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

| Plan title and reference                             | Author          | Rev | Dated    |
|------------------------------------------------------|-----------------|-----|----------|
| Standard Details<br>1016043.2000-4400                | Tonkin + Taylor | 2   | 06/11/25 |
| Rooding                                              |                 |     |          |
| Proposed Rooding Plan - Sheet 1<br>1016043.2000-6100 | Tonkin + Taylor | 2   | 06/11/25 |
| Proposed Rooding Plan - Sheet 2<br>1016043.2000-6101 | Tonkin + Taylor | 2   | 06/11/25 |
| Typical Sections<br>1016043.2000-6200                | Tonkin + Taylor | 2   | 06/11/25 |
| Standard Details<br>1016043.2000-6400                | Tonkin + Taylor | 2   | 06/11/25 |

## DOWNTOWN CARPARK SITE DEVELOPMENT - CONDITIONS OF CONSENT

### ATTACHMENT 3: VIADUCT STREETS

