

13 March 2025

www.marshallday.com

Attention: [REDACTED]

RANGITOOPUNI DEVELOPMENT CONSTRUCTION NOISE & VIBRATION

Dear [REDACTED]

As requested, we have reviewed the RangitooPuni Development masterplan prepared by Boffa Miskell, received via email on 26 February 2025. We expect construction noise and vibration to readily comply with the relevant Auckland Unitary Plan standards based on:

- Large setback distances (>100 metres) between the proposed development and the existing dwellings in the area; and
- Noisy activities being undertaken during normal daytime construction hours of 7.30 am to 6 pm, Monday to Saturday.

Should the consent decision makers wish to include a condition relating to construction noise and vibration, we provide the following example:

Construction of the development must be planned and managed so that construction noise and vibration comply with AUP Standards E25.6.27 and E25.6.30.

We trust this information is satisfactory. If you have any further questions, please do not hesitate to contact us.

Yours faithfully

MARSHALL DAY ACOUSTICS LIMITED

[REDACTED]
[REDACTED]
Senior Acoustic Engineer